



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM**

STATE ONLY NATURAL MINOR OPERATING PERMIT

Issue Date: March 13, 2023

Effective Date: March 13, 2023

Expiration Date: March 13, 2028

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

State Only Permit No: 58-00013

Natural Minor

Federal Tax Id - Plant Code: 46-0833495-1

Owner Information

Name: ROUNDTOP ENERGY LLC
Mailing Address: 106 ISABELLA ST STE 600
PITTSBURGH, PA 15212-5841

Plant Information

Plant: ROUNDTOP ENERGY/AUBURN
Location: 58 Susquehanna County 58905 Auburn Township
SIC Code: 4911 Trans. & Utilities - Electric Services

Responsible Official

Name: JOE BROADWATER
Title: VP OF OPERATIONS
Phone: (814) 226 - 0851 Ext.1038 Email: Joe.Broadwater@imgenergysolutions.com

Permit Contact Person

Name: SHANNON LORD
Title: MANAGER, EHS
Phone: (724) 933 - 0140 Ext.402 Email: Shannon.Lord@imgenergysolutions.com

[Signature] _____
MARK J. WEJKSZNER, NORTHEAST REGION AIR PROGRAM MANAGER



SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents
Site Inventory List

Section B. General State Only Requirements

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.
- #023 Reporting
- #024 Report Format

Section C. Site Level State Only Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level State Only Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

- E-I: Restrictions



SECTION A. Table of Contents

- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)


- F-I: Restrictions
- F-II: Testing Requirements
- F-III: Monitoring Requirements
- F-IV: Recordkeeping Requirements
- F-V: Reporting Requirements
- F-VI: Work Practice Standards
- F-VII: Additional Requirements

Section G. Emission Restriction Summary

Section H. Miscellaneous









**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
110	JENBACHER ENGINE #1		
111	JENBACHER ENGINE #2		
112	JENBACHER ENGINE #3		
113	JENBACHER ENGINE #4		
114	JENBACHER ENGINE #5		
118	EMERGENCY ENGINE		
220	GAS TREATMENT		
TANK1	NEW LUBE OIL TANK - 2000 GAL		
TANK2	USED LUBE OIL TANK - 1000 GAL		
TANK3	UREA STORAGE TANK - 5236 GAL		
TANK4	COOLANT TANK - 1000 GAL		
C01	OXIDATION CATALYST ENGINE 1		
C02	SCR ENGINE 1		
C03	OXIDATION CATALYST ENGINE 2		
C04	SCR ENGINE 2		
C05	OXIDATION CATALYST ENGINE 3		
C06	SCR ENGINE 3		
C07	OXIDATION CATALYST ENGINE 4		
C08	SCR ENGINE 4		
C09	OXIDATION CATALYST ENGINE 5		
C10	SCR ENGINE 5		
FML1	NATURAL GAS		
FML2	DIESEL FUEL		
S110	STACK - ENGINE #1		
S111	STACK - ENGINE #2		
S112	STACK - ENGINE #3		
S113	STACK - ENGINE #4		
S114	STACK - ENGINE #5		
S118	STACK - EMERGENCY ENGINE		
S220	GAS TREATMENT STACK		
Z01	TANK FUGITIVES		

PERMIT MAPS



PERMIT MAPS



**SECTION B. General State Only Requirements****#001 [25 Pa. Code § 121.1]****Definitions.**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 127.446]**Operating Permit Duration.**

- (a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit.
- (b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit.

#003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)]**Permit Renewal.**

- (a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit.
- (b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.
- (c) The permittee shall submit with the renewal application a fee for the processing of the application as specified in 25 Pa. Code § 127.703(b). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.
- (d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413.
- (e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j).
- (f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application.

#004 [25 Pa. Code § 127.703]**Operating Permit Fees under Subchapter I.**

- (a) The permittee shall pay the annual operating permit maintenance fee according to the following fee schedule in either paragraph (1) or (2) in accordance with 25 Pa. Code § 127.703(d) on or before December 31 of each year for the next calendar year.
- (1) For a synthetic minor facility, a fee equal to:
- (i) Four thousand dollars (\$4,000) for calendar years 2021—2025.
 - (ii) Five thousand dollars (\$5,000) for calendar years 2026—2030.
 - (iii) Six thousand three hundred dollars (\$6,300) for the calendar years beginning with 2031.

**SECTION B. General State Only Requirements**

(2) For a facility that is not a synthetic minor, a fee equal to:

- (i) Two thousand dollars (\$2,000) for calendar years 2021—2025.
- (ii) Two thousand five hundred dollars (\$2,500) for calendar years 2026—2030.
- (iii) Three thousand one hundred dollars (\$3,100) for the calendar years beginning with 2031.

(b) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]**Transfer of Operating Permits.**

(a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.

(b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.

(c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008]**Inspection and Entry.**

(a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#007 [25 Pa. Code §§ 127.441 & 127.444]**Compliance Requirements.**

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:

**SECTION B. General State Only Requirements**

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

#008 [25 Pa. Code § 127.441]**Need to Halt or Reduce Activity Not a Defense.**

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#009 [25 Pa. Code §§ 127.442(a) & 127.461]**Duty to Provide Information.**

(a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.

(b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

#010 [25 Pa. Code § 127.461]**Revising an Operating Permit for Cause.**

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

- (1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.
- (2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.
- (3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.
- (4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

#011 [25 Pa. Code §§ 127.450, 127.462, 127.465 & 127.703]**Operating Permit Modifications**

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and significant operating permit modifications, under this permit, as outlined below:

**SECTION B. General State Only Requirements**

(b) Administrative Amendments. The permittee shall submit the application for administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.

(c) Minor Operating Permit Modifications. The permittee shall submit the application for minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.

(d) Significant Operating Permit Modifications. The permittee shall submit the application for significant operating permit modifications in accordance with 25 Pa. Code § 127.465.

(e) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

#012 [25 Pa. Code § 127.441]**Severability Clause.**

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

#013 [25 Pa. Code § 127.449]**De Minimis Emission Increases.**

(a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

(b) The Department may disapprove or condition de minimis emission increases at any time.

(c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NO_x from a single source during the term of the permit and 5 tons of NO_x at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM₁₀ from a single source during the term of the permit and 3.0 tons of PM₁₀ at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:

**SECTION B. General State Only Requirements**

(1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.

(2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.

(3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.

(4) Space heaters which heat by direct heat transfer.

(5) Laboratory equipment used exclusively for chemical or physical analysis.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:

(1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.

(2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.

(3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.

(f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.

(g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.

(h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#014 [25 Pa. Code § 127.3]**Operational Flexibility.**

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

(1) Section 127.14 (relating to exemptions)

(2) Section 127.447 (relating to alternative operating scenarios)

(3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)

(4) Section 127.449 (relating to de minimis emission increases)

(5) Section 127.450 (relating to administrative operating permit amendments)

**SECTION B. General State Only Requirements**

(6) Section 127.462 (relating to minor operating permit modifications)

(7) Subchapter H (relating to general plan approvals and general operating permits)

#015 [25 Pa. Code § 127.11]**Reactivation**

(a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a).

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

#016 [25 Pa. Code § 127.36]**Health Risk-based Emission Standards and Operating Practice Requirements.**

(a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)].

(b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act.

#017 [25 Pa. Code § 121.9]**Circumvention.**

No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#018 [25 Pa. Code §§ 127.402(d) & 127.442]**Reporting Requirements.**

(a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139.

(b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source.

(c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager
PA Department of Environmental Protection
(At the address given in the permit transmittal letter, or otherwise notified)

(d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and complete.

(e) Any records, reports or information submitted to the Department shall be available to the public except for such

**SECTION B. General State Only Requirements**

records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.

#019 [25 Pa. Code §§ 127.441(c) & 135.5]**Sampling, Testing and Monitoring Procedures.**

(a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.

(b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.

#020 [25 Pa. Code §§ 127.441(c) and 135.5]**Recordkeeping.**

(a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

#021 [25 Pa. Code § 127.441(a)]**Property Rights.**

This permit does not convey any property rights of any sort, or any exclusive privileges.

#022 [25 Pa. Code § 127.447]**Alternative Operating Scenarios.**

The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.

**SECTION B. General State Only Requirements****#023 [25 Pa. Code §135.3]****Reporting**

(a) If the facility is a Synthetic Minor Facility, the permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator of a Synthetic Minor Facility may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

#024 [25 Pa. Code §135.4]**Report Format**

If applicable, the emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

(a) No person may permit the emission into the outdoor atmosphere of fugitive air contaminant from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paving and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations.
- (7) Blasting in open pit mines. Emissions from drilling are not considered as emissions from blasting.
- (8) Not Applicable
- (9) Sources and classes of sources other than those identified in paragraphs (1)-(7), for which the operator has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
 - (i) the emissions are of minor significance with respect to causing air pollution; and
 - (ii) the emissions are not preventing or interfering with the attainment or maintenance of any ambient air quality standard.

002 [25 Pa. Code §123.2]**Fugitive particulate matter**

A person may not permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source if such emissions are visible at the point the emissions pass outside the person's property.

003 [25 Pa. Code §123.31]**Limitations****MALODOR EMISSIONS**

A person may not permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

004 [25 Pa. Code §123.41]**Limitations**

(a) A person may not permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.
- (2) Equal to or greater than 60% at any time

005 [25 Pa. Code §123.42]**Exceptions**

The limitations of § 123.41 (relating to limitations) shall not apply to a visible emission in any of the following instances:

- (1) When the presence of uncombined water is the only reason for failure of the emission to meet the limitations.

**SECTION C. Site Level Requirements**

(2) When the emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.

(3) When the emission results from sources specified in § 123.1 (a)(1)—(9) (relating to prohibition of certain fugitive emissions).

006 [25 Pa. Code §129.14]**Open burning operations**

(a) The permittee may not permit the open burning of material in a manner that:

(1) The emissions are visible, at any time, at the point such emissions pass outside the property of the person on whose land the open burning is being conducted.

(2) Malodorous air contaminants from the open burning are detectable outside the property of the person on whose land the open burning is being conducted.

(3) The emissions interfere with the reasonable enjoyment of life or property.

(4) The emissions cause damage to vegetation or property.

(5) The emissions are or may be deleterious to human or animal health.

(b) Exceptions. The requirements above do not apply where the open burning operations result from a fire set for either of the following reasons:

(1) to prevent or abate a fire hazard, when approved by the Department and set by o under the supervision of a public officer.

(2) to instruct personnel in fire fighting, when approved by the Department.

(3) for the prevention and control of disease or pests, when approved by the Department.

(4) in conjunction with the production of agricultural commodities in their unmanufactured state on the premises of the farm operation.

(5) for the burning of domestic refuse, when the fire is on the premise of a structure occupied solely as a dwelling by two families or less and when the refuse results from the normal occupancy of the structure.

(6) for recreational or ceremonial purposes.

(7) solely for cooking food.

(c) This permit does not constitute authorization to burn solid waste pursuant to Section 610(3) of the Solid Waste management Act, 35 P.S. Section 6018.610(3), or any other provision of the Solid Waste Management Act.

II. TESTING REQUIREMENTS.**# 007 [25 Pa. Code §139.1]****Sampling facilities.**

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such source. The Department will set forth, in the request, the time period in which the facilities shall be provided as well as the specifications for such facilities.

**SECTION C. Site Level Requirements****III. MONITORING REQUIREMENTS.****# 008 [25 Pa. Code §123.43]****Measuring techniques**

(a) Visible emissions may be measured using either of the following:

(1) A device approved by the Department and maintained to provide accurate opacity measurements.

(2) Observers, trained and qualified to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.

009 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall conduct a weekly inspection of the facility during daylight hours while the facility is operating to detect the presence of visible air contaminant emissions, visible fugitive air contaminant emissions and malodorous air contaminant emissions in excess of applicable emission limits.

(b) All visible air contaminant emissions, visible fugitive air contaminant emissions and malodorous air contaminant emissions observed to be in excess of an emission limit shall be reported to the manager of the facility at once.

IV. RECORDKEEPING REQUIREMENTS.**# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall keep records of the emission estimates and supporting calculations on a monthly basis used to verify compliance with the carbon monoxide (CO), nitrogen oxides (NO_x), particulate matter less than 10 microns in size (PM₁₀), sulfur oxides (SO_x), volatile organic compounds (VOCs), individual hazardous air pollutant (HAP), combined hazardous air pollutants (HAPs), and greenhouse gases (GHGs), measured on a CO₂e basis, emissions limitations in any 12 consecutive month period for all sources at the facility.

(b) These records shall be retained for a minimum of 5 years and shall be made available to the Department upon request.

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall keep records of the weekly inspections required pursuant to this operating permit. The records shall include the name of the company representative performing each inspection, the date and time of each inspection, a description of any visible air contaminant emission, fugitive air contaminant emission or malodorous air contamination observed to be in excess of an emission limit, the name of the facility manager to whom notice of any observed excessive emission was given, a description of any corrective action taken to eliminate/reduce any observed excessive emission and the date and time any such corrective action taken.

(b) All records generated pursuant to this operating permit shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

V. REPORTING REQUIREMENTS.**# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee, within one (1) hour of discovery of an occurrence, shall notify the Department, by phone at (570) 826-2511, of any malfunction, record keeping or reporting errors, or other possible non-compliance issues, which reasonably is believed to either result in or possibly result in, or which results in, the emission of air contaminants in excess of the limitations specified in, or established pursuant to, any applicable rule or regulations contained in Article III of the Rules and Regulations of the Department of Environmental Protection. A written report shall be submitted to the Department within five working days following the initial notification describing the incident and the corrective actions taken or to be taken. The Department may take enforcement action for any violations of the applicable standards.

013 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

Any notification as a result of any condition herein should be directed to:

**SECTION C. Site Level Requirements**

Mark J Wejkszner
 Air Quality Program Manager
 Department of Environmental Protection
 2 Public Square
 Wilkes-Barre, PA 18701-1915

VI. WORK PRACTICE REQUIREMENTS.**# 014 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

(a) The permittee shall take all reasonable actions to prevent particulate matter from becoming airborne. These actions shall include, but not be limited to, the following:

- (1) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.
- (2) Application of asphalt, oil, water or suitable chemicals on dirt roads, material stockpiles and other surfaces which may give rise to airborne dusts.
- (3) Paving and maintenance of roadways.
- (4) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

VII. ADDITIONAL REQUIREMENTS.**# 015 [25 Pa. Code §121.7]****Prohibition of air pollution.**

No person may permit air pollution as that term is defined in the act (The Air Pollution Control Act (35 P.S. Section 4001-4015)).

016 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

- (a) Within 180 days after the start-up of an air contamination source, the permittee shall develop a leak detection and repair (LDAR) program and perform LDAR monitoring on all high pressure (~1,000 psig) components.
- (b) The LDAR monitoring must be conducted on each pump, valve, relief valve, flange and connector, if applicable, in high pressure natural gas service using an optical gas imaging camera such as a FLIR camera or a gas leak detector capable of reading methane concentrations in air of 0% to 5% with an accuracy of +/- 0.2%.
- (c) The permittee may request, in writing, the use of other leak detection monitoring devices, to be approved, in writing, by the Department. Such LDAR monitoring equipment shall be operated in accordance with manufacturer-recommended procedures and, where applicable, Method 21 specified in 40 CFR Part 60, Appendix A. Each LDAR monitoring device shall be calibrated before use on each day of its use by following the manufacturer-recommended procedures or the procedure set forth at Method 21 specified in 40 CFR Part 60, Appendix A.
- (d) Leak means:
 - (i) Any emissions imaged by the optical gas instrument;
 - (ii) Indications of liquids dripping;
 - (iii) Indications by a sensor that a seal or barrier fluid system has failed;
 - (iv) Screening results using a gas leak detector exceed 2.5% methane and/or 500 ppm of VOCs.
- (e) A release from any equipment or component designed by the manufacturer to protect the equipment, controller(s), safety of personnel, to prevent ground water contamination, to prevent gas migration, or an emergency situation is not considered a leak.

**SECTION C. Site Level Requirements**

(f) The permittee shall monitor each pump, valve, relief valve, flange and connector, if applicable, in high pressure natural gas service at least annually.

(g) Leaks shall be repaired no later than 15 calendar days after a leak is detected, unless the facility shuts down or determines that ordering of replacement parts is necessary for repair of the leak(s).

(h) A leak is considered repaired if it is adjusted or otherwise altered and one of the following can be demonstrated after such adjustment or alteration:

- (i) No detectable emissions consistent with EPA Method 21 specified in 40 CFR Part 60, Appendix A;
- (ii) A concentration of 2.5% methane or less using a gas leak detector and a VOC concentration of 500 ppm or less;
- (iii) No visible leak image when using an optical gas imaging camera; if an optical gas imaging camera was originally used to detect the leak;
- (iv) No bubbling at leak interface using a soap solution bubble test specified in EPA Method 21; or a procedure based on the formation of bubbles in a soap solution that is sprayed on a potential leak source may be used for those sources that do not have continuously moving parts and that do not have a surface temperature greater than the boiling point or less than the freezing point of the soap solution; or
- (v) Any other method approved, in writing, by the Department.

(i) If a leak is not repaired within fifteen (15) days after it is detected, the leaking equipment or component must be listed on a Delay of Repair (DOR) List. The permittee must submit a written request to the appropriate regional office for an extension of the 15 day repair deadline. This includes extensions required due to facility shutdowns and/or the ordering of replacement parts. The written request shall also include the reason(s) for the extension request and the schedule for completion of the repairs. The Department may grant an extension of the LDAR deadline based upon the written request.

(j) The optical gas imaging camera or other Department-approved gas leak detection equipment shall be operated in accordance with manufacturer-recommended procedures.

(k) The permittee shall, at a minimum, on a monthly basis perform audible, visual, and olfactory (AVO) inspections to detect leaks from the equipment listed above.

017 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The company shall not impose conditions upon or otherwise restrict the Department's access to the aforementioned source(s) and/or any associated air cleaning device(s) and shall allow the Department to have access at any time to said source(s) and associated air cleaning device(s) with such measuring and recording equipment, including equipment recording visual observations, as the Department deems necessary and proper for performing its duties and for the effective enforcement of the Air Pollution Control Act.

018 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable requirements specified in 40 CFR Part 60 Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Reciprocating IC Engines and 40 CFR, Part 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. Copies of all requests, reports, applications, submittals, and other communications shall be sent to both EPA and the Department. The EPA copies shall be forwarded to:

Enforcement & Compliance Assurance Division
Air, RCRA and Toxics Branch (3ED21)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, PA 19103-2852

and

Mark J Wejkszner

**SECTION C. Site Level Requirements**

Air Quality Program Manager
Department of Environmental Protection
2 Public Square
Wilkes-Barre, Pa 18701-1915

VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

**SECTION D. Source Level Requirements**

Source ID: 110

Source Name: JENBACHER ENGINE #1

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: 111

Source Name: JENBACHER ENGINE #2

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 112

Source Name: JENBACHER ENGINE #3

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 113

Source Name: JENBACHER ENGINE #4

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: 114

Source Name: JENBACHER ENGINE #5

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.


No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 118

Source Name: EMERGENCY ENGINE

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).**

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Emission Standards and Operating Limitations requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6600 through 63.6604.

002 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Emission and Fuel Standards requirements specified in 40 CFR Part 60 Subpart IIII 60.4204 through 60.4207.

II. TESTING REQUIREMENTS.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Testing and Initial Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6610 through 63.6630.

004 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Testing requirements specified in 40 CFR Part 60 Subpart IIII 60.4212 through 60.4213.

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

005 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Notification, Reporting and Records requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6645 through 63.6660.

006 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall comply with all applicable Notification, Reporting, and Records requirements specified in 40 CFR Part 60 Subpart IIII 60.4214.

**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.**# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall comply with all applicable Continuous Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6635 through 63.6640.

008 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Other requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6665 through 63.6675.

009 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable General Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6605.

010 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The diesel fueled emergency engine is subject to 40 CFR Part 63 Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines and the permittee shall comply with all applicable requirements of the subpart.

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The diesel fueled emergency engine is subject to 40 CFR Part 60 Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines and the permittee shall comply with all applicable requirements of the subpart.

012 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Compliance requirements specified in 40 CFR Part 60 Subpart IIII 60.4210 through 60.4211.

013 [25 Pa. Code §127.441]**Operating permit terms and conditions.**


Source ID 118 is a diesel-fired 2013 Generac 100kW, 198 BHP emergency engine.

**SECTION D. Source Level Requirements**

Source ID: 220

Source Name: GAS TREATMENT

Source Capacity/Throughput:

**I. RESTRICTIONS.****Fuel Restriction(s).**

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall only use pipeline quality natural gas as fuel in the preheater.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).


**SECTION D. Source Level Requirements**

Source ID: TANK1

Source Name: NEW LUBE OIL TANK - 2000 GAL

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 2

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: TANK2

Source Name: USED LUBE OIL TANK - 1000 GAL

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 2

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: TANK3

Source Name: UREA STORAGE TANK - 5236 GAL

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 2

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.


No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: TANK4

Source Name: COOLANT TANK - 1000 GAL

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1

Group Description: Engines

Sources included in this group

ID	Name
110	JENBACHER ENGINE #1
111	JENBACHER ENGINE #2
112	JENBACHER ENGINE #3
113	JENBACHER ENGINE #4
114	JENBACHER ENGINE #5
C01	OXIDATION CATALYST ENGINE 1
C02	SCR ENGINE 1
C03	OXIDATION CATALYST ENGINE 2
C04	SCR ENGINE 2
C05	OXIDATION CATALYST ENGINE 3
C06	SCR ENGINE 3
C07	OXIDATION CATALYST ENGINE 4
C08	SCR ENGINE 4
C09	OXIDATION CATALYST ENGINE 5
C10	SCR ENGINE 5

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO₂, in the effluent gas exceeds 500 ppmvd.

002 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall not permit the emission into outdoor atmosphere of particulate matter in excess of 0.04 gr/dscf, pursuant to 25 Pa. Code § 123.13 (c)(1)(i).

003 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Emission Standards requirements specified in 40 CFR Part 60 Subpart JJJJ 60.4233 through 60.4234.

004 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Emission Standards and Operating Limitations requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6600 through 63.6604.

005 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The emission of visible air contaminants into the outdoor atmosphere shall not occur in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 10% for a period or periods aggregating more than three minutes in any 1 hour,
- (2) Equal to or greater than 30% at any time.

**SECTION E. Source Group Restrictions.****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) Particulate - 0.319 lbs/hr/engine, (1.595 pounds per hour, total)
- (b) Nitrogen Oxides (NOx) - 0.8 lbs/hr/engine (4.0 pounds per hour, total)
- (c) Sulfur Dioxide (SO₂) - 0.019lbs/hr/engine (0.095 pounds per hour, total)
- (d) Carbon Monoxide (CO) - 1.58lbs/hr/engine (7.9 pounds per hour, total)
- (e) Volatile Organic Compounds (VOC) - 1.01 lbs/hr/engine (5.05 pounds per hour, total)
- (f) Formaldehyde (HCHO) - 0.340 lbs/hr/engine (1.7 lbs/hr, total)
- (g) Total HAPs - 0.372 lbs/hr/engine (1.86 lbs/hr, total)

These emission limits do not apply during the startup and shutdown of the internal combustion engines. Each startup and shutdown period is limited to a maximum of 30 minutes each.

007 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall limit the emissions from all sources at the facility during any consecutive 12-month period to the following:

- (a) Particulate - 6.65 tons/year
- (b) Nitrogen Oxides (NO_x) as NO₂ - 16.85 tons/year
- (c) Sulfur Dioxide (SO_x) - 0.395 tons/year
- (d) Carbon Monoxide (CO) - 29.63 tons/year
- (e) Volatile Organic Compounds (VOC) - 20.24 tons/year
- (f) Formaldehyde (HCHO) - 7.08 tons/year
- (g) Hazardous Air Pollutants (Combined HAPS) - 7.79 tons/year
- (h) Green House Gases (CO₂e) - 98,122.2 tons/year

Fuel Restriction(s).**# 008 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall only use pipeline quality natural gas as fuel in each engine.

Operation Hours Restriction(s).**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Each engine shall not operate more than 8,322 hours/yr (based on a 12 month rolling sum), which include start-up and shut down hours.

II. TESTING REQUIREMENTS.**# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

In addition to the initial source testing requirement, every 2,500 hours of operation and no sooner than forty-five (45) days from the previous test, the owner or operator shall perform periodic monitoring for NO_x and CO emissions to verify continued compliance upon each of the respective engines which has a rated capacity greater than 500 brake horsepower and subject to the BAT. A Department-approved test that has been performed within 45 days prior to the scheduled periodic monitoring may be used in lieu of the periodic monitoring for that time period. A portable gas analyzer may be used to satisfy the requirements of this condition utilizing three test runs of twenty (20) minutes for each test run. The Department may alter the frequency of portable analyzer tests based on the test results. The frequency of portable gas analyzer tests may be altered with written Departmental approval. The portable gas analyzer shall be used and maintained according to the manufacturer's specifications and the procedures specified in ASTM D 6522 or equivalent as approved by the Department.

Within thirty (30) calendar days after the completion of periodic monitoring, the owner or operator shall submit the results to the appropriate DEP Regional Office. The Department reserves the right to require source tests in accordance with EPA

**SECTION E. Source Group Restrictions.**

reference methods should the data from the portable analyzer warrant such tests.

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Testing requirements specified in 40 CFR Part 60 Subpart JJJJ 60.4244.

012 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Testing and Initial Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6610 through 63.6630.

013 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall conduct a stack test for emissions utilizing methodology outlined in 25 Pa. Code Section 139 and the Department's Source Testing Manual or by other means approved by the Department. The source testing shall be performed while the source is operating at maximum capacity on the maximum substitution rate of natural gas, or as close to maximum as the engines will operate. At a minimum, the sources shall be tested for:

- (a) Nitrogen Oxides (NO_x) as NO₂.
- (b) Volatile Organic Compounds (VOC).
- (c) Carbon Monoxide (CO).
- (d) formahdehyde (HCHO)

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**# 014 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The company shall keep daily records of the amount of natural gas processed through the Gas Conditioning System.

015 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall record the following:

- (a) Monthly amount of fuel fired in the engines.
- (b) 12-month rolling total amount of fuel fired in the engines.
- (c) Monthly hours of operation.
- (d) Monthly emissions of particulate, NO_x, SO_x, CO, VOC and HAPs.
- (e) 12-month rolling total emissions of particulate, NO_x, SO_x, CO, VOC and HAPs.

016 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall calculate the emissions from the engines using the rates found in the application, or as approved by the Department. The emission rates may be reviewed after results of testing are approved by the Department. Emission rates from approved test results shall be used to calculate emissions once approved.

017 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall record each start-up, shutdown and malfunction of the engines. The records shall include the date, time, duration and type of event.

Note: "Malfunction" means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

**SECTION E. Source Group Restrictions.****V. REPORTING REQUIREMENTS.****# 018 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall comply with all applicable Notification, Reporting and Records requirements specified in 40 CFR Part 60 Subpart JJJJ 60.4245.

019 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Notification, Reporting and Records requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6645 through 63.6660.

VI. WORK PRACTICE REQUIREMENTS.**# 020 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall not, at any time, operate any engine without the simultaneous operation of the engine's respective oxidation catalyst and SCR system.

021 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The Gas Conditioning System shall be operated in accordance with manufacturing specifications.

VII. ADDITIONAL REQUIREMENTS.**# 022 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The facility shall be:

(a) operated in such a manner as not to cause air pollution, as defined in 25 Pa. Code § 121.1.

(b) operated and maintained in a manner consistent with good operating and maintenance practices; and

(c) operated and maintained in accordance with the manufacturer's specifications and the applicable terms and conditions of this Permit.

023 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

Each engine shall be equipped with non-resettable hour meters.

024 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Compliance requirements specified in 40 CFR Part 60 Subpart JJJJ 60.4243.

025 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Continuous Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6635 through 63.6640.

026 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Other requirements specified in 40 CFR Part 60 Subpart JJJJ 60.4235 through 60.4237.

027 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable Other requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6665 through 63.6675.

028 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall comply with all applicable General Compliance requirements specified in 40 CFR Part 63 Subpart ZZZZ 63.6605.

**SECTION E. Source Group Restrictions.****# 029 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The engines shall be designed to comply with the Compliance Requirements for Manufacturers specified in 40 CFR Part 60 Subpart JJJJ 60.4238 through 60.4242.

030 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The engines to be installed shall be Lean Burn with OxCat/SCR.

031 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The natural gas fueled engines are subject to 40 CFR, Part 60, Subpart JJJJ - Standards of Performance for Stationary Spark Ignited Internal Combustion Engines and the permittee shall comply with all applicable requirements of the subpart.

032 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The natural gas fueled engines are subject to 40 CFR, Part 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines and the permittee shall comply with all applicable requirements of the subpart.

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 2

Group Description: Storage Tanks

Sources included in this group

ID	Name
TANK1	NEW LUBE OIL TANK - 2000 GAL
TANK2	USED LUBE OIL TANK - 1000 GAL
TANK3	UREA STORAGE TANK - 5236 GAL

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Storage tanks shall be:

- (a) operated in such a manner as not to cause air pollution.
- (b) operated and maintained in a manner consistent with good operating and maintenance practices.
- (c) operated and maintained in accordance with the manufacturer's specifications.

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).



SECTION F. Alternative Operation Requirements.

No Alternative Operations exist for this State Only facility.



SECTION G. Emission Restriction Summary.

No emission restrictions listed in this section of the permit.

**SECTION H. Miscellaneous.**

The Natural Minor Operating Permit application was received on June 1, 2022. The annual operating permit maintenance fee shall be submitted to the Department in accordance with 25 Pa. Code, Chapter 127, Section 127.703. The annual maintenance fees are due no later than December 31, annually.

Request for Determination (RFD) 58-0140 was approved on August 23, 2018 for replacement engine.

The following is a list of sources that have been determined by the Department to be of minor significance under 25 Pa. Code, Chapter 127, Section 127.14(a)(8) and are not regulated in this State-Only Operating Permit. However, this determination does not exempt the sources from compliance with all applicable air quality regulations specified in 25 Pa. Code Chapters 121-143:

- 1.736 MMBtu/hr Cambridge M-series Make-up Air Heater



***** End of Report *****
