Attachment A: PERMITTED CONSTRUCTION/MODIFICATIONS PWSID No. 4490319

Encina Fort Union LLC Issued October 5, 2023

The following facilities and treatments systems are approved and shall be installed as described in your NCWS Application. The facilities and treatments systems shall be maintained and kept in working condition.

⊠ Well				
Well Name	NP-1	Maximum Instantaneous Pumping Rate	35 gpm	
Location			(Limited to 30 gpm by treatment facilities.)	
Sodium Hypochlorite Disinfer Sodium Hypochlorite Disi	ection			
Chemical Feed Location	Raw Water	Disinfection Segment	Baffling Factor	
		1,500-gallon tank	0.6	
☑ Iron and Manganese Treatment				
□ Preoxidation				
Chemical Type	Sodium Hypochlorite	Chemical Feed Location	Raw Water	
	and Filtration – Greensand Plu		040:	
Number of Units		Height	64.3 inches	
Maximum Rate of Filtration	9.5 gpm/ft ² (1 unit online) or 30 gpm per vessel.	Diameter	24 inches	
Routine Rate of Filtration	4.8 gpm/ft ² (2 units online) or 15 gpm per vessel.	Media Depth	30 inches	
Backwash Rate 12 gpm/ft² or 37.7 gpm per vessel.				
Location	Filter Building	Number of Pumps	2	
Pump No.	1	Pump No.	2 95 anm	
GPM TDH	85 gpm 180 feet	GPM TDH	85 gpm 180 feet	
Hydropneumatic Tank		IDH	160 leet	
Trydrophiedinatic Tank	1 - 44 ganons			
⊠ Contact Tank				
Volume	1,500 gallons	Number of Baffles	Inlet Diffused Baffled Plate	
Length	17.75 feet	Baffling Factor	0.6	
Diameter	4.0 feet			
⊠ Finished Water Storage Tan	k			
Name	FW Tank	Volume	, g	
Type of Storage Tank	Factory powder coated, bolted steel tank.	Diameter Roof to Sidewall Height	15 feet 15 feet	
Location	TBD	Max Water Height		
□ Distribution System				
Approximate Length	1,500 feet – Phase 1		HDPE	30%
	5,800 feet – Phase 2	Material(s)	SS 316/316L	70%