



ANNUAL DATA	Avg	Min	Max	RSQ	95%	Opt. Goal	Reg.
	NTU	NTU	NTU		NTU	% Values	% Values
Raw Turbidity	21.1		441.0	n/a	61.5	n/a	n/a
Max. Settled Turbidity	2.5	1.1	8.1	0.16	3.8	28.7	n/a
Combined Filtered Turbidity	0.09	0.03	0.44	0.10	0.17	69.7	98.9

RSQ = Correlation Coefficient for two selected data sets

95% = 95th Percentile value for data set

Opt. Goal = % of values in data set that are less than or equal to the selected optimization turbidity goal

Reg. = % of values in data set that are less than or equal to the regulated turbidity requirement

