# Commonwealth of Pennsylvania Department of Environmental Protection (DEP) Bureau of Point and Non-Point Source Management Harrisburg, PA

**Issued to:** Nicholas Noble, Government Relations Manager

Orenco Systems, Inc. 814 Airway Avenue Sutherlin, Oregon 97479 Phone: 800-348-9843 www.orenco.com

**Technology:** Orenco AdvanTex<sup>®</sup> Treatment System (AdvanTex)

Classification Date: August 25, 2009

October 6, 2009 January 18, 2012 December 4, 2012

**Classification Type:** Alternate technology (Listing #A2009-0001-0004)

In accordance with Title 25, Chapter 73, Section 73.72, DEP classifies the Orenco AdvanTex® (AdvanTex) treatment system for use as an alternate onlot sewage treatment system. This classification permits the use of the AdvanTex as a treatment system used for the specific purposes of reducing CBOD<sub>5</sub>, TSS, and total nitrogen in the sewage effluent prior to discharge to an absorption area. This system has demonstrated that it can produce an effluent which shall not exceed 10 mg/L CBOD<sub>5</sub> and 10 mg/L TSS as monthly averages. With ultraviolet disinfection, the AdvanTex can also reduce fecal coliform concentrations to treatment levels which shall not exceed 200 cfu/100 ml on a monthly average basis. When the system is used to reduce total nitrogen, the discharge limitations for total nitrogen shall not exceed 20 mg/l as a monthly average. The system is approved for use on limiting zones of less than 20 inches. The AdvanTex also satisfies NSF Std-40 criteria and may be used as a conventional aerobic treatment tank described in Section 73.32 where nitrogen removal is not a concern.

#### I. Technology Description

The AdvanTex treatment system configuration consists of either a single dual-compartment processing tank or a combination of separate septic and recirculating tanks with each configuration recirculating wastewater through an AdvanTex packed bed filters, and a final discharge of the effluent to an onlot absorption area or spray field.

#### II. Design Requirements

- a. <u>Location</u>: The AdvanTex may be installed for the treatment of domestic strength wastewater serving a new construction or a repair.
- b. <u>Size:</u> The Orenco AdvanTex Treatment system with model numbers: AX20N, AX20RTN, AX25RTN, and AX100 may be utilized for CBOD/TSS/TN removal.
  - (1) The AX20N and the AX20RTN are rated for 500 gpd/pod.

- (2) The AX25RTN is rated for 625 gpd/pod.
- (3) The AX100 is rated for 2,500 gpd/pod.

# c. Construction:

- (1) The AdvanTex must be installed:
  - i. Per the manufacture's installation instructions.
  - ii. By an Orenco trained and authorized installer.
- (2) Tank installations must consist of either a two-compartment tank, two tanks in series, or otherwise conform to meet the requirements of Section 73.31. Hydraulic retention times must be the greater of 3 days or the tank volumes required by Section 73.31. Vertically aligned circular tanks are not permitted.
- (3) The number of AdvanTex filters to be installed must be in accordance with the manufacturer's design specifications.
- (4) The AdvanTex treatment system must be constructed so that a sample can be collected from the recirculating splitter valve. If uv disinfection is utilized, then the sample must be taken from the spigot in the discharge basin.
- (5) The AdvanTex must be configured and operated using the Combination Mode.
- (6) The AdvanTex filters must maintain between a minimum recirculation ratio of 4:1 and a maximum recirculation ratio of 7:1 based upon actual daily flow. The preferable recirculation ratio is 4:1.
- (7) All valves connected to the manifold inside the AdvanTex filter must be in the closed position during operation.
- (8) All AdvanTex filter pods shall include insulation.
- (9) Sites that utilize water softeners must plumb the water softener backwash into the treatment tank. The manufacturer recommends that only salt-free water softeners be used with the AdvanTex Treatment System.
- (10) Additional requirements for the AX-RTN Only (Model Numbers AX20RTN and AX25RTN):
  - i. May be installed for single-family homes only;
  - ii. The Orenco Biotube Effluent Filter (Model Numbers FTS0444-36V, FTW0444-36V, and FT0822-14B filters) must be installed at the outlet of the final septic tank.
  - iii. If the AXRTN is being installed parallel to septic tank, the AXRTN needs to be offset from the septic tank by 4 feet (1.2 m) for units without antibuoyancy measures and 6 feet (1.8 m) for units with antibuoyancy measures.
- (11) The area surrounding the tanks shall be constructed to divert surface water.
- (12) All AX-100 designs must include a letter from the manufacturer or the manufacturer's authorized representative certifying the contents of the design package.

## d. Use of the Component/System and Siting Requirements:

(1) For final treatment and disposal for an onlot system described in Chapter 73 other than IRSIS, up to a 40 percent reduction in the size of the absorption area is allowed where the percolation rate is in the range of 3 to 60 minutes per inch (min/in), inclusive. However, where the percolation rate is in the range of 61 to 180 min/in, inclusive, no reduction in absorption area sizing is permitted.

- (2) On sites exhibiting limiting zones greater than or equal to 20 inches from the mineral soil surface, the absorption area may be designed in accordance with the alternate atgrade absorption area. Where the percolation rate is in the range of 3 to 60 minutes per inch, inclusive, up to a 40% reduction in the size of the absorption area is allowed. However, where the percolation rate is in the range of 61 to 180 min/in, inclusive, no reduction in absorption area sizing is permitted.
- (3) On sites exhibiting limiting zones less than 20 inches from the mineral soil surface, the absorption area may be designed in accordance with the specifications described by the alternate shallow limiting zone at-grade absorption area. Ultraviolet (uv) disinfection is optional.
- (4) The absorption area may also be designed in accordance with the specifications described by the alternate drip irrigation.

#### (5) General:

- i. Where absorption area sizing reductions are proposed, they are not cumulative. No additional sizing reduction is allowed for use of either an aerobic tank or infiltration chambers.
- ii. If absorption area sizing reductions are proposed, where the system is used to serve a new dwelling, the soil profile evaluations and percolation testing must document that sufficient area is available for installation of a full-sized absorption area (prior to the calculation of the 40 percent reduction).
- iii. The absorption area must be designed to take full advantage of the slope to move effluent out from under the absorption area and downgradient with the laterals placed parallel to the contour.

## III. Minimum Maintenance Standards

a. <u>Service Contract:</u> A service contract with a Service Provider qualified to maintain the AdvanTex Treatment System is required. The service contract will require a minimum of two site visits annually. When the AdvanTex is used for the specific purposes of reducing total nitrogen, the telemetry monitoring system is required unless the subject site does not have telemetry capabilities.

## b. Inspection:

- (1) Inspection of the area around the outside of the media filter and soil absorption area every 6 months by the homeowner and annually by the Service Provider to ensure that there is no ponding of effluent or downgradient seepage.
- (2) Septic tanks, dosing tanks, and lift pump tanks shall be inspected every 6 months for structural integrity of the tank, inlet and outlet baffles, solids retainer, pumps, siphons, and electrical connections. Aerobic tanks shall be inspected every 6 months for structural integrity of the tank, inlets, and outlet baffles, buoyed solids retainer, pumps, siphons, and electrical connections. The inspection and concurrent pumping of excess solids shall be conducted in accordance with the manufacturer's requirements.

# c. <u>Sampling:</u>

- (1) When the AdvanTex is installed for the purposes of reducing total nitrogen (TN), a sample should be collected from the treated effluent at least once annually by the maintenance provider and analyzed for TN. The location of sampling should be in accordance with the operation and maintenance manual. The sampling shall not commence until at least 30 seconds of continuous discharge through the sampling tap has occurred. Analysis should be completed by a certified laboratory. A test result for TN that is 45 mg/l or greater may indicate system non-compliance and possible performance issues. Such results justify further investigation to determine a cause for the observed condition and to determine possible repair activity. Continued non-compliance is considered a nuisance violation under Section 14 of the Act and may be subject to compliance action by the local agency.
- (2) The Service Provider may require additional sampling if in the Service Provider's judgment the AdvanTex is not performing to the following effluent quality where required: 10 mg/L CBOD<sub>5</sub>, 10 mg/L TSS, and/or 20 mg/L total nitrogen.
- (3) When the AdvanTex is used for sites that remove total nitrogen, test results must be sent to the local agency and DEP Central Office (Division of Planning and Permits). Other information should include the property owner, the property owner's address, the location of the site, the AdvanTex filter model number, the date of the sample collection, and the effluent data. Submittal of the information shall be on an annual basis each January.
- (4) The homeowner must retain annual records of monitoring information on a rolling 5-year period.

## IV. Permitting Requirements

- a. A sewage enforcement officer who has successfully completed an appropriate Department sponsored training course that included this specific technology or has received review delegation in writing from the Department may independently review the design and issue the permit for components under this listing. All other proposals under this listing must be submitted to the Department for review and comment.
- b. When permitting onlot systems in areas of elevated nitrate-nitrogen groundwater concentrations, the permitting authority must verify whether a DEP sewage facilities planning approval letter condition exists which requires the lot(s) to be permitted with the AdvanTex treatment system.
- c. Issuing onlot sewage system permits that are inconsistent with planning approval conditioned upon use of the AdvanTex treatment system is considered a violation of Act 537
- d. Section III is required to maintain operation of the AdvanTex treatment system.

- e. When the AdvanTex is used for the specific purpose of reducing total nitrogen (TN), the following conditions apply:
  - (1) The sewage enforcement officer may only issue permits for residential establishments;
  - (2) Design plans involving commercial or institutional establishments shall be submitted to the DEP Regional Office with the applicable jurisdiction.

#### V. Planning Requirements

- a. The AdvanTex treatment system satisfies the nitrate-nitrogen reduction requirement conditions specified in certain DEP sewage facilities planning module approval letters.
- b. A preliminary hydrogeologic evaluation is required under conditions set forth in 71.62(c)(2). Results from the preliminary hydrogeologic which identify a potential for a conflict between the proposal and existing or potential future uses of groundwater in the area will require a detailed hydrogeologic study. The accepted nitrogen loading figure that may be used for assessing groundwater impacts from the AdvanTex treatment system may be lowered to 20 mg/l total nitrogen in the preliminary hydrogeologic evaluation when a commitment to use the AdvanTex is included with the planning proposal. Note that the DEP Bureau of Laboratories defines total nitrogen as TN = NO<sub>2</sub>-N + NO<sub>3</sub>-N + TKN-N. Preliminary hydrogeologic evaluations may assume that all nitrogen entering the system will be converted to nitrate-nitrogen as stated in *Impact of the Use of Subsurface Disposal Systems on Groundwater Nitrate Nitrogen Levels* (Document ID 362-2207-004). Thus, the 20 mg/l total nitrogen shall be considered equivalent to 20 mg/l nitrate-nitrogen.
- c. DEP may require the permitting and use of the proposed AdvanTex technology as a condition for approval of that project.