

Stage II Dispenser Replacement Information

This document is intended to provide instruction and assistance relating to the *Suspension of Enforcement of the Stage II Vapor Recovery Requirements for Control of Emissions of Volatile Organic Compounds from New and Modified Gasoline Dispensing Equipment in the Philadelphia and Pittsburgh-Beaver Valley Areas* published on November 12, 2016 in the Pennsylvania Bulletin. This supplements that notice; it does not change it.

The suspension of enforcement applies when an owner or operator of a gasoline dispensing facility replaces old gasoline dispensers or adds new gasoline dispensers for an existing tank system after November 12, 2016.

Please ensure that copies of all records of the work done are kept on site with Stage II records, including completed checklists and results of the required pressure decay testing (and tank tie testing, as appropriate) to document the work that was done.

Please submit notice to the appropriate DEP regional office, Philadelphia Air Management Services, or Allegheny County Health Department prior to beginning work on the system. Please submit the notice at least 30 days prior to the activity to the appropriate address listed below. Please note that 30 days prior notice is required for tank handlers for this type of work.

Note: the notice can be e-mailed for those contacts with e-mails listed below. In Philadelphia County, in addition to providing written notice, owners and operators should contact the Philadelphia Air Management Services at (215) 685-7572 or DPHAMS_Service_Requests@phila.gov to discuss additional requirements that may apply to equipment changes addressed in this notice.

<p>Southeast Regional Office (Bucks, Chester, Delaware, Montgomery Counties)</p> <p>James Rebarchak, Air Quality Program Manager Department of Environmental Protection Southeast Regional Office 2 East Main Street Norristown, PA 19401</p> <p>Email (preferred): RA-EPSEROAQREPORTS@pa.gov</p>	<p>Southwest Regional Office (Armstrong, Beaver, Butler, Fayette, Washington, Westmoreland Counties)</p> <p>Mark Gorog, Air Quality Program Manager Department of Environmental Protection Southwest Regional Office 400 Waterfront Drive Pittsburgh, PA 15222</p>
<p>Philadelphia Air Management Services (City of Philadelphia)</p> <p>Source Registration Philadelphia Air Management Services 321 University Avenue Philadelphia, PA 19104</p> <p>Email: DPHAMS_Service_Requests@phila.gov</p>	<p>Allegheny County Health Dept. (Allegheny County)</p> <p>Allegheny County Health Dept. Air Quality Program 301 39th, Building #7 Pittsburgh, PA 15201</p> <p>Email (preferred): AQReports@alleghenycounty.us</p>

Please also be aware that dispenser removal and decommissioning vapor return piping are tank handling activities that require a DEP certified installer, and also requires, “2630-FM-BECB0575 Underground Storage Tank Modification Reports” to be submitted to the Storage Tanks Program at the appropriate regional office and at the central office of the DEP, within 30 days of the completion of the work.

Suggested Dispenser Replacement Notice Format

Site Information	
Site Name:	Tanks Facility ID:
County:	Municipality:
Location Street Address:	City:
Zip:	Phone:
Project Information	
Planned Dispenser Replacement Date:	Current Number of Dispensers at Site:
ID(s) of New Dispensers Being Installed:	
Detailed Description of Project:	
Owner Information	
Owner Name:	Phone:
Owner Mailing Address:	City:
State:	Zip:
Contractor Information	
Contractor Company Name:	Tanks Certification ID No.:
Certified Individual Name:	Tanks Individual Certification ID No.:
Contractor Phone:	