

September 19, 2024

CERTIFIED MAIL NO.

Re: Water Supply Request for Investigation ID: 360839

58 Pa. C.S. § 3218 Determination Lenox Township, Susquehanna County

Dear

The Department of Environmental Protection ("Department") has been investigating the possible degradation of your water supply located at the above-referenced address ("Water Supply") from oil and gas activities. The Department has determined that your Water Supply was adversely affected by oil and gas activities, including but not limited to the drilling, alteration, or operation of an oil or gas well. The information upon which this determination is based is summarized below.

Please note that without any treatment, water quality sampling indicates that on occasion your water quality does not meet (i.e., is worse than) the following health and/or aesthetic statewide standards. Note that Primary Maximum Contaminant Levels ("MCLs") are intended to reflect potential dangers to human health, while Secondary Maximum Contaminant Levels ("SMCLs") reflect the aesthetics of the water (i.e., taste, smell, etc.). None of the parameters in the Water Supply were above a MCL; however, certain samples were above some SMCLs, as set forth in the table below.

Parameters	Unit	Statewide Standards or Recommended Levels	Your <u>Highest</u> Sample Results that Were Detected Above Statewide Standards/Levels
Aluminum	mg/L	0.2	1.3
Iron	mg/L	0.3	6.0
Manganese	mg/L	0.05	0.097
Methane	mg/L	7 (DEP Action Level)	44

Summary of Investigation

On November 30, 2021, the Department was notified that methane was detected in your Water Supply during sampling being conducted as part of a nearby gas migration investigation. Subsequently, water quality samples were collected from the Water Supply on several occasions by the Department and private consultants. The samples were submitted to the Department's laboratory in Harrisburg or to an accredited third-party laboratory for analysis. The analytical reports for the samples collected by the Department were previously provided to you, but are summarized for your convenience in the enclosed table along with sample results provided by Coterra Energy, Inc.

Samples of the methane from the Water Supply were collected and sent to a specialized laboratory for isotopic and compositional analysis. These analyses allowed for a more detailed characterization of the gas present in the Water Supply. The isotope and compositional analyses indicate that the stray gas in your Water Supply appears to be associated with oil and gas activities.

Methane is the predominant component of natural gas. Federal water standard limitations have not been established for methane gas. The level of concern begins above 28 mg/L methane, which is referred to as the saturation level. At this level, under normal atmospheric pressure, the water cannot hold additional methane in solution. This may allow the gas to come out of the water and concentrate in the air space of your home or building. There is a physical danger of fire or explosion due to the migration of natural gas into water wells or through soils into dwellings where it could be ignited by sources that are present in most homes/buildings. Natural gas can also cause a threat of asphyxiation, although this is extremely rare.

When the Department is made aware of methane levels greater than 7 mg/L, it notifies the water supply owner of the hazards associated with methane in their water supply. Please be aware, however, that the methane levels can fluctuate. This means that even with a relatively low level of methane, you should be vigilant of changes in your water that could indicate an increase in methane concentration.

It is the Department's recommendation that all water wells should be equipped with a working vent. This will help alleviate the possibility of concentrating these gases in areas where ignition would pose a threat to life or property. Please note that it is not possible to completely eliminate the hazards of having natural gas in your Water Supply by simply venting your well.

The Department is continuing to work to permanently resolve this issue. Should you have any questions regarding the investigation, please contact Eric Rooney, P.G. at 570.346.5543.

Sincerely,

ennifer W. Means

Environmental Program Manager Eastern Oil and Gas District

Jemily aMeans

Enclosures:

Laboratory Analytical Results Table

c: Michael O'Donnell Eric Rooney, P.G. Briana Cunningham Complaint File # 360839

6 26 44 98 17 12 10 9.1 .*7 5 0.210 0.480 0.009 0.007 0.067 0.045 0.034 No Standard 42 <0.0210 0.0480 0.070 0.067 0.045 0.034 No Standard 9 64 <0.050 <0.0050 <0.0050 <0.0050 <0.0050 No Standard 10 64 <0.050 <0.0050 <0.0050 <0.0050 <0.0050 No Standard 10 0.18 <0.047 <0.020 <0.0020 <0.0050 <0.0050 <0.0050 20 <0.0020 <0.0020 <0.0020 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 </th <th>11/29/2021 12/1/2021 Coterra Coterra</th> <th>7a DEP</th> <th>12/2/2021 Coterra</th> <th>8/9/2022 Coterra</th> <th>4/18/2023 Coterra</th> <th>6/14/2023 Coterra</th> <th>8/31/2023 Coterra</th> <th>12/5/2023 Coterra</th> <th>3/12/2024 Coterra</th> <th></th>	11/29/2021 12/1/2021 Coterra Coterra	7a DEP	12/2/2021 Coterra	8/9/2022 Coterra	4/18/2023 Coterra	6/14/2023 Coterra	8/31/2023 Coterra	12/5/2023 Coterra	3/12/2024 Coterra	
0.210 0.480 0.069 0.070 0.065 0.034 c0.0550 c0.0690 0.070 c0.065 c0.0050 c0.0050 c0.0050 c0.0050 c0.0050 c0.0050 c0.0050 c0.0050 c0.18 ~ f.7 74 74 74 c0.020 ~ c0.0020 c0.0020 c0.0020 c0.0020 c0.047 ~ c0.0020 c0.0020 c0.0020 c0.0020 c0.047 ~ c0.0020 c0.0020 c0.0020 c0.0020 c0.047 ~ c0.047 0.048 0.048 0.046 c0.047 ~ c0.048 0.048 0.046 c0.050 c0.047 ~ c0.048 0.048 0.046 c0.050 c0.050 ~ c0.050 ~ c0.050 c0.050 c0.050 c0.050 ~ c0.050 ~ c0.050 c0.050 c0.050 c0.050 c0.042 ~ ~	30	27.0	36		0 0	1	4	4		MCL/Standa
64 ~ 67 ~ 71 74 76 <td>0.230</td> <td>0.245</td> <td>0.210</td> <td>0.480</td> <td>0.069</td> <td>0.070</td> <td>0.067</td> <td>0.045</td> <td>0.034</td> <td>No Standard</td>	0.230	0.245	0.210	0.480	0.069	0.070	0.067	0.045	0.034	No Standard
64 ~ 67 ~ 71 74 74 74 0.18 ~ 1.3 ~ 6.030 c.0.030 c.0.030 c.0.030 c.0.0020 ~ c.0.0020 ~ c.0.047 c.0.048 c.0.030 c.0.047 ~ c.0.062 ~ c.0.047 c.0.062 c.0.050 c.2.5 ~ c.0.75 ~ c.0.75 c.0.75 c.0.75 c.2.5 ~ c.0.75 c.0.75 c.0.75 c.0.75 c.0.75 c.2.6 ~ c.0.75 c.0.75 c.0.75 c.0.75 c.0.75 c.2.6 ~ c.0.75 c.0.75 c.0.75 c.0.75 c.0.75 c.0.50 ~ c.0.50 ~ c.0.50 c.0.50 c.0.50 c.0.50 c.0.050 ~ c.0.50 ~ c.0.50 c.0.50 c.0.50 c.0.50 c.0.02 ~ c.0.02 c.0.020 c.0.020 c.0.020 c.0.020	<0.0050 <	<0.0142	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050	No Standard
0.18 - 4.3 - 6.030 c.0.030 c.0.030 c.0.030 c.0.030 c.0.0020 c.0.0020 c.0.0020 c.0.0020 c.0.0020 c.0.047 c.0.047 c.0.048 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.047 c.0.046 c.0.046 c.0.047 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.046 c.0.050	63	68.0	64	~	67	2	71	74	74	No Standard
<0,0020 <0,0020 < <0,0020 < </td <td>0.19 0.0</td> <td>0.092900</td> <td>0.18</td> <td>~</td> <td>1.3</td> <td>2</td> <td><0.030</td> <td><0.030</td> <td><0.030</td> <td>0.2</td>	0.19 0.0	0.092900	0.18	~	1.3	2	<0.030	<0.030	<0.030	0.2
0.047 ~ 0.062 ~ 0.047 0.048 0.046 <2.5	<0.0020 <0.	<0.00300	<0.0020	~	<0.0020		<0.0020	<0.0020	<0.0020	*0.010
42.5 ~ 0.75 ~ 0.05 ~ 0.050 <	0.049 0.0	0.043	0.047	2	0.062	~	.0.047	0.048	0.046	*2
31 2 37 36 36 36 36 36 36 36 36 36 36 36 36 36 36 36 36 36 36 36 40 410 110 110 110 110 110 110 110 110 110 110 110 110 111 4.3 4.2 20.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.050 <0.0	<0.50 <0	<0.2	<2.5	>	<0.75	2	<0.75	<0.75	<0.75	No Standard
110 ~ 120 ~ 110 111	30 30.000	00	31	2	35	2	37	36	36	No Standard
0.58 - 6.0 - 1.1 1.8 1.5 <0.050	110 89		110	2	120	2	110	110	110	No Standard
<0.050 <0.050	2.7 0.705		0.58	,	6.0	3	1.1	1.8	1.5	0.3
3.6 ~ 4.0 ~ 4.1 4.3 4.2 0.022 ~ 0.042 ~ 0.020 0.042 0.097 7.2 ~ 0.020 0.042 ~ 7.6 1.1 ~ 1.3 ~ 7.6 4.0010 ~ 1.0 1.1 1 5.0010 ~ 6.0010 <0.0010	<0.050 <0.0250	0	<0.050	~	<0.050	2	<0.050	<0.050	<0.050	No Standard
0.022 ~ 0.042 ~ 0.020 0.042 0.097 7.2 ~ 0.042 ~ 7.6 7.6 1.1 ~ 1.3 ~ 1.0 1.1 1 <0.0010	3.6 3.43		3.6	2	4.0	2	4.1	4.3	4.2	No Standard
7.2 ~ ~ ~ ~ 7.6 1.1 ~ 1.3 ~ 1.0 1.1 1 <0.0010	0.056 0.020		0.022	2	0.042	1	0.020	0.042	0.097	0.05
1.1 ~ 1.3 ~ 1.0 1.1 1 <0.0010	7.1 7.3		7.2	~	2	2	~	2	9.7	6.5-8.5
<0.0010 ~ <0.0010 ~ <0.0010 ~ <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010 <0.0010	1.0 <1.00		1.1	2	1.3	2	1.0	1.1	1	No Standard
14 ~ 17 ~ 14 14 13 260 ~<	<0.0010 <0.00400	8	<0.0010	~	<0.0010	,	<0.0010	<0.0010	<0.0010	*0.05
260 ~	14 13.54		14		17	2	14	14	13	No Standard
0.24 ~ 0.24 ~ 0.24 0.25 0.24 0.24 170 ~ 49 ~ 42 39 35 140 ~ 39 ~ 150 140 140 46 ~ 11 ~ 9.8 8.7 8.3 14 4.7 ~ 39 ~ <3.0	250 271.00	00	260	2	2	2	~	~	~	No Standard
170 ~ 49 ~ 42 39 35 140 ~ 39 ~ 150 120 140 46 ~ 11 ~ 9.8 8.7 8.3 4.7 ~ 39 ~ <3.0	0.24 0.225	2	0.24	2	0.24	2	0.24	0.25	0.24	No Standard
140 ~ 39 ~ 150 140 46 ~ 11 ~ 9.8 8.7 8.3 4.7 ~ 39 ~ <3.0	33 35.55	55	170	1	49	1	42	39	35	250
46 ~ 11 ~ 9.8 8.7 8.3 4.7 ~ 39 ~ <3.0	130 160	0	140	2	39	2	150	120	140	200
4.7 ~ 39 ~ <3.0	9.3 9.45	ις.	46	2	11	2	9.8	8.7	8.3	250
5.3 ~ 70 ~ 9.7 18 18	9.5 <20	0.	4.7	~	39	5	<3.0	<3.0	11	No Standard
	9.6	7	5.3	2	. 70	2	9.7	18	18	No Standard

Highlighting indicates an exceeded standard or level~ = Not analyzed * Denotes Primary MCL < Indicates analyte was not detected above its detection limit.

** 7 mg/L represents the Department's official action level for dissolved methane in groundwater.