

April 22, 2016

Cambria Township Supervisors
P.O. Box 248
Revloc, PA 15948

Re: Sunoco Pennsylvania Pipeline Project – Ebensburg Station
Preliminary/Final Land Development Plan
Cambria Township, Cambria County, PA

Dear Township Supervisors:

I have reviewed the above-referenced Preliminary/Final Land Development Plan and offer the following comments:

Summary of information provided for review:

1. Letter from Tetra Tech – Bill Smith dated February 11, 2016 transmitting the Site Development Drawings.
2. Letter from Tetra Tech – Rachel Silva dated February 8, 2016 requesting floodplain / stormwater management consistency
3. Site Development Plans dated January 2016.

Completeness Review:

1. EADS sent a fax transmittal identifying contact information for the Township Engineer and requesting an email address for Bill Smith of Tetra Tech. No response was received to date.
2. The following items were not received for review: 1) Post Construction Stormwater Management Report, 2) Road Occupancy Permit Application and fee, 3) E&S Control Plan Report.
3. Tetra Tech states in their letter of February 11, 2016 that the Site Development Plan is being submitted as a courtesy for Township review but not for any formal approval. The requirement for formal review should be confirmed by the Solicitor prior to consenting to not proceeding with a formal review. I would still have concern that the driveways are designed properly and the stormwater management be in compliance with the Township ordinances.
4. Tetra Tech states in their letter of February 8, 2016 that they are requesting a letter of consistency related to Floodplains and Stormwater Management. Tetra Tech was informed that additional information would be needed in order for the Township to provide a letter. Rachel Silva responded that additional information will be provided.

Subdivision and Land Development Ordinance Comments:


1. A Driveway Permit shall be obtained from Cambria Township where site access is onto a Township Road. (Section 212.1.g.(14)). The proposed access drives shall not discharge site runoff onto public roads. Permit should be secured if required.
2. The NPDES permit shall be submitted to the Township (Section 212.2.d). A copy of the NPDES permit shall be submitted to the Township prior to final plan approval. Permit should be secured if required.

Stormwater Management Comments:

1. The Drainage Plan shall include a Narrative Report with all calculations, assumptions, and criteria used in the design of the control measures and structures (Section 402.A.6). A Post Construction Stormwater Management Report was not submitted for review. An E&S Control Plan Report was not submitted for review.

If you have any questions or comments, please contact Dan Beyer at (814) 944-5035 or dbeyer@eadsgroup.com.

Sincerely,
The EADS Group, Inc.



By: Keith C. Vasas, P.E.

KCV

Copy: Tetra Tech, c/o Bill Smith, 661 Anderson Drive, Pittsburgh, PA 15220-2700

Tetra Tech, c/o Rachel Silva, 285 Ellicott Street, Buffalo, New York, 14203

R:\1603 Cambria Twp\16033 Retainer 2016\05 Design\20 MS\1.4 Sunoco FP - SWM Consistency Request\Sunoco Pipeline Review Letter 2016-04-22.docx