



**DESIGN AND CONSTRUCTION:**

- CONTRACTOR SHALL FIELD VERIFY DEPTH OF ALL EXISTING UTILITIES SHOWN OR NOT SHOWN ON THIS DRAWING.
- THE MINIMUM SEPARATION DISTANCE FROM EXISTING SUBSURFACE UTILITIES SHALL NOT BE LESS THAN 10 FEET AS MEASURED FROM THE OUTSIDE EDGE OF THE UTILITY TO OUTSIDE OF PROPOSED PIPELINE.
- DESIGNED IN ACCORDANCE WITH CFR 49 195 & ASME B31.4
- GROSSING PIPE SPECIFICATION:  
 HDD HORZ. LENGTH (L)=3146'  
 HDD PIPE LENGTH (S)=3156'  
 20" x 0.456" W.T., X-65, API5L, PSL2, ERW, BFW  
 COATING: 14-16 MILS FBE WITH 30-35 MIL ARO (POWERCRETE R95)
- INTERNAL DESIGN PRESSURE 1480 PSIG (SEAM FACTOR 1.0, DESIGN FACTOR 0.50).
- INSTALLATION METHOD: HORIZONTAL DIRECTIONAL DRILL (HDD).
- PIPELINE WARNING MARKERS SHALL BE INSTALLED ON BOTH SIDES OF ALL ROAD, RAILWAY, AND STREAM CROSSINGS.
- CARRIER PIPE NOT ENCASED.
- PIPE / AMBIENT TEMPERATURE MUST BE NO LESS THAN 30°F DURING PULLBACK WITHOUT PRIOR WRITTEN APPROVAL FROM THE ENGINEER.
- CONDUCT 4-HOUR PRE-INSTALLATION HYDROTEST OF HDD PIPE STRING TO MINIMUM 1850 PSIG.
- SEE SUNOCO PENNSYLVANIA PIPELINE PROJECT ESRI WEBMAP FOR ACCESS ROAD ALIGNMENT.
- SUNOCO PIPELINE, L.P.'S HORIZONTAL DIRECTIONAL DRILL INADVERTENT RETURN CONTINGENCY PLAN WILL BE IMPLEMENTED AT ALL TIMES.
- SUNOCO PIPELINE, L.P.'S EROSION AND SEDIMENTATION CONTROL PLAN WILL BE IMPLEMENTED AT ALL TIMES.

**NOTES:** REFER TO TEST BORING LOG S3-0580 FOR COMPLETE SOIL MATERIAL DESCRIPTION

**GEOTECH SB-01**  
 -NG EL. 429'  
 -TOPSOIL (0' - 0.7')  
 -SC (0.7' - 6.5')  
 -GROUNDWATER (8.0')  
 -SM (6.5' - 13.5')  
 -WEATHERED GNEISS (13.5' - 14.0')  
 -COMPLETION DEPTH EL. 415'

**GEOTECH SB-02**  
 -NG EL. 430'  
 -TOPSOIL (0' - 0.2')  
 -GROUNDWATER (8.0')  
 -SM (0.2' - 16.0')  
 -WEATHERED GNEISS (16.0' - 24.0')  
 -FRACTURED GNEISS (24.0' - 31.0')  
 -COMPLETION DEPTH EL. 399'

**GEOTECH SB-03**  
 -NG EL. 439'  
 -TOPSOIL (0' - 0.2')  
 -SM (0.2' - 8.0')  
 -FRACTURED GNEISS (8.0' - 17.5')  
 -COMPLETION DEPTH EL. 421'

**GEOTECH SB-04**  
 -NG EL. 387'  
 -TOPSOIL (0' - 0.2')  
 -SM (0.7' - 30.0')  
 -GROUNDWATER (19.0')  
 -COMPLETION DEPTH EL. 357'

**NOTE:** REFER TO TEST BORING LOG S3-0580 FOR COMPLETE SOIL MATERIAL DESCRIPTION

| NOTES   |  |  |  | REF. DRAWING  |  |  |  | REVISIONS   |  |   |  |                        |  | SUNOCO PIPELINE, L.P.  |  |   |  |
|---|--|--|--|---|--|--|--|---|--|---|--|------------------------|--|--|--|---|--|
| 1. ALL COORDINATES SHOWN ARE IN LATITUDE AND LONGITUDE. ALL MSL ELEVATIONS ARE NAD83<br>2. STATIONING IS BASED ON HORIZONTAL DISTANCES<br>3. ROONEY ENGINEERING, INC. AND SUNOCO PIPELINE, LP ARE NOT RESPONSIBLE FOR LOCATION OF FOREIGN UTILITIES SHOWN IN PLOT PLAN OR PROFILE. THE INFORMATION SHOWN HEREON IS FURNISHED WITHOUT LIABILITY ON THE PART OF ROONEY ENGINEERING, INC. AND SUNOCO PIPELINE, LP. FOR ANY DAMAGES RESULTING FROM ERRORS OR OMISSIONS THEREIN.<br>4. CONTRACTOR IS RESPONSIBLE FOR LOCATING ALL UTILITIES. CONTACT ONE CALL AT 811 PRIOR TO DIGGING.<br>5. SUNOCO EMERGENCY HOTLINE NUMBER IS #1-800-786-7440. |  |  |  | ES-6.07 TO ES-6.09 EROSION & SEDIMENT PLAN<br>SHEET 4 TO SHEET 5 AERIAL SITE PLAN |  |  |  | EP2 REVISED PER PADEP COMMENTS RECEIVED 09-06-16<br>EP1 REVISED PER PADEP COMMENTS<br>EP<br>C ISSUED FOR BID<br>B ISSUED FOR BID<br>A ISSUED FOR REVIEW |  |   |  |                        |  | DLM 10/21/16 RBM 10/21/16 AAW 10/21/16<br>MRS 05/10/16 RMB 05/10/16 AAW 05/10/16<br>MRS 02/26/16 RMB 02/26/16 AAW 02/26/16<br>DLM 08/21/15 RMB 08/21/15 AAW 08/21/15<br>DLM 07/31/15 RMB 07/31/15 AAW 07/31/15<br>RTT 03/27/15 RMB 03/27/15 AAW 03/27/15 |  | SUNOCO PIPELINE, L.P.<br>20-INCH HORIZONTAL DIRECTIONAL DRILL<br>GRADYVILLE RD<br>PENNSYLVANIA PIPELINE PROJECT |  |
| DWG NO DWG NO DESCRIPTION NO. DESCRIPTION   |  |  |  | DWG NO DWG NO DESCRIPTION NO. DESCRIPTION   |  |  |  |   |  | SCALE: 1"=250'<br>DWG. NO. PA-DE-0032.0000-RD |  | <br><br>(303) 792-5911 |  |  |  |   |  |