Pennsylvania Pipeline Project	Site Restoration and Post Construction Stormwater Management Plan November 2016
ATT	ACHMENT 3 – CONSTRUCTION DETAILS

EXISTING GRADE -WIDTH VARIES EXISTING GRADE -AASHTO #57 CHOKED WITH SAND NOTES: 1. FILL WITH TOPSOIL TO ACHIEVE DESIRED SHAPE. TYPICAL AGGREGATE SURFACE DETAIL INFILTRATION BERM DETAIL -HDPE CLEANOUT MIN 18" DIA _OVERLAP NON-WOVEN GEOTEXTILE AT LEAST 16" _AASHTO #3 CENTERLINE — SOIL AMENDMENT AREA WIDTH VARIES CONTINUOUS NONWOVEN GEOTEXTILE GRAVEL AREA **VARIES** CONTINUOUSLY PERFORATED HDPE PIPE UNCOMPACTED SUBGRADE -NOTES: NOTES: 1. NON-WOVEN GEOTEXTILE SHALL CONSIST OF NEEDLED NONWOVEN POLYPROPYLENE FIBERS AND MEET THE FOLLOWING PROPERTIES: 1. SOIL AMENDMENT MEDIAN SHOULD CONSIST OF SOIL AND COMPOST AT A RATIO OF 2:1 (SOIL: COMPOST). 2. SOIL AMENDMENT SHOULD NOT BE USED ON SLOPES GREATER THAN 30%. a. GRAB TENSILE STRENGTH (ASTM-D4632) 3. COMPOST CAN BE SUBSTITUTED WITH MULCH, MANURE, SAND. b. MULLEN BURST STRENGTH (ASTM-D3786) c. FLOW RATE (ASTM-D4491) 4. NO VEHICULAR TRAFFIC WILL BE PERMITTED TO DRIVE IN THE SOIL AMENDMENT AREA TO MINIMIZE THE POSSIBILITY OF COMPACTION d. UV RESISTANCE AFTER 500 HOURS (ASTM-D4355) 70% e. HEAT-SET OR HEAT-CALENDARED FIBERS ARE NOT PERMITTED 5. ALL CONSTRUCTION SHOULD BE COMPLETED AND STABILIZED BEFORE BEGINNING SOIL RESTORATION. ACCEPTABLE TYPES INCLUDE MIRAFI 140N, AMOCO 4547, AND 6. SOIL AMENDMENT TO BE INSTALLED BY TILING. GEOTEX 451. INFILTRATION TRENCH DETAIL

NOT TO SCALE SOIL AMENDMENT DETAIL

NOT TO SCALE **REVISIONS** 1-20" & 1-16" PROPOSED WELDED STEEL NATURAL GAS LIQUIDS PIPELINES SUNOCO PIPELINE L.P. **TETRA TECH** NO. BY DATE REMARKS SINKING SPRING, PENNSYLVANIA PENNSYLVANIA PIPELINE PROJECT www.tetratech.com POST CONSTRUCTION STORMWATER MANAGEMENT PLAN 661 ANDERSEN DRIVE - FOSTER PLAZA 7 SOUTHWEST REGIONAL OFFICE PITTSBURGH, PA 15220 DETAILS T: (412) 921-7090 | F: (412) 921-4040

PROJECT NO.: 112IC05958

FIGURE 1

DESIGNED BY:
DRAWN BY:
CHECKED BY: