

Carson, Megan

From: Doug Siler <doug.siler@gibson-thomas.com>
Sent: Wednesday, July 20, 2016 3:46 PM
To: Carson, Megan
Cc: Callie Krueger; Patrick Karnash; robert.simcik@tetrattech.com; Diane Dominick
Subject: Sunoco Pennsylvania Pipeline Project within Hempfield Township (Hempfield Township Plan No. 20160372)

Megan,

I do not have any technical comments on the above referenced land disturbance plan. However, as per §72-14.F(1) of the Hempfield Township Code, a bond in the amount of 25% of the project's construction cost will need to be posted to guarantee site stabilization and restoration. The construction cost does not need to include the cost of the gas line installation itself but it should include all E&SC BMPs, storm water runoff control BMPs and site restoration measures within the Township of Hempfield. Please provide an itemized construction cost for these. This cost estimate can either be an engineer's estimate of probable cost or a contractor's quote.

Also, please provide a letter of approval of the E&SC plan from the PA DEP upon your receipt of it. Once I receive these items, I will send the Township my letter of consistency with the Township Stormwater Management and Land Disturbance Activity Ordinance.

Thank you,
Doug

Douglas P. Siler, P.E.

Phone: 724-539-8562

Fax: 724-539-3697

Cell: 724-875-8077

doug.siler@gibson-thomas.com



1004 Ligonier St • PO Box 853 • Latrobe PA 15650

DISCLAIMER:

This electronic message contains information generated by Gibson-Thomas Engineering solely for the intended recipients. Any unauthorized interception of this message or the use or disclosure of the information it contains may violate the law and subject the violator to civil or criminal penalties. If you believe you have received this message in error, please notify the sender and delete the email immediately.