

**From:** [Merritt McGlynn](#)  
**To:** [Piktel, Joseph](#); [Bailey, Brian \(P.E.\)](#)  
**Cc:** [Debra Raggio](#); [John Slade](#); [Colleen Nagel](#); [Zaman, Muhammad](#)  
**Subject:** [External] RE: Proposed Plan Approval 08-00060A KDI Wyalusing Power LLC/New Fortress Energy Site  
**Date:** Monday, September 22, 2025 5:58:30 PM  
**Attachments:** [image001.png](#)

---

**ATTENTION:** *This email message is from an external sender. Do not open links or attachments from unknown senders. To report suspicious email, use the [Report Phishing button in Outlook](#).*

Brian, Joe –

Following up on your earlier questions:

- Water usage: In addition to the SCR, the facility is implementing water injection to control NOx to achieve the 95% reduction down to permit limits. The site will need about 75 million gallons of demineralized water per year to control NOx.
- Ammonia storage: The plant is estimated to use up 10,000 gallons per week, and the engineers recommended installing a 22,000-gallon tank. The local ammonia provider uses a 6,000-gallon truck and estimates deliveries 3X a week every other week.

Please let us know if you have any additional questions as you complete the final review of the draft Plan Approval.

Best,  
Merritt



**Merritt McGlynn** / Directing Consultant

610.422.1133 / [Profile](#) / [LinkedIn](#)

[www.all4inc.com](#) / [Locations](#) / [Articles](#) / [Podcast](#) / [Training](#)

**ALL4 // STRATEGY WITH SOLUTION. PARTNERSHIP WITH A PURPOSE.**

---

**From:** Merritt McGlynn  
**Sent:** Friday, August 15, 2025 1:40 PM  
**To:** [Piktel, Joseph <jpiktel@pa.gov>](mailto:jpiktel@pa.gov); [Bailey, Brian \(P.E.\) <briabailey@pa.gov>](mailto:briabailey@pa.gov); [Zaman, Muhammad <mzaman@pa.gov>](mailto:mzaman@pa.gov)  
**Cc:** [Debra Raggio <draggio@newfortressenergy.com>](mailto:draggio@newfortressenergy.com); [Komi Hassan <khassan@newfortressenergy.com>](mailto:khassan@newfortressenergy.com); [John Slade <jslade@all4inc.com>](mailto:jslade@all4inc.com); [Colleen Nagel <cnagel@all4inc.com>](mailto:cnagel@all4inc.com)  
**Subject:** Proposed Plan Approval 08-00060A KDI Wyalusing Power LLC/New Fortress Energy Site

Good afternoon,

Following up on the end of the comment period for the pending Plan Approval for the KDI Wyalusing Facility, we are following up on two questions from earlier this week:

- Confirm the KDI corporate structure:
  - We discussed with the Facility Responsible Official and confirmed that there are no changes to the corporate structure since the application submittal. Refer to Section B of the attached Compliance Review Form for the corporate structure.
- Confirm the natural gas supplier and confirm that the gas will meet “pipeline quality natural gas:”
  - Kinder Morgan’s MARC-1 and Williams Transco Liberty are both available. Natural gas transported on Kinder Morgan MARC-1 and/or Williams Transco pipelines must meet the respective pipeline’s tariffed requirements for natural gas quality and composition. Pipeline tariffs are regulated by FERC.

Please let us know if you have any questions or need any additional information as you develop your comment-response document.

Have a great weekend,  
Merritt



**Merritt McGlynn** / Directing Consultant

610.422.1133 / [Profile](#) / [LinkedIn](#)

[www.all4inc.com](#) / [Locations](#) / [Articles](#) / [Podcast](#) / [Training](#)

***ALL4 // STRATEGY WITH SOLUTION. PARTNERSHIP WITH A PURPOSE.***