



**Request for Determination of Requirement  
For Plan Approval/Operating Permit (RFD)**

**OFFICIAL USE ONLY**

<b>Facility Name:</b>	CRANE CLEAN ENERGY CENTER		
<b>RFD Facility ID:</b>	4991		
<b>RFD Application ID:</b>	11429	<b>Permit Number:</b>	null
<b>Request Reviewed By:</b>	Brian M Wetzel	<b>Date Received:</b>	01/05/2026
<b>Determination Reviewed By:</b>	Vincent M Pascucci	<b>Review Completed Date:</b>	01/07/2026

- 
- A plan approval is not required for this source (See 25 Pa. Code Section 127.14(a)(1)-(9)).
  - A plan approval is not required for this source (See 25 Pa. Code Section 127.14(b)).
  - An operating permit is not required for this source (See 25 Pa. Code Section 127.443(a)).
  - The source(s) do(es) not qualify for exemption. Applicant is required to submit a plan approval application.
  - The source(s) do(es) not qualify for exemption. Applicant is required to submit an operating permit application.
- 

**Remarks**

Temporary operation of the engines for maintenance testing exempt per 25 Pa. Code §127.14(a)(8), Item 44 - Any source granted an exemption by the Department through the execution of a Request for Determination (RFD) form. Each engine shall be limited to combusting 4,560 gallons of diesel. Constellation Energy Generation/Crane Clean Energy Center shall maintain records of the amount of diesel combusted in each engine per month. These records shall be retained for a minimum of five (5) years and shall be made available to the Department upon request..

---

**Conditions**