


ANALYTICAL REPORT

Eurofins Lancaster Laboratories Env, LLC
2425 New Holland Pike
Lancaster, PA 17601
Tel: (717)656-2300

Laboratory Job ID: 410-39905-1
Client Project/Site: Newberry System
Sampling Event: Newberry System

For:
SUEZ Water Environmental Services Inc
6310 Allentown Blvd
Suite 104
Harrisburg, Pennsylvania 17112

Attn: Penny Bumbarger



Authorized for release by:
5/25/2021 3:53:48 PM

Elizabeth Zanar, Project Manager
(717)556-7290
Elizabeth.Zanar@eurofinset.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
 - Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
 - Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.
- Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

Elizabeth Zanar
Project Manager
5/25/2021 3:53:48 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	9
Surrogate Summary	19
QC Sample Results	21
QC Association Summary	25
Lab Chronicle	27
Certification Summary	31
Method Summary	32
Sample Summary	33
Chain of Custody	34
Receipt Checklists	36

Definitions/Glossary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Qualifiers

LCMS

Qualifier	Qualifier Description
E	Result exceeded calibration range.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Job ID: 410-39905-1

Laboratory: Eurofins Lancaster Laboratories Env, LLC

Narrative

Job Narrative
410-39905-1

Receipt

The samples were received on 5/14/2021 11:26 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was -0.3°C

LCMS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Detection Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-39905-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	10		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	5.6		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	6.5		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorononanoic acid	4.3		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	5.7		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	42		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	55		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-39905-2

No Detections.

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-39905-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	6.7		1.8	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.7		1.8	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.0		1.8	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	5.0		1.8	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid - DL	69		18	4.4	ng/L	10		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid - DL	84		18	4.4	ng/L	10		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-39905-4

No Detections.

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-39905-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	2.7		1.8	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 302 DuPont Between Lead & Lag FB

Lab Sample ID: 410-39905-6

No Detections.

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-39905-7

No Detections.

Client Sample ID: 7670061 302 DuPont After Lag Vessel FB

Lab Sample ID: 410-39905-8

No Detections.

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-39905-9

No Detections.

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-39905-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	9.4		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.9		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	7.0		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	4.9		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	11		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Env, LLC

Detection Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-39905-12

No Detections.

Client Sample ID: 7670061 005 Conley Well

Lab Sample ID: 410-39905-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	6.6		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	1.8		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	3.6		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	1.9		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	3.0		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	5.1		1.7	0.44	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 005 Conley Well FB

Lab Sample ID: 410-39905-14

No Detections.

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	9.8		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	3.0		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	6.6		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.2		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	4.9		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	6.9		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 301 Conley Between Lead & Lag FB

Lab Sample ID: 410-39905-16

No Detections.

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-39905-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	10		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.7		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.1		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.1		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	3.3		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	2.8		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-39905-18

No Detections.

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-39905-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	10		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.7		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.1		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.0		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	3.4		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	2.8		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Env, LLC

Detection Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-39905-20

No Detections.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Env, LLC

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-39905-1

Date Collected: 05/13/21 09:35

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	10		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluoroheptanoic acid	5.6		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorooctanoic acid	6.5		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorononanoic acid	4.3		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorodecanoic acid	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorotridecanoic acid	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorotetradecanoic acid	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorobutanesulfonic acid	5.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorohexanesulfonic acid	42		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorooctanesulfonic acid	55		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
NEtFOSAA	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
NMeFOSAA	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluoroundecanoic acid	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Perfluorododecanoic acid	<1.7		1.7	0.44	ng/L		05/17/21 06:57	05/20/21 14:37	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	87		70 - 130				05/17/21 06:57	05/20/21 14:37	1
13C2 PFDA	92		70 - 130				05/17/21 06:57	05/20/21 14:37	1
13C2 PFHxA	86		70 - 130				05/17/21 06:57	05/20/21 14:37	1

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-39905-2

Date Collected: 05/13/21 09:35

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluoroheptanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorooctanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorononanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorodecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorotridecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorotetradecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
NEtFOSAA	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
NMeFOSAA	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluoroundecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Perfluorododecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 14:48	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	89		70 - 130				05/17/21 06:57	05/20/21 14:48	1
13C2 PFDA	90		70 - 130				05/17/21 06:57	05/20/21 14:48	1
13C2 PFHxA	86		70 - 130				05/17/21 06:57	05/20/21 14:48	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-39905-3

Date Collected: 05/13/21 10:10

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	6.7		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluoroheptanoic acid	2.7		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorooctanoic acid	5.0		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorononanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorodecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorotridecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorotetradecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorobutanesulfonic acid	5.0		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
NEtFOSAA	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
NMeFOSAA	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluoroundecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Perfluorododecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:00	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	85		70 - 130				05/17/21 06:57	05/20/21 15:00	1
13C2 PFDA	90		70 - 130				05/17/21 06:57	05/20/21 15:00	1
13C2 PFHxA	86		70 - 130				05/17/21 06:57	05/20/21 15:00	1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanesulfonic acid	69		18	4.4	ng/L		05/17/21 06:57	05/22/21 03:30	10
Perfluorooctanesulfonic acid	84		18	4.4	ng/L		05/17/21 06:57	05/22/21 03:30	10
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	85		70 - 130				05/17/21 06:57	05/22/21 03:30	10
13C2 PFDA	88		70 - 130				05/17/21 06:57	05/22/21 03:30	10
13C2 PFHxA	85		70 - 130				05/17/21 06:57	05/22/21 03:30	10

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-39905-4

Date Collected: 05/13/21 10:10

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluoroheptanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorooctanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorononanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorodecanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorotridecanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorotetradecanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
NEtFOSAA	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
NMeFOSAA	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluoroundecanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Perfluorododecanoic acid	<1.9		1.9	0.47	ng/L		05/17/21 06:57	05/20/21 15:11	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	82		70 - 130				05/17/21 06:57	05/20/21 15:11	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-39905-4

Date Collected: 05/13/21 10:10

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	86		70 - 130	05/17/21 06:57	05/20/21 15:11	1
13C2 PFHxA	83		70 - 130	05/17/21 06:57	05/20/21 15:11	1

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-39905-5

Date Collected: 05/13/21 10:00

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	2.7		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluoroheptanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorooctanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorononanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorodecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorotridecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorotetradecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
NEtFOSAA	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
NMeFOSAA	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluoroundecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1
Perfluorododecanoic acid	<1.8		1.8	0.44	ng/L		05/17/21 06:57	05/20/21 15:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	80		70 - 130	05/17/21 06:57	05/20/21 15:23	1
13C2 PFDA	86		70 - 130	05/17/21 06:57	05/20/21 15:23	1
13C2 PFHxA	86		70 - 130	05/17/21 06:57	05/20/21 15:23	1

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-39905-6

FB

Date Collected: 05/13/21 10:00

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluoroheptanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorooctanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorononanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorodecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorotridecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorotetradecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
NEtFOSAA	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
NMeFOSAA	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluoroundecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1
Perfluorododecanoic acid	<1.9		1.9	0.48	ng/L		05/17/21 06:57	05/20/21 15:34	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-39905-6

FB

Date Collected: 05/13/21 10:00

Matrix: Potable Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	85		70 - 130	05/17/21 06:57	05/20/21 15:34	1
13C2 PFDA	90		70 - 130	05/17/21 06:57	05/20/21 15:34	1
13C2 PFHxA	79		70 - 130	05/17/21 06:57	05/20/21 15:34	1

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-39905-7

Date Collected: 05/13/21 10:05

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		05/17/21 06:57	05/20/21 15:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	90		70 - 130	05/17/21 06:57	05/20/21 15:46	1
13C2 PFDA	88		70 - 130	05/17/21 06:57	05/20/21 15:46	1
13C2 PFHxA	83		70 - 130	05/17/21 06:57	05/20/21 15:46	1

Client Sample ID: 7670061 302 DuPont After Lag Vessel FB

Lab Sample ID: 410-39905-8

Date Collected: 05/13/21 10:05

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluoroheptanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorooctanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorononanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorodecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorotridecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorotetradecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
NEtFOSAA	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
NMeFOSAA	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluoroundecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1
Perfluorododecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 09:51	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 302 DuPont After Lag Vessel FB

Lab Sample ID: 410-39905-8

Date Collected: 05/13/21 10:05

Matrix: Potable Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	96		70 - 130	05/19/21 09:18	05/22/21 09:51	1
13C2 PFDA	95		70 - 130	05/19/21 09:18	05/22/21 09:51	1
13C2 PFHxA	95		70 - 130	05/19/21 09:18	05/22/21 09:51	1

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-39905-9

Date Collected: 05/13/21 09:55

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	102		70 - 130	05/19/21 09:18	05/22/21 10:02	1
13C2 PFDA	100		70 - 130	05/19/21 09:18	05/22/21 10:02	1
13C2 PFHxA	96		70 - 130	05/19/21 09:18	05/22/21 10:02	1

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-39905-11

Date Collected: 05/13/21 10:50

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	9.4		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluoroheptanoic acid	2.9		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorooctanoic acid	7.0		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorohexanesulfonic acid	4.9		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorooctanesulfonic acid	11		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 10:25	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-39905-11

Date Collected: 05/13/21 10:50

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	90		70 - 130	05/19/21 09:18	05/22/21 10:25	1
13C2 PFDA	105		70 - 130	05/19/21 09:18	05/22/21 10:25	1
13C2 PFHxA	97		70 - 130	05/19/21 09:18	05/22/21 10:25	1

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-39905-12

Date Collected: 05/13/21 10:50

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 10:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	91		70 - 130	05/19/21 09:18	05/22/21 10:37	1
13C2 PFDA	97		70 - 130	05/19/21 09:18	05/22/21 10:37	1
13C2 PFHxA	93		70 - 130	05/19/21 09:18	05/22/21 10:37	1

Client Sample ID: 7670061 005 Conley Well

Lab Sample ID: 410-39905-13

Date Collected: 05/13/21 10:55

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	6.6		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluoroheptanoic acid	1.8		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorooctanoic acid	3.6		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorononanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorodecanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorotridecanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorotetradecanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorobutanesulfonic acid	1.9		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorohexanesulfonic acid	3.0		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorooctanesulfonic acid	5.1		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
NEtFOSAA	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
NMeFOSAA	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluoroundecanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1
Perfluorododecanoic acid	<1.7		1.7	0.44	ng/L		05/19/21 09:18	05/22/21 10:48	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 005 Conley Well

Lab Sample ID: 410-39905-13

Date Collected: 05/13/21 10:55

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	98		70 - 130	05/19/21 09:18	05/22/21 10:48	1
13C2 PFDA	98		70 - 130	05/19/21 09:18	05/22/21 10:48	1
13C2 PFHxA	93		70 - 130	05/19/21 09:18	05/22/21 10:48	1

Client Sample ID: 7670061 005 Conley Well FB

Lab Sample ID: 410-39905-14

Date Collected: 05/13/21 10:55

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluoroheptanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorooctanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorobutanesulfonic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorohexanesulfonic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorooctanesulfonic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	94		70 - 130	05/19/21 09:18	05/22/21 11:00	1
13C2 PFDA	102		70 - 130	05/19/21 09:18	05/22/21 11:00	1
13C2 PFHxA	99		70 - 130	05/19/21 09:18	05/22/21 11:00	1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-15

Date Collected: 05/13/21 10:45

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	9.8		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluoroheptanoic acid	3.0		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorooctanoic acid	6.6		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorobutanesulfonic acid	3.2		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorohexanesulfonic acid	4.9		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorooctanesulfonic acid	6.9		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 11:11	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-15

Date Collected: 05/13/21 10:45

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	94		70 - 130	05/19/21 09:18	05/22/21 11:11	1
13C2 PFDA	99		70 - 130	05/19/21 09:18	05/22/21 11:11	1
13C2 PFHxA	98		70 - 130	05/19/21 09:18	05/22/21 11:11	1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-16

FB

Date Collected: 05/13/21 10:45

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 11:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	100		70 - 130	05/19/21 09:18	05/22/21 11:23	1
13C2 PFDA	103		70 - 130	05/19/21 09:18	05/22/21 11:23	1
13C2 PFHxA	98		70 - 130	05/19/21 09:18	05/22/21 11:23	1

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-39905-17

Date Collected: 05/13/21 10:40

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	10		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluoroheptanoic acid	2.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorooctanoic acid	5.1		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorononanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorodecanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorotridecanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorotetradecanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorobutanesulfonic acid	3.1		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorohexanesulfonic acid	3.3		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorooctanesulfonic acid	2.8		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
NEtFOSAA	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
NMeFOSAA	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluoroundecanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1
Perfluorododecanoic acid	<1.7		1.7	0.42	ng/L		05/19/21 09:18	05/22/21 11:34	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-39905-17

Date Collected: 05/13/21 10:40

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	100		70 - 130	05/19/21 09:18	05/22/21 11:34	1
13C2 PFDA	99		70 - 130	05/19/21 09:18	05/22/21 11:34	1
13C2 PFHxA	92		70 - 130	05/19/21 09:18	05/22/21 11:34	1

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-39905-18

Date Collected: 05/13/21 10:40

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluoroheptanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorooctanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorononanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorodecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorotridecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorotetradecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
NEtFOSAA	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
NMeFOSAA	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluoroundecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1
Perfluorododecanoic acid	<1.9		1.9	0.47	ng/L		05/19/21 09:18	05/22/21 11:57	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	95		70 - 130	05/19/21 09:18	05/22/21 11:57	1
13C2 PFDA	102		70 - 130	05/19/21 09:18	05/22/21 11:57	1
13C2 PFHxA	97		70 - 130	05/19/21 09:18	05/22/21 11:57	1

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-39905-19

Date Collected: 05/13/21 10:35

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	10		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluoroheptanoic acid	2.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorooctanoic acid	5.1		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorobutanesulfonic acid	3.0		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorohexanesulfonic acid	3.4		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorooctanesulfonic acid	2.8		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		05/19/21 09:18	05/22/21 12:09	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-39905-19

Date Collected: 05/13/21 10:35

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	88		70 - 130	05/19/21 09:18	05/22/21 12:09	1
13C2 PFDA	87		70 - 130	05/19/21 09:18	05/22/21 12:09	1
13C2 PFHxA	89		70 - 130	05/19/21 09:18	05/22/21 12:09	1

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-39905-20

Date Collected: 05/13/21 10:35

Matrix: Potable Water

Date Received: 05/14/21 11:26

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		05/19/21 09:18	05/22/21 12:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130	05/19/21 09:18	05/22/21 12:20	1
13C2 PFDA	102		70 - 130	05/19/21 09:18	05/22/21 12:20	1
13C2 PFHxA	89		70 - 130	05/19/21 09:18	05/22/21 12:20	1

Surrogate Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		d5NEFOS (70-130)	PFDA (70-130)	PFHxA (70-130)
410-39905-1	7670061 002 Coppersmith Well	87	92	86
410-39905-3	7670061 003 DuPont Well	85	90	86
410-39905-3 - DL	7670061 003 DuPont Well	85	88	85
410-39905-5	7670061 302 DuPont Between Lead & Lag	80	86	86
410-39905-7	7670061 302 DuPont After Lag Vessel	90	88	83
410-39905-9	7670061 102 DuPont EP	102	100	96
410-39905-11	7670061 001 Playground Well	90	105	97
410-39905-13	7670061 005 Conley Well	98	98	93
410-39905-15	7670061 301 Conley Between Lead & Lag	94	99	98
410-39905-17	7670061 301 Conley After Lag Vessel	100	99	92
410-39905-19	7670061 101 Conley EP Grab Water	88	87	89
LCS 410-126924/2-A	Lab Control Sample	78	87	81
LCS 410-128129/2-A	Lab Control Sample	102	103	95
LCS 410-126924/3-A	Lab Control Sample Dup	85	87	85
LCS 410-128129/3-A	Lab Control Sample Dup	79	86	85
LLCS 410-126924/4-A	Lab Control Sample	76	86	83
LLCS 410-128129/4-A	Lab Control Sample	100	99	93
MB 410-126924/1-A	Method Blank	70	70	72
MB 410-128129/1-A	Method Blank	92	89	88

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
PFDA = 13C2 PFDA
PFHxA = 13C2 PFHxA

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Matrix: Potable Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		d5NEFOS (70-130)	PFDA (70-130)	PFHxA (70-130)
410-39905-2	7670061 002 Coppersmith Well FB	89	90	86
410-39905-4	7670061 003 DuPont Well FB	82	86	83
410-39905-6	7670061 302 DuPont Between Lead & Lag FB	85	90	79
410-39905-8	7670061 302 DuPont After Lag Vessel FB	96	95	95
410-39905-12	7670061 001 Playground Well FB	91	97	93
410-39905-14	7670061 005 Conley Well FB	94	102	99
410-39905-16	7670061 301 Conley Between Lead & Lag FB	100	103	98
410-39905-18	7670061 301 Conley After Lag Vessel FB	95	102	97
410-39905-20	7670061 101 Conley Field Blank Grab Water	97	102	89

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

Surrogate Summary

Client: SUEZ Water Environmental Services Inc

Job ID: 410-39905-1

Project/Site: Newberry System

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Lab Sample ID: MB 410-126924/1-A
Matrix: Drinking Water
Analysis Batch: 128475

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 126924

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Perfluorohexanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluoroheptanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorooctanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorononanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorodecanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorotridecanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorotetradecanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorobutanesulfonic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorohexanesulfonic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorooctanesulfonic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
NEtFOSAA	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
NMeFOSAA	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluoroundecanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1
Perfluorododecanoic acid	<2.0		2.0	0.50	ng/L		05/17/21 06:57	05/20/21 14:03	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	70		70 - 130	05/17/21 06:57	05/20/21 14:03	1
13C2 PFDA	70		70 - 130	05/17/21 06:57	05/20/21 14:03	1
13C2 PFHxA	72		70 - 130	05/17/21 06:57	05/20/21 14:03	1

Lab Sample ID: LCS 410-126924/2-A
Matrix: Drinking Water
Analysis Batch: 127614

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 126924

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec.
							Limits
Perfluorohexanoic acid	100	82.5	E	ng/L		82	70 - 130
Perfluoroheptanoic acid	100	85.1	E	ng/L		85	70 - 130
Perfluorooctanoic acid	100	85.4	E	ng/L		85	70 - 130
Perfluorononanoic acid	100	86.6	E	ng/L		87	70 - 130
Perfluorodecanoic acid	100	84.8	E	ng/L		85	70 - 130
Perfluorotridecanoic acid	100	96.3	E	ng/L		96	70 - 130
Perfluorotetradecanoic acid	100	92.9	E	ng/L		93	70 - 130
Perfluorobutanesulfonic acid	88.5	71.6	E	ng/L		81	70 - 130
Perfluorohexanesulfonic acid	91.2	88.4	E	ng/L		97	70 - 130
Perfluorooctanesulfonic acid	92.6	85.2	E	ng/L		92	70 - 130
NEtFOSAA	100	80.2	E	ng/L		80	70 - 130
NMeFOSAA	100	80.9	E	ng/L		81	70 - 130
Perfluoroundecanoic acid	100	86.4	E	ng/L		86	70 - 130
Perfluorododecanoic acid	100	87.2	E	ng/L		87	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	78		70 - 130
13C2 PFDA	87		70 - 130
13C2 PFHxA	81		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: LCSD 410-126924/3-A

Matrix: Drinking Water

Analysis Batch: 127614

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 126924

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec.		RPD	Limit
							Limits	RPD		
Perfluorohexanoic acid	100	85.1	E	ng/L		85	70 - 130	3	30	
Perfluoroheptanoic acid	100	85.4	E	ng/L		85	70 - 130	0	30	
Perfluorooctanoic acid	100	86.2	E	ng/L		86	70 - 130	1	30	
Perfluorononanoic acid	100	83.3	E	ng/L		83	70 - 130	4	30	
Perfluorodecanoic acid	100	85.6	E	ng/L		86	70 - 130	1	30	
Perfluorotridecanoic acid	100	96.2	E	ng/L		96	70 - 130	0	30	
Perfluorotetradecanoic acid	100	92.7	E	ng/L		93	70 - 130	0	30	
Perfluorobutanesulfonic acid	88.5	74.9	E	ng/L		85	70 - 130	4	30	
Perfluorohexanesulfonic acid	91.2	83.5	E	ng/L		92	70 - 130	6	30	
Perfluorooctanesulfonic acid	92.6	84.0	E	ng/L		91	70 - 130	1	30	
NEtFOSAA	100	85.3	E	ng/L		85	70 - 130	6	30	
NMeFOSAA	100	83.6	E	ng/L		84	70 - 130	3	30	
Perfluoroundecanoic acid	100	87.9	E	ng/L		88	70 - 130	2	30	
Perfluorododecanoic acid	100	92.9	E	ng/L		93	70 - 130	6	30	

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	85		70 - 130
13C2 PFDA	87		70 - 130
13C2 PFHxA	85		70 - 130

Lab Sample ID: LLCS 410-126924/4-A

Matrix: Drinking Water

Analysis Batch: 127614

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 126924

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec.		Limit
							Limits	RPD	
Perfluorohexanoic acid	2.40	1.60	J	ng/L		66	50 - 150		
Perfluoroheptanoic acid	2.40	1.63	J	ng/L		68	50 - 150		
Perfluorooctanoic acid	2.40	1.76	J	ng/L		73	50 - 150		
Perfluorononanoic acid	2.40	1.62	J	ng/L		68	50 - 150		
Perfluorodecanoic acid	2.40	1.64	J	ng/L		69	50 - 150		
Perfluorotridecanoic acid	2.40	1.75	J	ng/L		73	50 - 150		
Perfluorotetradecanoic acid	2.40	1.73	J	ng/L		72	50 - 150		
Perfluorobutanesulfonic acid	2.12	1.28	J	ng/L		60	50 - 150		
Perfluorohexanesulfonic acid	2.19	1.55	J	ng/L		71	50 - 150		
Perfluorooctanesulfonic acid	2.22	1.45	J	ng/L		65	50 - 150		
NEtFOSAA	2.40	1.61	J	ng/L		67	50 - 150		
NMeFOSAA	2.40	1.45	J	ng/L		60	50 - 150		
Perfluoroundecanoic acid	2.40	1.69	J	ng/L		70	50 - 150		
Perfluorododecanoic acid	2.40	1.65	J	ng/L		69	50 - 150		

Surrogate	LLCS LLCS		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	76		70 - 130
13C2 PFDA	86		70 - 130
13C2 PFHxA	83		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: MB 410-128129/1-A
Matrix: Drinking Water
Analysis Batch: 129439

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 128129

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Perfluorohexanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluoroheptanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorooctanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorononanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorodecanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorotridecanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorotetradecanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorobutanesulfonic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorohexanesulfonic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorooctanesulfonic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
NEtFOSAA	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
NMeFOSAA	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluoroundecanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1
Perfluorododecanoic acid	<2.0		2.0	0.50	ng/L		05/19/21 09:18	05/22/21 09:04	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	92		70 - 130	05/19/21 09:18	05/22/21 09:04	1
13C2 PFDA	89		70 - 130	05/19/21 09:18	05/22/21 09:04	1
13C2 PFHxA	88		70 - 130	05/19/21 09:18	05/22/21 09:04	1

Lab Sample ID: LCS 410-128129/2-A
Matrix: Drinking Water
Analysis Batch: 129439

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 128129

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Perfluorohexanoic acid	25.6	22.5		ng/L		88	70 - 130
Perfluoroheptanoic acid	25.6	19.7		ng/L		77	70 - 130
Perfluorooctanoic acid	25.6	22.9		ng/L		90	70 - 130
Perfluorononanoic acid	25.6	22.4		ng/L		87	70 - 130
Perfluorodecanoic acid	25.6	23.5		ng/L		92	70 - 130
Perfluorotridecanoic acid	25.6	24.4		ng/L		95	70 - 130
Perfluorotetradecanoic acid	25.6	23.7		ng/L		93	70 - 130
Perfluorobutanesulfonic acid	22.7	18.6		ng/L		82	70 - 130
Perfluorohexanesulfonic acid	23.3	20.3		ng/L		87	70 - 130
Perfluorooctanesulfonic acid	23.7	22.0		ng/L		93	70 - 130
NEtFOSAA	25.6	21.8		ng/L		85	70 - 130
NMeFOSAA	25.6	21.8		ng/L		85	70 - 130
Perfluoroundecanoic acid	25.6	23.3		ng/L		91	70 - 130
Perfluorododecanoic acid	25.6	21.5		ng/L		84	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	102		70 - 130
13C2 PFDA	103		70 - 130
13C2 PFHxA	95		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: LCSD 410-128129/3-A

Matrix: Drinking Water

Analysis Batch: 129618

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 128129

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Perfluorohexanoic acid	25.6	19.8		ng/L		77	70 - 130	13	30
Perfluoroheptanoic acid	25.6	18.3		ng/L		71	70 - 130	8	30
Perfluorooctanoic acid	25.6	19.9		ng/L		78	70 - 130	14	30
Perfluorononanoic acid	25.6	19.5		ng/L		76	70 - 130	14	30
Perfluorodecanoic acid	25.6	19.8		ng/L		77	70 - 130	17	30
Perfluorotridecanoic acid	25.6	18.2		ng/L		71	70 - 130	29	30
Perfluorotetradecanoic acid	25.6	19.3		ng/L		75	70 - 130	21	30
Perfluorobutanesulfonic acid	22.7	15.8		ng/L		70	70 - 130	17	30
Perfluorohexanesulfonic acid	23.3	16.7		ng/L		71	70 - 130	20	30
Perfluorooctanesulfonic acid	23.7	18.1		ng/L		76	70 - 130	19	30
NEtFOSAA	25.6	18.0		ng/L		70	70 - 130	19	30
NMeFOSAA	25.6	17.9		ng/L		70	70 - 130	20	30
Perfluoroundecanoic acid	25.6	18.6		ng/L		73	70 - 130	22	30
Perfluorododecanoic acid	25.6	19.0		ng/L		74	70 - 130	12	30

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	79		70 - 130
13C2 PFDA	86		70 - 130
13C2 PFHxA	85		70 - 130

Lab Sample ID: LLCS 410-128129/4-A

Matrix: Drinking Water

Analysis Batch: 129439

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 128129

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Perfluorohexanoic acid	2.40	1.96	J	ng/L		82	50 - 150		
Perfluoroheptanoic acid	2.40	1.57	J	ng/L		65	50 - 150		
Perfluorooctanoic acid	2.40	1.89	J	ng/L		79	50 - 150		
Perfluorononanoic acid	2.40	1.98	J	ng/L		82	50 - 150		
Perfluorodecanoic acid	2.40	1.91	J	ng/L		80	50 - 150		
Perfluorotridecanoic acid	2.40	2.05	J	ng/L		85	50 - 150		
Perfluorotetradecanoic acid	2.40	1.95	J	ng/L		81	50 - 150		
Perfluorobutanesulfonic acid	2.12	1.51	J	ng/L		71	50 - 150		
Perfluorohexanesulfonic acid	2.19	1.59	J	ng/L		73	50 - 150		
Perfluorooctanesulfonic acid	2.22	1.80	J	ng/L		81	50 - 150		
NEtFOSAA	2.40	1.92	J	ng/L		80	50 - 150		
NMeFOSAA	2.40	1.72	J	ng/L		72	50 - 150		
Perfluoroundecanoic acid	2.40	2.04	J	ng/L		85	50 - 150		
Perfluorododecanoic acid	2.40	2.09	J	ng/L		87	50 - 150		

Surrogate	LLCS		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	100		70 - 130
13C2 PFDA	99		70 - 130
13C2 PFHxA	93		70 - 130

QC Association Summary

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-39905-1

LCMS

Prep Batch: 126924

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-39905-1	7670061 002 Coppersmith Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-2	7670061 002 Coppersmith Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-3	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-3 - DL	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-4	7670061 003 DuPont Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-5	7670061 302 DuPont Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-6	7670061 302 DuPont Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-7	7670061 302 DuPont After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	
MB 410-126924/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS 410-126924/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCSD 410-126924/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LLCS 410-126924/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	

Analysis Batch: 127614

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCS 410-126924/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
LCSD 410-126924/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
LLCS 410-126924/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924

Prep Batch: 128129

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-39905-8	7670061 302 DuPont After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-9	7670061 102 DuPont EP	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-11	7670061 001 Playground Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-12	7670061 001 Playground Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-13	7670061 005 Conley Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-14	7670061 005 Conley Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-15	7670061 301 Conley Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-16	7670061 301 Conley Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-17	7670061 301 Conley After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-18	7670061 301 Conley After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-39905-19	7670061 101 Conley EP Grab Water	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-39905-20	7670061 101 Conley Field Blank Grab Water	Total/NA	Potable Water	EPA 537 Ver 1.1	
MB 410-128129/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS 410-128129/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCSD 410-128129/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LLCS 410-128129/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	

Analysis Batch: 128456

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-39905-1	7670061 002 Coppersmith Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
410-39905-2	7670061 002 Coppersmith Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	126924
410-39905-3	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
410-39905-4	7670061 003 DuPont Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	126924
410-39905-5	7670061 302 DuPont Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
410-39905-6	7670061 302 DuPont Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	126924
410-39905-7	7670061 302 DuPont After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924

Analysis Batch: 128475

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 410-126924/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924

QC Association Summary

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-39905-1

LCMS

Analysis Batch: 129439

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-39905-3 - DL	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	126924
410-39905-8	7670061 302 DuPont After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
410-39905-9	7670061 102 DuPont EP	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-11	7670061 001 Playground Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-12	7670061 001 Playground Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
410-39905-13	7670061 005 Conley Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-14	7670061 005 Conley Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
410-39905-15	7670061 301 Conley Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-16	7670061 301 Conley Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
410-39905-17	7670061 301 Conley After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-18	7670061 301 Conley After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
410-39905-19	7670061 101 Conley EP Grab Water	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
410-39905-20	7670061 101 Conley Field Blank Grab Water	Total/NA	Potable Water	EPA 537 Ver 1.1	128129
MB 410-128129/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
LCS 410-128129/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129
LLCS 410-128129/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129

Analysis Batch: 129618

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCSD 410-128129/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	128129



Lab Chronicle

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-39905-1

Date Collected: 05/13/21 09:35

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 14:37	DCS9	ELLE

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-39905-2

Date Collected: 05/13/21 09:35

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 14:48	DCS9	ELLE

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-39905-3

Date Collected: 05/13/21 10:10

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 15:00	DCS9	ELLE
Total/NA	Prep	EPA 537 Ver 1.1	DL		126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1	DL	10	129439	05/22/21 03:30	Y6ZN	ELLE

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-39905-4

Date Collected: 05/13/21 10:10

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 15:11	DCS9	ELLE

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-39905-5

Date Collected: 05/13/21 10:00

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 15:23	DCS9	ELLE

Client Sample ID: 7670061 302 DuPont Between Lead & Lag FB

Lab Sample ID: 410-39905-6

Date Collected: 05/13/21 10:00

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 15:34	DCS9	ELLE

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-39905-7

Date Collected: 05/13/21 10:05

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			126924	05/17/21 06:57	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	128456	05/20/21 15:46	DCS9	ELLE

Client Sample ID: 7670061 302 DuPont After Lag Vessel FB

Lab Sample ID: 410-39905-8

Date Collected: 05/13/21 10:05

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 09:51	Y6ZN	ELLE

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-39905-9

Date Collected: 05/13/21 09:55

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 10:02	Y6ZN	ELLE

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-39905-11

Date Collected: 05/13/21 10:50

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 10:25	Y6ZN	ELLE

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-39905-12

Date Collected: 05/13/21 10:50

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 10:37	Y6ZN	ELLE

Client Sample ID: 7670061 005 Conley Well

Lab Sample ID: 410-39905-13

Date Collected: 05/13/21 10:55

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 10:48	Y6ZN	ELLE

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 005 Conley Well FB

Lab Sample ID: 410-39905-14

Date Collected: 05/13/21 10:55

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 11:00	Y6ZN	ELLE

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-15

Date Collected: 05/13/21 10:45

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 11:11	Y6ZN	ELLE

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-39905-16

FB

Date Collected: 05/13/21 10:45

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 11:23	Y6ZN	ELLE

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-39905-17

Date Collected: 05/13/21 10:40

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 11:34	Y6ZN	ELLE

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-39905-18

Date Collected: 05/13/21 10:40

Matrix: Potable Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 11:57	Y6ZN	ELLE

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-39905-19

Date Collected: 05/13/21 10:35

Matrix: Drinking Water

Date Received: 05/14/21 11:26

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 12:09	Y6ZN	ELLE

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-39905-20

Date Collected: 05/13/21 10:35

Matrix: Potable Water

Date Received: 05/14/21 11:26

<u>Prep Type</u>	<u>Batch Type</u>	<u>Batch Method</u>	<u>Run</u>	<u>Dilution Factor</u>	<u>Batch Number</u>	<u>Prepared or Analyzed</u>	<u>Analyst</u>	<u>Lab</u>
Total/NA	Prep	EPA 537 Ver 1.1			128129	05/19/21 09:18	GU2F	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	129439	05/22/21 12:20	Y6ZN	ELLE

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Env, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Accreditation/Certification Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Laboratory: Eurofins Lancaster Laboratories Env, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	36-00037	01-31-22

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Method Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Method	Method Description	Protocol	Laboratory
EPA 537 Ver 1.1	EPA 537 Version 1.1	EPA	ELLE
EPA 537 Ver 1.1	EPA 537 Version 1.1	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Env, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Sample Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-39905-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Asset ID
410-39905-1	7670061 002 Coppersmith Well	Drinking Water	05/13/21 09:35	05/14/21 11:26	
410-39905-2	7670061 002 Coppersmith Well FB	Potable Water	05/13/21 09:35	05/14/21 11:26	
410-39905-3	7670061 003 DuPont Well	Drinking Water	05/13/21 10:10	05/14/21 11:26	
410-39905-4	7670061 003 DuPont Well FB	Potable Water	05/13/21 10:10	05/14/21 11:26	
410-39905-5	7670061 302 DuPont Between Lead & Lag	Drinking Water	05/13/21 10:00	05/14/21 11:26	
410-39905-6	7670061 302 DuPont Between Lead & Lag FB	Potable Water	05/13/21 10:00	05/14/21 11:26	
410-39905-7	7670061 302 DuPont After Lag Vessel	Drinking Water	05/13/21 10:05	05/14/21 11:26	
410-39905-8	7670061 302 DuPont After Lag Vessel FB	Potable Water	05/13/21 10:05	05/14/21 11:26	
410-39905-9	7670061 102 DuPont EP	Drinking Water	05/13/21 09:55	05/14/21 11:26	
410-39905-11	7670061 001 Playground Well	Drinking Water	05/13/21 10:50	05/14/21 11:26	
410-39905-12	7670061 001 Playground Well FB	Potable Water	05/13/21 10:50	05/14/21 11:26	
410-39905-13	7670061 005 Conley Well	Drinking Water	05/13/21 10:55	05/14/21 11:26	
410-39905-14	7670061 005 Conley Well FB	Potable Water	05/13/21 10:55	05/14/21 11:26	
410-39905-15	7670061 301 Conley Between Lead & Lag	Drinking Water	05/13/21 10:45	05/14/21 11:26	
410-39905-16	7670061 301 Conley Between Lead & Lag FB	Potable Water	05/13/21 10:45	05/14/21 11:26	
410-39905-17	7670061 301 Conley After Lag Vessel	Drinking Water	05/13/21 10:40	05/14/21 11:26	
410-39905-18	7670061 301 Conley After Lag Vessel FB	Potable Water	05/13/21 10:40	05/14/21 11:26	
410-39905-19	7670061 101 Conley EP Grab Water	Drinking Water	05/13/21 10:35	05/14/21 11:26	
410-39905-20	7670061 101 Conley Field Blank Grab Water	Potable Water	05/13/21 10:35	05/14/21 11:26	





Lancaster Laboratories
Environmental



410-39905 Chain of Custody

Final Analysis Request/Chain of Custody

Sample # _____

Client: SUEZ WATER PA				Matrix		Analyses Requested						For Lab Use Only																																																													
Project Name: Newberry System			Site ID #:			Preservation and Filtration Codes						SF #: _____																																																													
Project Manager: Elizabeth Zanar			P.O. #:			<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:20px;">O</td> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td style="width:20px;">PFAS (14) 537 v 1.1</td> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr><td> </td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>						O												PFAS (14) 537 v 1.1																																																SCR #: _____	
O																																																																									
PFAS (14) 537 v 1.1																																																																									
Sampler: Penny Bumbarger			PWSID #: 7670061			<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td colspan="12" style="text-align:center;">Preservation Codes</td> </tr> <tr> <td>H = HCl</td><td>T = Thiosulfate</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>N = HNO₃</td><td>B = NaOH</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>S = H₂SO₄</td><td>P = H₃PO₄</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td colspan="12">F = Field Filtered O = Other</td> </tr> </table>						Preservation Codes												H = HCl	T = Thiosulfate											N = HNO ₃	B = NaOH											S = H ₂ SO ₄	P = H ₃ PO ₄											F = Field Filtered O = Other													
Preservation Codes																																																																									
H = HCl	T = Thiosulfate																																																																								
N = HNO ₃	B = NaOH																																																																								
S = H ₂ SO ₄	P = H ₃ PO ₄																																																																								
F = Field Filtered O = Other																																																																									
Phone #: 717-773-0185			Quote #: 219948A			<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td colspan="12" style="text-align:center;">Remarks</td> </tr> <tr> <td colspan="12" style="text-align:center;">Monthly Compliance</td> </tr> <tr> <td colspan="12"> </td> </tr> </table>						Remarks												Monthly Compliance																																																	
Remarks																																																																									
Monthly Compliance																																																																									
State where samples were collected: PA			For Compliance: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td colspan="12" style="text-align:center;">Sample Identification</td> </tr> <tr> <td colspan="2" style="text-align:center;">Collection</td> <td rowspan="2" style="text-align:center;">Grab</td> <td rowspan="2" style="text-align:center;">Composite</td> <td rowspan="2" style="text-align:center;">Soil <input type="checkbox"/> Sediment</td> <td rowspan="2" style="text-align:center;">Water <input type="checkbox"/> Potable <input type="checkbox"/> NPDES</td> <td rowspan="2" style="text-align:center;">Other: GAC Filtered Water <input type="checkbox"/></td> <td rowspan="2" style="text-align:center;">Total # of Containers</td> <td rowspan="2" style="text-align:center;">PFAS (14) 537 v 1.1</td> <td colspan="3" rowspan="2"> </td> <td colspan="3" rowspan="2"> </td> </tr> <tr> <td style="text-align:center;">Date</td> <td style="text-align:center;">Time</td> </tr> </table>						Sample Identification												Collection		Grab	Composite	Soil <input type="checkbox"/> Sediment	Water <input type="checkbox"/> Potable <input type="checkbox"/> NPDES	Other: GAC Filtered Water <input type="checkbox"/>	Total # of Containers	PFAS (14) 537 v 1.1							Date	Time																																	
Sample Identification																																																																									
Collection		Grab	Composite	Soil <input type="checkbox"/> Sediment	Water <input type="checkbox"/> Potable <input type="checkbox"/> NPDES	Other: GAC Filtered Water <input type="checkbox"/>	Total # of Containers	PFAS (14) 537 v 1.1																																																																	
Date	Time																																																																								
002 Coppersmith Well				5/13/21 0935		X		X		2		X																																																													
FB - Coppersmith Well				5/13/21 0935						2		X																																																													
003 DuPont Well				5/13/21 1010		X		X		2		X																																																													
FB - DuPont Well				5/13/21 1010						2		X																																																													
302s DuPont Between Lead and Lag				5/13/21 1000		X		X		2		X																																																													
FB - DuPont Between Lead and Lag				5/13/21 1000						2		X																																																													
302s DuPont After Lag				5/13/21 1005		X		X		2		X																																																													
FB - DuPont After Lag				5/13/21 1005						2		X																																																													
EP 102 DuPont				5/13/21 0955		X		X		2		X																																																													
FB - EP 102 DuPont				5/13/21 0955						2		X																																																													
Turnaround Time Requested (TAT) (please check):				Standard <input checked="" type="checkbox"/> Rush <input type="checkbox"/>		Relinquished by:		Date		Time		Received by:		Date		Time																																																									
(Rush TAT is subject to laboratory approval and surcharges.)						Penny Bumbarger		5/14/21		1021		Gabe Dieck		5/14/21		1021																																																									
Date results are needed:						Relinquished by:		Date		Time		Received by:		Date		Time																																																									
Rush results requested by (please check):				E-Mail <input checked="" type="checkbox"/> Phone <input type="checkbox"/>		Gabe Dieck		5/14/21		1121																																																															
E-mail Address: penny.bumbarger@suez.com						Relinquished by:		Date		Time		Received by:		Date		Time																																																									
Phone: 717-773-0185																																																																									
Data Package Options (please check if required)						Relinquished by:		Date		Time		Received by:		Date		Time																																																									
Type I (Validation/non-CLP) <input type="checkbox"/>		MA MCP <input type="checkbox"/>																																																																							
Type III (Reduced non-CLP) <input type="checkbox"/>		CT RCP <input type="checkbox"/>																																																																							
Type VI (Raw Data Only) <input type="checkbox"/>		TX TRRP-13 <input type="checkbox"/>																																																																							
NJ DKQP <input type="checkbox"/>		NYSDEC Category <input type="checkbox"/> A or <input type="checkbox"/> B				Relinquished by Commercial Carrier:																																																																			
EDD Required? Yes <input type="checkbox"/> No <input type="checkbox"/>				If yes, format: _____		UPS _____ FedEx _____ Other _____						Temperature upon receipt		-0.3°C																																																											

ES
11. 5/14/21 12:00 PM

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

Environmental Analysis Request/Chain of Custody



Lancaster Laboratories
Environmental

Acct. # 44297 Group # _____

Sample # _____

Client: SUEZ WATER PA		Matrix		Analyses Requested								For Lab Use Only					
Project Name: Newberry System		Site ID #:		Preservation and Filtration Codes O								SF #: _____					
Project Manager: Elizabeth Zanar		P.O. #:										<input type="checkbox"/> Tissue <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Surface		SCR #: _____			
Sampler: Penny Bumbarger		PWSID #: 7670061		<input type="checkbox"/> Sediment <input type="checkbox"/> Potable <input type="checkbox"/> NPDES		<input type="checkbox"/> Water <input type="checkbox"/> NPDES		<input type="checkbox"/> Other: GAC Filtered Water		Preservation Codes H = HCl T = Thiosulfate N = HNO ₃ B = NaOH S = H ₂ SO ₄ P = H ₃ PO ₄ F = Field Filtered O = Other							
Phone #: 717-773-0185		Quote #: 219948A		<input type="checkbox"/> Soil <input type="checkbox"/> Water		<input type="checkbox"/> Other: GAC Filtered Water		Total # of Containers PFAS (14) 537 v 1.1		Remarks							
State where samples were collected: PA		For Compliance: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		<input type="checkbox"/> Composite		<input type="checkbox"/> Grab		Date Time Grab Composite		Monthly Compliance							
Sample Identification		Collection		Soil		Water		Other: GAC Filtered Water		Total # of Containers		PFAS (14) 537 v 1.1					
001 Playground Well		5/13/21 1050				X				2		X					
FB - Playground Well		5/13/21 1050								2		X					
005 Conley Well		5/13/21 1055				X				2		X					
FB - Conley Well		5/13/21 1055								2		X					
301s Conley Between Lead and Lag		5/13/21 1045						X		2		X					
FB - Conley Between Lead and Lag		5/13/21 1045								2		X					
301s Conley After Lag		5/13/21 1040						X		2		X					
FB - Conley After Lag		5/13/21 1040								2		X					
EP 101 Conley		5/13/21 1035						X		2		X					
FB - EP 101 Conley		5/13/21 1035								2		X					
Turnaround Time Requested (TAT) (please check):				Standard <input checked="" type="checkbox"/> Rush <input type="checkbox"/>		Relinquished by:		Date		Time		Received by:		Date		Time	
(Rush TAT is subject to laboratory approval and surcharges.)						Penny Bumbarger		5/14/21		1021		Gina Deod		5/14/21		1021	
Date results are needed:						Relinquished by:		Date		Time		Received by:		Date		Time	
Rush results requested by (please check):				E-Mail <input checked="" type="checkbox"/> Phone <input type="checkbox"/>		Gina Deod		5/14/21		1121							
E-mail Address: penny.bumbarger@suez.com						Relinquished by:		Date		Time		Received by:		Date		Time	
Phone: 717-773-0185						Relinquished by:		Date		Time		Received by:		Date		Time	
Data Package Options (please check if required)						Relinquished by:		Date		Time		Received by:		Date		Time	
Type I (Validation/non-CLP) <input type="checkbox"/>		MA MCP <input type="checkbox"/>		Relinquished by:		Date		Time		Received by:		Date		Time		Time	
Type III (Reduced non-CLP) <input type="checkbox"/>		CT RCP <input type="checkbox"/>		Relinquished by:		Date		Time		Received by:		Date		Time		Time	
Type VI (Raw Data Only) <input type="checkbox"/>		TX TRRP-13 <input type="checkbox"/>		Relinquished by:		Date		Time		Received by:		Date		Time		Time	
NJ DKQP <input type="checkbox"/>		NYSDEC Category <input type="checkbox"/> A or <input type="checkbox"/> B		Relinquished by Commercial Carrier:		Date		Time		Received by:		Date		Time		Time	
EDD Required? Yes <input type="checkbox"/> No <input type="checkbox"/>				If yes, format: _____		UPS _____ FedEx _____ Other _____		Date		Time		Received by:		Date		Time	
												Temperature upon receipt		5/14/21		1126	
																-0.3 °C	

Login Sample Receipt Checklist

Client: SUEZ Water Environmental Services Inc

Job Number: 410-39905-1

Login Number: 39905

List Source: Eurofins Lancaster Laboratories Env, LLC

List Number: 1

Creator: Sanchez, Melvin E

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable ($\leq 6^{\circ}\text{C}$, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temperature is acceptable ($\leq 6^{\circ}\text{C}$, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	N/A	
Is the Field Sampler's name present on COC?	True	
Sample Preservation Verified.	N/A	
Residual Chlorine Checked.	N/A	
Sample custody seals are intact.	N/A	

