From:	Wade, Colin
To:	Cherry, Timothy
Cc:	Mcclennen, Bonnie
Subject:	Trip Report: Boyertown Landfill HSCA Site - May 10, 2023
Date:	Wednesday, May 10, 2023 2:52:51 PM

Boyertown Landfill HSCA Site
Douglass Township, Montgomery County
M**ay 10, 2023:**

I arrived at the Site at 080 in order to oversee for the installation of point of entry treatment (POET) systems at two homes with exceedances of PFOA. I met Tetra Tech (N. Debic) and Sharp Water Culligan. We started at 15 Diehl, and Culligan installed two carbon filters, a water meter, and a sediment filter in a crawl space (Photo 1). We collected water samples for PFAS (vi. USEPA Method 537.1) pre-POET system, mid-POET system, and from the kitchen faucet to confirm that POET system was removing PFOA to below its Maximum Contaminant Level.

Photo 1.) 15 Diehl Drive POET System

We then proceed at 1000 to 165 Gilbertsville Road and installed the POET system of the same components there without issue (Photo 2).

Photo 2.) 165 Gilbertsville POET System

We collected the confirmatory samples, and I left the Site at 1300. The confirmatory samples will be analyzed by ALS Group USA, Corp, and results are expected within a month.

-Colin

Colin R. Wade (he/him/his)| Environmental Protection Specialist
Department of Environmental Protection | Southeast Regional Office
2 E. Main Street | Norristown, PA 19401
Phone: 484.250.5722 | Fax: 484.250.5961
www.dep.pa.gov

PRIVILEGED AND CONFIDENTIAL COMMUNICATION
The information transmitted is intended only for the person or entity to whom it is addressed and may contain confidential and/or privileged material. Any use of this information other than by the intended recipient is prohibited. If you receive this message in error, please send a

reply e-mail to the sender and delete the material from any and all computers. Unintended transmissions shall not constitute waiver of the attorney-client or any other privilege.