



December 14, 2015

Ailene Batoon  
Tetra Tech, Inc.  
285 Ellicott Street  
Buffalo, NY 14203

RE: Sunoco Pipeline L.P. – Pennsylvania Pipeline Project  
Floodplain/Stormwater Management Program Consistency Request  
PN: WNT-15-202

Dear Ms. Batoon:

On behalf of West Nantmeal Township, we have completed a review of the Consistency Request letter dated November 18, 2015 along with the accompanying Location Maps and Site Maps submitted by Tetra Tech on behalf of Sunoco Pipeline L.P. requesting our acknowledgment of consistency with the Township Floodplain Management and Stormwater Management Programs.

We offer the following comments for your consideration:

- 1) We find the presented design to be in general conformance with the West Nantmeal Township Zoning Ordinance for the Flood Hazard Overlay District (Article 5, Section 502).
- 2) The proposed pipeline will incur  $\geq 5,000$  square feet of proposed earth disturbance, and is subject to the provisions of the Stormwater Ordinance (Ordinance No. 113-2013, Table 106.1). Please submit an application for a Stormwater Management Permit with the required information as specified in the *Stormwater Management Application Package* demonstrating the pipeline project's compliance with the provisions of the West Nantmeal Stormwater Management Ordinance, specifically the Erosion and Sediment Control requirements.

Should you have any questions or concerns, please do not hesitate to contact me at 610-705-4500.

Very truly yours,  
CEDARVILLE Engineering Group, LLC

April M. Barkasi, P.E.  
Township Engineer

cc: Gary C. Elston, Chairman, West Nantmeal Township Board of Supervisors  
Susan L. Ward, Secretary/Treasurer, West Nantmeal Township