

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer																		
Unknown	Unknown		Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	20	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.27 J		
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0096	0.27 J			
			Pressure Tank	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	2.4	
				POET- Influent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/17/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/09/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/10/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET- Midfluent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET- Effluent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			~300	Unknown	Post Holding Tank #1 Post Holding Tank #2 Laundry Room Sink	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
						02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	0.35 J	
						04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
					POET-Influent	05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
						06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
						08/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
					POET-Midfluent	05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
06/24/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/21/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	05/01/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.96 J			
	06/24/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J			
	08/21/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown	Influent	04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Midfluent	04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J			
		Effluent	04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
500	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	3.4			
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	1.8				
		Kitchen Sink	06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4			
			03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J			
		POET-Influent	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5			
			POET-Midfluent	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
POET-Effluent	07/22/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J				
	255	240	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
02/28/2025				ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	0.17 J				
POET - Influent			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/20/2025	ND<0.19	15	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET - Midfluent			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET - Effluent			03/15/2025	ND<0.19	ND<0.19	ND<0.13	0.65 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.82				
		POET - Influent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J			
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J			
		POET - Midfluent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J			
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Effluent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J			
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer																		
~200	133	Kitchen Sink Pressure Tank (Basement) Kitchen	02/04/2025	ND<0.5	1,000	700	10,000	20	840	100	130	130	5	0.05	5			
			02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.13 J		
			03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0094	0.45 J		
			POET - Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET - Effluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Unknown	Unknown	Outside Spigot	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.11 J	ND<0.0094	0.19 J
					02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	0.19 J	ND<0.0094	0.36 J
					03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
					05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
					08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
		Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
					03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
POET - Influent	03/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J		
	05/03/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
	05/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
	08/07/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET - Midfluent	05/03/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/07/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET - Effluent	03/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/03/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
	08/07/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
60-80	Unknown	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.42 J			
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J			
		POET - Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Midfluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/06/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
POET - Effluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Kitchen Sink	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12			
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
		POET-Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		08/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		08/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13												

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
	DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	Unknown	Second Kitchen	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	0.17 J	
			Pressure Tank (Influent)	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.0	
			POET - Midfluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Smaller Kitchen Sink (Effluent)	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink (Effluent)	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	06/02/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/04/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	02/11/2025	ND<0.50		ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12			
	02/27/2025	ND<0.10		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
	03/19/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/14/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	POET-Influent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	POET-Midfluent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/08/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
09/02/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
160	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
		Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Midfluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Unknown	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
		POET-Influent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
08/05/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Outside Spigot	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J		
		POET-Influent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
Unknown	Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				02/21/2025	0.52	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	0.31 J	0.46 J	ND<0.10	ND<0.0094	ND<0.12		
			POET-Influent		02/28/2025	0.18 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
					03/10/2025	0.42 J	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.41 J	0.30 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/07/2025	0.23 J	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					08/27/2025	0.69	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	0.30 J	0.34 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
					03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
					03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
146-160	100	Outside Spigot	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-		
			01/28/2025	0.92	6.6	ND<0.50	100	ND<0.50	1.0	84	47	23	ND<0.50	ND<0.0094	0.017 J			
		POET-Influent		02/19/2025	0.13 J	0.27 J	0.72	29	ND<0.10	1.7	47	2.1	1.3	ND<0.10	ND<0.0094	ND<0.12		
				02/24/2025	ND<0.10	ND<0.10	0.44 J	13	ND<0.10	0.94	30	0.32 J	0.22 J	ND<0.10	ND<0.0094	0.13 J		
				03/20/2025	ND<0.19	ND<0.19	0.29 J	4.2 J	ND<0.13	1.3	19	2.8	1.4	ND<0.15	ND<0.005	ND<0.3		
				03/27/2025	ND<0.19	ND<0.19	0.18 J	4.4	ND<0.13	0.98	18	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/10/2025	ND<0.19	ND<0.19	0.13 J	8.2	ND<0.13	0.70	12	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	6.5	ND<0.13	0.52	11	ND<0.13	ND<0.15	ND<0.15	-	-		
				05/07/2025	0.21 J	ND<0.19	ND<0.13	5.1	ND<0.13	0.53	11	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/01/2025	ND<0.19	ND<0.19	ND<0.13	1.5	ND<0.13	ND<0.13	2.1	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/18/2025	ND<0.19	ND<0.19	ND<0.13	0.61	ND<0.13	ND<0.13	0.66	0.21 J	0.19 J	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent		02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	ND<0.12
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	-	-		
				05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
POET-Effluent		02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
		02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12		
		03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.45 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.42 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.43 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	-	-				
		05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Kitchen Sink	05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
NA	NA	Bottom of Saltwater Pool	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~100	Unknown	Bathroom Sink	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-		
		Upstairs Bathroom Sink	01/30/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent		04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent		04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent		04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	06/30/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/12/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (µg/L) 5	1,2 Dibromo- ethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	Unknown	Unknown	Utility Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			Kitchen Sink	02/24/2025	0.63	ND<0.10	ND<0.10	0.63	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			POET - Influent	03/31/2025	28	25	0.64	250	ND<0.13	0.17 J	48	130	70	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	17	2.0	0.21 J	62	ND<0.13	1.4	50	2.5	1.0	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	14	0.48 J	ND<0.13	42	ND<0.13	0.74	34	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Midfluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~100	Unknown	Kitchen Sink	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			Pressure Tank	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.47 J
			POET-Influent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.15 J
			POET-Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
				04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Basement Sink	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~182	180	Kitchen Sink	01/23/2025	12	ND<0.50	ND<0.50	0.29	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0091	ND<0.12
			Post-Treatment	01/30/2025	12	ND<0.50	ND<0.50	0.19	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J
				02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			POET-Influent	02/25/2025	14	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.0	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/25/2025	8.8	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	1.2	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/06/2025	3.6	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/25/2025	1.3	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.89	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/22/2025	0.42 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.42 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pool Water	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)			
DEP MSCs for a Residential, Used Aquifer	Unknown	Unknown	Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12			
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12				
				Laundry Room Sink	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.10	ND<0.13	ND<0.15	ND<0.15	ND<0.0095	ND<0.12		
					04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				POET-Influent	06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				POET-Midfluent	08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				POET-Effluent	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
					08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				503	340	Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
							03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						POET-Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
							05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	07/29/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/04/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	POET-Midfluent	03/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		05/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		07/29/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		03/04/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	POET-Effluent	03/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		05/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		07/29/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	300	200	Bladder Tank Pressure Tank			01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.16 J		
						02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13										

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer																	
					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
~220	Unknown	Bladder Tank Basement (Influent)	01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.63	
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J		
		POET-Influent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Kitchen Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
07/11/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
185-250	Unknown	Kitchen Sink	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
		Kitchen Sink (First Floor)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
		POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
			08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
345	325	Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.23 J		
		Utility Sink (Effluent)	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2		
		POET-Influent		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Kitchen Sink (Effluent)	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Basement Sink (Effluent)	08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
200-220	~180	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Pressure Tank (Influent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	1.5	
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.5		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4		
		08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.00			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer																	
					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
180	Unknown		Front Spigot	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.28 J	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J	
			POET-Influent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Midfluent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					POET-Effluent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
	Unknown	Unknown	Pressure Tank (Influent)	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.93
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	5.3	
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.6	
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.90	
				05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.2	
Laundry Room Sink			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.42 J		
			POET-Midfluent	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
05/23/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Basement Sink (Effluent)			04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5		
			05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J		
	07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.0				
450	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown	Pressure Tank	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.41 J	
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET - Influent	06/05/2025	ND<0.19	1.7	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET - Midfluent	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET - Effluent	08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.46 J		
			Pressure Tank	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.30 J	
				POET-Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/11/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		05/12/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
03/17/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
Unknown	180		Bladder Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J		
		POET-Influent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.22 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.14 J	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.24 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.16 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Unknown	Unknown		Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.59	
						02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.6
				POET-Influent		03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.39 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	05/13/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	07/16/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/27/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/29/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
295	Unknown				Bladder Tank	01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
					Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
		POET-Influent		02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent		09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent		08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.6	
				09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05			
	~303	~240-252	Bladder Tank	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	1.7		
			POET -Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	3.1
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.15	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET -Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	0.13 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~600-700	~400	Bladder Tank	01/23/2025	15	6.7	2.7	49	ND<0.50	1.3	19	48	39	ND<0.50	ND<0.0092	5.2		
			Kitchen Sink	01/31/2025	8.9	3.7	1.7	25	ND<0.50	0.94	7.3	29	22	ND<0.50	ND<0.0093	0.23 J		
			POET-Influent	02/15/2025	25	6.7	4.1	44	0.12 J	1.9	20	49	34	ND<0.50	ND<0.0095	ND<0.12		
				02/24/2025	28	4.6	4.6	42	0.14 J	2.1	22	55	41	ND<0.50	ND<0.0094	0.15 J		
				03/24/2025	15	2.3	3.8	19	ND<0.13	2.0	18	77	48	0.40 J	ND<0.005	ND<0.3		
				05/19/2025	5.6	1.4	2.3	13	ND<0.13	1.5	14	68	40	ND<0.15	ND<0.005	ND<0.3		
				07/17/2025	7.0	1.4	2.1	14	ND<0.13	1.3	13	54	30	ND<0.15	ND<0.005	ND<0.3		
				08/13/2025	15	2.2	2.7	13	ND<0.13	1.3	14	46	23	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12		
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	0.17 J		
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	ND<0.12		
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	07/17/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	08/13/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	400	230	Bladder Tank	01/23/2025	20	51	32	640	ND<0.50	7.6	120	310	120	ND<0.50	ND<0.0093	0.23 J		
			Post Treatment	02/07/2025	0.35 J	2.3	1.2	46	ND<0.50	0.26 J	29	19	11	ND<0.50	ND<0.0094	0.75		
				This well was taken out of service on February 17, 2025														
	420-450	300-430	Bladder Tank	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.4		
			Basement	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J		
			POET-Influent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer																		
Possibly 300	Unknown		Kitchen Sink	01/24/2025	5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			POET-Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	0.24 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			550-585	540 or 550	Kitchen Sink	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
						02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.22 J	
					POET-Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					POET-Midfluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
04/07/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
05/05/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
06/09/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	08/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	03/10/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/07/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/05/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	06/09/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
550																		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethyl-benzene	1,3,5-Trimethyl-benzene	1,2-Dichloro-ethane	1,2-Dibromo-ethane	Dissolved Lead	
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	
DEP MSCs for a Residential, Used Aquifer																	
~85-86	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J	
			02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J		
			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13				ND<0.005	ND<0.3	
		Pressure Tank (Influent).	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.25 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			06/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
		POET-Midfluent	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Kitchen Sink (Effluent)	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		~80	Unknown	Pressure Tank	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				POET-Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
04/02/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
04/25/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent	07/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	03/04/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/02/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	04/25/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	07/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
03/04/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
04/02/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
04/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/14/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
125	125	Pressure Tank	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	41		
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.9		
		Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
~200-210	~180	Pressure Tank (Influent)	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.66		
			02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.95		
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J		
		POET-Influent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
Kitchen Sink (Effluent)	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.55				
	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)			
DEP MSCs for a Residential, Used Aquifer																				
Unknown	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12			
			POET-Influent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
			POET-Midfluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
			POET-Effluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3				
			~120-150	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
					POET-Influent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
						03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3		
						04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3		
						06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3		
						08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3		
POET-Midfluent	03/21/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
	04/22/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
	06/03/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
	08/14/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
POET-Effluent	02/21/2025	ND<0.10			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12				
	03/21/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
	04/22/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0005	ND<0.3					
	06/03/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.1													

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2 Dibromo- ethane	Dissolved Lead		
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	
DEP MSCs for a Residential, Used Aquifer																		
600-705	600	Bathroom Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	2.1	
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J	
		Pressure Tank (Influent)	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
03/17/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Influent	04/17/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/19/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	07/23/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent	04/17/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/19/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	07/23/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
POET-Effluent	04/17/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/19/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	07/23/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown			Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
					02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.22 J
				POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
~150	125	Pressure Tank (Influent)	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/27/2025	ND<0.19	0.66	0.28 J	0.66 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	2.0	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Unknown	Unknown	Kitchen Sink	01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.12
					Pressure Tank (Influent)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
				POET-Influent		07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
					POET-Midfluent	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
				07/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Effluent	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
300-330	>180			Kitchen Sink Outside Spigot	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
					03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Influent	03/20/2025	ND<0.19	58	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					03/26/2025	ND<0.19	1.7	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		04/21/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/22/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		07/16/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		09/11/2025	ND<0.19														

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer																			
Unknown	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.13 J		
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J	
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			600	334	Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.17 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.31 J
						02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
					POET - Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005
03/26/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	0.15 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
04/25/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
05/28/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.4 J		
07/21/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET - Midfluent	02/19/2025	ND<0.10			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
	03/10/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	03/26/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
	~150-200	~150-200	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.16 J	ND<0.50	0.23 J	1.1	0.71	ND<0.50	ND<0.0094	ND<0.12		
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.27 J	ND<0.10	ND<0.20	1.2	0.69	ND<0.10	ND<0.0095	ND<0.12		
			POET-Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.18 J	ND<0.13	ND<0.14	0.27 J	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Effluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/14/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/18/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	~350	230	Bathroom Sink	09/26/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-	
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			Pressure Tank (Influent)	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.15	ND<0.10	ND<0.0094	0.16 J
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Influent	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
03/18/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
04/14/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
05/12/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	<250	Outside Spigot	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Kitchen Sink (post charcoal treatment)	09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1		
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			POET-Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		03/31/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/27/2025		0.21 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
03/04/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
03/31/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
400	<350	Outside Spigot Outside Spigot (Pre-Treatment) Kitchen Sink (Post-Treatment)	09/25/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
			01/31/2025	39	7.9	49	230	0.2	18	160	ND<0.50	180	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63	
			02/14/2025	92	80	41	310	0.33 J	13	110	280	120	ND<0.10	ND<0.0095	ND<0.12		
			02/24/2025	58	9.4	ND<0.10	250	0.42 J	ND<0.10	140	450	200	ND<0.10	ND<0.0094	ND<0.12		
			03/21/2025	150	36	17	390	0.30 J	9.8	120	480	210	4.3	ND<0.005	ND<0.3		
			04/23/2025	39	5.5	7.5	200	0.64	3.6	82	240	98	ND<0.15	ND<0.005	ND<0.3		
			05/19/2025	8.0	1.8	5.8	84	ND<0.13	3.6	110	280	160	ND<0.15	ND<0.005	ND<0.3		
			06/19/2025	32	19	5.7	120	0.39 J	1.3	28	95	86	0.76	ND<0.005	ND<0.3		
			07/03/2025	13	310	10	280	ND<0.13	3.2	34	190	150	0.16 J	ND<0.005	ND<0.3		
			07/24/2025	0.98	11	3.4	80	0.51	1.2	20	72	99	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025	ND<0.19	ND<0.19	0.24 J	2.7	ND<0.13	0.21 J	2.7	14	68	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.17 J	0.17 J	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent - Upstairs Bathroom	07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	13.6		
300	200	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.17 J	
		Pressure Tank (Influent)	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12		
			03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
400	380-390	Pressure Tank (Influent)	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52		
			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Kitchen Sink (Effluent)	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15</					

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2-Dibromo- ethane	Dissolved Lead			
	(μg/L)	(μg/L)			(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)			
DEP MSCs for a Residential, Used Aquifer																			
	+340	340	Kitchen Sink	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.20	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12			
			POET-Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				POET-Midfluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			03/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/30/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/18/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/02/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.5 J		
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095
			02/27/2025			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.13 J
			POET-Influent			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	06/06/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/06/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Midfluent	03/14/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		04/10/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/06/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	150-200	150	Utility Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Pressure Tank (Influent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.78
			Utility Sink (Effluent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.36 J
			POET-Influent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	147	~115	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.18 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			POET-Influent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.3 J
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			POET-Midfluent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pre-Carbon Treatment	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52
			Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
			Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Irrigation Well	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	6.5
	Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	430	400	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Kitchen Sink (First Floor)	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~600	Unknown	Pressure Tank	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Spigot in Basement	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	Unknown	Kitchen Sink *bypassed carbon	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0
			Influent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Backyard Spigot	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.14 J
			Outside Spigot (next to front door)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Influent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.6
			POET - Midfluent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	570-700	700	Pressure Tank	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	5.6
			Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank (Influent)	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	400	Unknown	Kitchen Sink (Effluent)	05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Utility Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.33 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.54
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethyl-benzene	1,3,5-Trimethyl-benzene	1,2-Dichloro-ethane	1,2-Dibromo-ethane	Dissolved Lead		
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)		
DEP MSCs for a Residential, Used Aquifer																		
340-400	340	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Influent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Midfluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Effluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		137	120	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				POET-Influent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
05/16/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/01/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Midfluent	03/22/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/16/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	03/22/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/16/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~350	Unknown	Pressure Tank	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	24		
		POET-Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7			
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		POET-Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/31/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
Unknown	Unknown	Bathroom Sink Next to Kitchen	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
		02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	0.16 J				
		04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
105	75	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J		
		03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13									

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2 Dibromo- ethane	Dissolved Lead
	(μg/L)	(μg/L)			(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	
DEP MSCs for a Residential, Used Aquifer																
~65-80	Unknown	Bathroom Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.45 J	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J	
			POET-Influent	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J	
		08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J			
		POET-Midfluent	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Effluent		03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		08/08/2025	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	ND<0.3			
		655	400	Pressure Tank	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
	POET-Influent			05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	POET-Midfluent			05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	POET-Effluent			05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300	100-150	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094
02/27/2025				ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
POET-Influent			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
07/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
07/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Laundry Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J	
		07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
		Kitchen Sink	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~75-90	70-90	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND							

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2-Dibromo- ethane	Dissolved Lead
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
DEP MSCs for a Residential, Used Aquifer																
140	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.0
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.9
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	2.1
		POET-Influent	05/10/2025	ND<0.19	ND<0.19	0.18 J	0.77	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.5 J
			07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.7
		POET-Midfluent	05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent	05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
~101	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Influent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.5 J
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
~212	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
		Pressure Tank	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
		POET - Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET - Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET - Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
200-400	250-350	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
		Bladder Tank	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.86
		Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.957 J
		POET-Influent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent	03/10/2025	ND<0.19	0.29 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/25/2025													

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer						5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
193	180	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	ND<0.12	
		Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.0
			09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	5.8	
		POET-Influent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	6.7	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	3.1		
			06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	3.0		
		POET-Midfluent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.3		
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Kitchen Sink (Effluent)	09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			POET-Effluent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	4.5	
		04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.7 J		
		06/03/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
09/05/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.6 J				
~135	~135	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.23 J		
		Basement (Influent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
		POET-Influent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Basement (Midfluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/08/2025	ND<0.19	ND<0.19	ND<0.13													

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer																		
500	170	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	17.6		
			05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	12.0		
		08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	4.9			
		03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
		680-740	150	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
03/13/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3		
04/16/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3		
05/20/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3		
08/11/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
03/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
04/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
05/20/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
08/11/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
03/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
04/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
05/20/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
08/11/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
03/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
04/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
05/20/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.05	ND<0.3			
08/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<							

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (µg/L) 5	1,2 Dibromo- ethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	223	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.65
			Bladder Tank (Basement)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			POET-Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Bladder Tank (Basement)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank (Influent)	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~ 200	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Bladder Tank (Basement)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			POET-Influent	03/19/2025	ND<0.19	0.23 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~125-180	Unknown	Outside Spigot - Influent	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.3
			Bladder Tank (Basement)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			Back Yard Spigot	04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			Outside Rear Spigot	07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
			Kitchen Sink - Effluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)			
Sample Address																			
DEP MSCs for a Residential, Used Aquifer																			
Unknown	Unknown	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			Pre -Water Softener	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	0.23 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank (Influent) - Main Well (Well 1)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank (Influent) - Back-up Well (Well 2, Old Well)	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent - Main Well (Well 1, New Well)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent - Back-up Well (Well 2, Old Well)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent (Combined)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent - Main Well (Well 1, New Well)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Effluent - Back-up Well (Well 2, Old Well)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.60		
		Outside Spigot	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Influent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		07/16/2025		ND<0.19	ND<0.19	ND<0.1													

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
	~35	Unknown	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~140	Unknown	Pressure Tank	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4	
				POET-Influent	04/29/2025	ND<0.19	ND<0.19	0.19 J	0.70	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Midfluent	04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Effluent	04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					POET-Influent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
					09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Midfluent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Effluent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J	
				03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10										

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (µg/L) 5	1,2 Dibromo- ethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pre-Treatment Pressure Tank Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	140-149	125-129	Spigot	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.001	1.6
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	149	147	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Bathroom Sink	07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.8
	Unknown	Unknown	Kitchen Sink	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
	150-180	137-150	Outside Spigot - Back Deck	02/27/2025	ND<0.10	0.12 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.40 J
			Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~150-180	~150-180	Outside Spigot Adjacent to Outside Spigot Under Deck	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.50 J
				03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~80	~80-100	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	200 100	Unknown Unknown	Kennel Main House	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	100-150	Jet Pump	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.23 J
	500-600	360-400	Kitchen Sink	02/07/2025	0.18 J	120	ND<0.50	ND<0.50	ND<0.50	0.12 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/18/2025	0.14 J	80	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
				03/25/2025	ND<0.19	40	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	13	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/25/2025	ND<0.19	4.1	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	240	200	Outside Spigot	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	~25	Jet Pump	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	26'9"	20	Basement Bathroom Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	90-92	60-92	Pressure Tank (Influent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/24/2025	ND<0.19	ND<0.19	0.17 J	0.50	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naphthalene (µg/L) 100	1,2,4-Trimethylbenzene (µg/L) 130	1,3,5-Trimethylbenzene (µg/L) 130	1,2-Dichloroethane (µg/L) 5	1,2 Dibromoethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	~40	32-40	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.22 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Basement Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	45-50	Unknown	Laundry Room Utility Sink	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Kitchen Sink	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Island Sink	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~240	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.7
			Influent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	115	100	Pre-Treatment Pressure Tank (Influent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0098	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Basement Sink (Effluent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (First Floor)	05/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	NA	NA	Northwest Side of Pond	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Well (Outfall Pipe)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Bathroom Sink (First Floor)	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	80-100	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~150	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~140	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (µg/L) 5	1,2 Dibromo- ethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	Unknown	Unknown	Kitchen Sink (First Floor)	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	280	270	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Influent (Carbon Filter)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.8
			POET-Influent	05/08/2025	ND<0.19	ND<0.19	0.21 J	0.87 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			POET-Effluent	05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	06/24/2025	ND<0.19	ND<0.19	0.22 J	0.65	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~300	~297	POET-Effluent	06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Influent (Pressure Tank)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent (Sink)	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	500	480	Kitchen Sink	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	600	500	Kitchen Sink	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink (First Floor)	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	460	40	POET-Effluent	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naph- thalene (µg/L) 100	1,2,4-Trimethyl- benzene (µg/L) 130	1,3,5-Trimethyl- benzene (µg/L) 130	1,2-Dichloro- ethane (µg/L) 5	1,2 Dibromo- ethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	65	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	4.2
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	9.7
			POET - Influent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Midfluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~80	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~200	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	85-88	~70	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	310	~240	Basement Spigot	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	-	-	Pressure Tank	09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	8.5
			Kitchen Sink	09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
	Unknown	Unknown	Influent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.2
			Kitchen Sink (Effluent)	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
	~ 90	Unknown	Kitchen Sink	02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.41 J
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	123	Unknown	Office Downstairs Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	90	~90	Basement (Pre-Treatment)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink (Effluent)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.50 J
			Basement Utility Sink (Effluent)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	26	26	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	240	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	200	~75	Untreated hose in closet	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.30 J	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.6
			Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					0.44 J	1.000	700	10.000	20	840	100	130	130	5	0.05	5
265	210	Pressure Tank	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.21 J
			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
		Utility Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.13	ND<0.15	ND<0.15	ND<0.005
		04/23/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		05/19/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		125-165	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095
03/05/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Influent	03/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Midfluent			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Effluent				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~30	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
03/06/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
03/28/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Influent			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Effluent	04/22/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
03/08/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
120	105	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		Effluent		03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Unknown	Unknown		Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
		03/06/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Midfluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Effluent	04/15/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Unknown	Unknown	Outside Spigot	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Utility Sink	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown		Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.32 J
		03/05/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown		Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
		03/07/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
		POET-Influent	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	05/10/2025	ND<0.19	ND<0.19	0.55	2.5	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent		05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	~80-85	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				03/03/2025	ND<0.19	14	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	100	~95-100	Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.51 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.48 J
				03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown		05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			POET-Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J
			POET-Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	62-64	Unknown		05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5
			Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	350	Unknown	Midfluent	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.16 J
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Unknown	Unknown	Kitchen Sink	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
			05/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
436-470	Unknown	POET-Midfluent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink	02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
		Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12	
Unknown	Unknown		03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Midfluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Effluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Pressure Tank	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Bathroom Sink	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J	
500	460															
		Influent	05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Midfluent	05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Effluent	05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown															
		Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
		Basement Bathroom / Laundry Room Sink	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.15 J	
400	340	Basement Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Downstairs Sink	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Influent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.20 J	
		Influent (Carbon Filter)	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005</		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)
			DEP MSCs for a Residential, Used Aquifer		5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	500-750	Unknown	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
			Pressure Tank	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
	500-750	Unknown	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
			Pressure Tank	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
	200-1,500	250-750	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Top Spigot	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Sink Near Kitchen	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
	91	60	Utility Sink (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
			Laundry Room Sink	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Laundry Sink	04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
	Unknown	Unknown	Kitchen Sink	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	140	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink (System Bypassed)	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Outside Spigot (Influent)	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	Unknown	Unknown	Pressure Tank	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.52
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
	Unknown	Unknown	Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.4
	Unknown	Unknown	Kitchen Sink (Effluent)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	250	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.3
			Laundry Room Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Basement Sink	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pre-Treatment Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.3	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Sink - Post Treatment (Non-RO Treatment)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	3.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2
			Post-Treatment - RO Spigot at	02/20/2025	ND<0.10	ND<0.10	ND<0.10	0.24 J	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/28/2025	ND<0.19	16	ND<0.13	ND<0.19	2.9	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/25/2025	ND<0.19	1.9	ND<0.13	ND<0.19	2.8	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	0.37 J	ND<0.13	ND<0.19	3.5	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	600	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.40 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.39 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.42 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.36 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.18 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300	Unknown	Pre-Treatment (Pressure Tank)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Post-Treatment (Kitchen Sink)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.10 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Pressure Tank	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			After Water Softener	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	5.2

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L) 5	Toluene (µg/L) 1,000	Ethyl-benzene (µg/L) 700	Total Xylenes (µg/L) 10,000	MTBE (µg/L) 20	Isopropyl Benzene (µg/L) 840	Naphthalene (µg/L) 100	1,2,4-Trimethylbenzene (µg/L) 130	1,3,5-Trimethylbenzene (µg/L) 130	1,2-Dichloroethane (µg/L) 5	1,2 Dibromoethane (µg/L) 0.05	Dissolved Lead (µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
	Unknown	Unknown	Basement Bathroom Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Influent (Pressure Tank)	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J
			Effluent (Basement Bathroom)	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300+	~300	Outside Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
			POET - Influent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Midfluent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	700-720	340-350	Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Spigot	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			First Floor Kitchen Sink (Effluent)	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Influent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	400	POET - Midfluent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Outside Spigot (South Side of House)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	600 - 700	Unknown	Outside Spigot	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	0.3 J	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9
	Unknown	300	Spigot Near Blue Pressure	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.6
			POET-Influent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~290	Unknown	POET-Effluent	08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.014	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Influent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.5
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2
			POET - Midfluent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
~350	Unknown	Unknown	Pre-Treatment Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.34 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			310	280	Kitchen Sink (First Floor)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
						03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Unknown	Unknown	Spigot Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
						02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.16 J
			340	120	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
						03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
					Pressure Tank (Influent)	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1
						Basement Spigot (Effluent)	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
					04/04/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
					Unknown	Unknown	Pressure Tank Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10
			03/27/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Unknown	Unknown	Kitchen Sink	04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			~400-600	Unknown	Kitchen Sink	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095
			04/15/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
400	380	Basement Kitchen Sink	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.8		
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
400	380	Basement Bathroom Sink	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5		
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.3 J		
400	380	Kitchen Sink (Effluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Pre-Treatment	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
600	50-500	Pressure Tank (Influent)	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Bathroom Sink (Effluent)	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
280-400	260	Bathroom Sink (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
			04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
400	360	Pre-Treatment	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J			
Unknown	Unknown	Kitchen Sink Pressure Tank (Influent)	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J			
			Midfluent	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Unknown	Unknown	Kitchen Sink Island	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
400	380	Outside Spigot	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12			
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
500	480	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J			
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7			
		Bladder Tank	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.2			
			05/03															

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane	1,2 Dibromo-ethane	Dissolved Lead (µg/L)
	DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	600	500	Filtered Drinking Water Faucet Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	500	480	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	600	500	Pressure Tank (Influent)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
	650	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Basement Sink	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	265-360	260	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
			Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	300	260	Pressure Tank	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~700	240	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~300+	Unknown	Pressure Tank	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink (Effluent)	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Maybe 200	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Influent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
04/14/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
188	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14							

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
	DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	60	45	Pressure Tank	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	25	~25	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J	
	33	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	65	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
	57	48	Pressure Tank	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.5
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.8 J
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	45	40	Port closest to well in the basement	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2	
	35-50	Unknown	Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~150	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J	
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0	
	Unknown	Unknown	Upstairs Kitchen Sink	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
				05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J	
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J	
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
	Unknown	Unknown	Kitchen Sink	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J	
	450 or 650	Unknown	Kitchen Sink	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/23/2025	ND<0.												

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	1,2-Dichloroethane	1,2 Dibromoethane	Dissolved Lead
					(µg/L) 5	(µg/L) 1,000	(µg/L) 700	(µg/L) 10,000	(µg/L) 20	(µg/L) 840	(µg/L) 100	(µg/L) 130	(µg/L) 130	(µg/L) 5	(µg/L) 0.05	(µg/L) 5
DEP MSCs for a Residential, Used Aquifer																
530-935	Unknown	Spigot attached to Barn	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
305	Unknown	Backyard Spigot Attached to House Influent	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
280-300	300	Pressure Tank (Influent)	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	3.5
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.3	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.8	
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.5	
			06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4	
		Midfluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.052	3.0	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink (Effluent) Bar Sink (Effluent) Kitchen Sink (Effluent)	06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
425	Unknown	Pressure Tank Utility Sink (basement)	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET - Influent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Midfluent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15		ND<0.005
POET - Effluent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~20 - 28	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.43 J
			03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
155	Unknown	Kitchen Sink Kitchen Sink (First Floor)	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~140	Unknown	Outside Spigot Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~860-900	~40	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
450	~350-400	Utility Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.61	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J	
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
300	~270	Bathroom Sink Outside Spigot	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~700-800	Unknown	Outside Spigot - Warehouse	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.71	
		Outside Spigot - House	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J	
		Outside Spigot	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2	
Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~500-800	Unknown	Laundry Room Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	05/21/2025	ND<0.19	ND<0.19	0.21 J	0.73	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
POET-Effluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown	Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10									

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	~200	70	Pressure Tank Spigot Kitchen Sink	03/08/2025 04/08/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	0.8 J ND<0.3
	Unknown	Unknown	Kitchen Sink (non-RO) Laundry Room Sink	03/20/2025 04/15/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
	Unknown	Unknown	Garage Spigot	02/28/2025 04/14/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 0.24 J	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0095 ND<0.005	ND<0.12 ND<0.3
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025 05/06/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
	Unknown	Unknown	Bladder Tank	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.4
	Unknown	Unknown	Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Effluent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink (First Floor) Kitchen Sink	02/22/2025 03/18/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~60-90	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
	~70-90	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
	Unknown	460	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~300	Unknown	Kitchen Sink	02/22/2025 03/19/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/25/2025 03/18/2025 04/16/2025	ND<0.10 ND<0.19 ND<0.19	ND<0.10 ND<0.19 ND<0.19	ND<0.10 ND<0.13 ND<0.13	ND<0.10 ND<0.19 ND<0.19	ND<0.10 ND<0.13 ND<0.13	ND<0.10 ND<0.13 ND<0.14	ND<0.20 ND<0.14 ND<0.13	ND<0.10 ND<0.13 ND<0.13	ND<0.10 ND<0.15 ND<0.15	ND<0.10 ND<0.15 ND<0.15	ND<0.0094 ND<0.005 ND<0.005	0.16 J ND<0.3 ND<0.3
	~60-70	Unknown	Kitchen Sink	03/18/2025 04/16/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
	41	Unknown	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.18 J
	~70	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/20/2025 03/05/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/22/2025 02/22/2025	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.20 ND<0.20	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.0094 ND<0.0095	ND<0.12 ND<0.12
	300	Unknown	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	144	Unknown	Pressure Tank	02/19/2025 03/11/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0095 ND<0.005	ND<0.12 7.2
				02/21/2025 03/07/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0095 ND<0.005	0.39 J ND<0.3
	Unknown	Unknown	Kitchen Sink - (Cottage)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	120	100	Kitchen Sink	02/20/2025 03/31/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				03/12/2025 04/21/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
	270	260	Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	500	460-480	Kitchen Sink-1 Apartment (Effluent1)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
	460-480	400-445	Kitchen Sink-2 House (Effluent2)	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Basement (Influent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
			Pressure Tank (Influent)	03/27/2025	0.72	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.35 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2005	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	450	~440	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	270	270	Utility Sink in Garage Utility Sink in Garage	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.34 J
	Unknown	Unknown	Pressure Tank Kitchen Sink	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.017 J
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~100	Unknown	Kitchen Sink	07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.9
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	140	140	Pressure Tank	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	128	Unknown	Kitchen Sink (First Floor)	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	185	Unknown	Kitchen Sink	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~30-50	Unknown	Kitchen Sink (Effluent)	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300	Unknown	Pressure Tank Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~30	Unknown	Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.52
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	350	300	Kitchen Sink	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	15	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	200 Unknown	Unknown 300	Well 15	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Well 9	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	~90	Kitchen Sink	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Utility Sink (near Kitchen)	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Notes:
DEP = Pennsylvania Department of Environmental Protection
MSCs = Medium-Specific Concentrations per 25 Pa. Code Chapter 250
µg/L = Micrograms/Liter
ND<# = Not Detected (# is method detection limit)
NA = Not Available or Not Analyzed
MDL = Method Detection Limit
RL = Reporting Limit
PID = Photoionization Detector
ppm = Parts Per Million
J = Approximate value; result is < RL and ≥ MDL
* = See laboratory report for qualifiers
Bold = Exceeds the DEP MSC for a Used, Residential Aquifer < 2,500 mg/L total dissolved solids
Volatiles analyzed via EPA Method 524.2
EDB analyzed via EPA Method 8011 through 2/28/2025; samples collected beginning 3/1/2025 analyzed via EPA Method 504
Dissolved Lead analyzed via EPA Method 200.8