

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
255	240	POET - Influent	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J				
			POET - Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/20/2025	ND<0.19	15	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/31/2025	ND<0.19	0.58	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET - Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET - Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	0.65 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.82
					POET - Influent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
						08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
						10/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					POET - Midfluent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
						08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						10/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
POET - Effluent	06/09/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J			
	08/06/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/20/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~200	133	Kitchen Sink			02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.13 J	
		Pressure Tank			02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.45 J	
		Kitchen	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET - Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		04/09/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		06/17/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		08/12/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		10/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Effluent		04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Unknown	Unknown	Outside Spigot	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.11 J	ND<0.0094	0.19 J
						02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	0.19 J	ND<0.0094	0.36 J
		03/20/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		04/14/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	0.15 J	ND<0.005	0.4 J	
		05/07/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		06/13/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	0.41 J	ND<0.005	0.7 J	
		08/08/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
10/09/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	0.41 J	ND<0.005	0.9 J			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05		
Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J	
			03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
		POET - Influent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J		
			05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
			05/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			08/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET - Midfluent	05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET - Effluent	10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			05/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		60-80	Unknown	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.42 J
					02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J
				POET - Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
04/26/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/06/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
08/18/2025	ND<0.19				ND<0.19	ND<0.13											

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2-Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	Unknown	Second Kitchen	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
			Pressure Tank (Influent)	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.2
			POET-Influent	08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.0
			POET - Midfluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Smaller Kitchen Sink	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			POET-Influent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	160	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	1,2-Dichloroethane	1,2-Dibromoethane	Dissolved Lead			
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)			
DEP MSCs for a Residential, Used Aquifer																			
Unknown	Unknown	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
			POET-Influent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Midfluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Effluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	8.1			
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Unknown	Unknown	Unknown	Outside Spigot	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
							02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
						03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
						03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J	
POET-Influent	04/11/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/09/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/02/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/20/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/15/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	POET-Midfluent	04/11/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
05/09/2025		ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/02/2025		ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/20/2025		ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
10/15/2025		ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent		04/11/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/09/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/02/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/20/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/15/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	Unknown	Unknown				Unknown	Kitchen Sink	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
02/21/2025								0.52	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	0.31 J	0.46 J	ND<0.10	ND<0.0094	ND<0.12
POET-Influent							02/28/2025	0.18 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
							03/10/2025	0.42 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.41 J	0.30 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/07/2025	0.23 J	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/05/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/27/2025	0.69	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.30 J	0.34 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
11/05/2025			3.3	ND<0.19	ND<0.13		ND<0.19	ND<0.13	ND<0.13	0.24 J	0.16 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Midfluent			02/28/2025	ND<0.10	ND<0.10		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12			
			03/10/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/08/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/07/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/05/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/27/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
11/05/2025			ND<0.19	ND<0.19	ND<0.13		ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent			02/28/2025	ND<0.10	ND<0.10		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12			
			03/10/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/08/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/07/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/05/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/27/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
11/05/2025			ND<0.19	ND<0.19	ND<0.13		ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	146-160	100	Outside Spigot	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
				01/28/2025	0.92	6.6	ND<0.50	100	ND<0.50	1.0	84	47	23	ND<0.50	ND<0.0094	0.017 J
			POET-Influent	02/19/2025	0.13 J	0.27 J	0.72	29	ND<0.10	1.7	47	2.1	1.3	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	0.44 J	13	ND<0.10	0.94	30	0.32 J	0.22 J	ND<0.10	ND<0.0094	0.13 J
				03/20/2025	ND<0.19	ND<0.19	0.29 J	4.2 J	ND<0.13	1.3	19	2.8	1.4	ND<0.15	ND<0.005	ND<0.3
				03/27/2025	ND<0.19	ND<0.19	0.18 J	4.4	ND<0.13	0.98	18	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	0.13 J	8.2	ND<0.13	0.70	12	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	6.5	ND<0.13	0.52	11	ND<0.13	ND<0.15	ND<0.15	-	-
				05/07/2025	0.21 J	ND<0.19	ND<0.13	5.1	ND<0.13	0.53	11	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/01/2025	ND<0.19	ND<0.19	ND<0.13	1.5	ND<0.13	ND<0.13	2.1	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/18/2025	ND<0.19	ND<0.19	ND<0.13	0.61	ND<0.13	ND<0.13	0.66	0.21 J	0.19 J	ND<0.15	ND<0.005	ND<0.3
				09/15/2025	ND<0.19	ND<0.19	ND<0.13	0.53	ND<0.13	0.30 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/03/2025	ND<0.19	ND<0.19	ND<0.13	0.35 J	ND<0.13	ND<0.13	0.38 J	0.37 J	0.29 J	ND<0.15	ND<0.005	ND<0.3
				11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	0.24 J	ND<0.13	ND<0.13	0.21 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	ND<0.12
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	-	-
				05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0095	ND<0.12
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.45 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.42 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.43 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	-	-
				05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2
				11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	NA	NA	Bottom of Saltwater Pool	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~100	Unknown	Bathroom Sink	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
			Upstairs Bathroom Sink	01/30/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	Unknown	Utility Sink Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	0.63	ND<0.10	ND<0.10	0.63	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			POET-Influent	03/31/2025	28	25	0.64	250	ND<0.13	0.17 J	48	130	70	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	17	2.0	0.21 J	62	ND<0.13	1.4	50	2.5	1.0	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	14	0.48 J	ND<0.13	42	ND<0.13	0.74	34	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/25/2025	8.5	ND<0.19	ND<0.13	13	ND<0.13	ND<0.13	18	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/19/2025	7.9	ND<0.19	ND<0.13	11	ND<0.13	ND<0.13	15	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.3
				11/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~100	Unknown	Kitchen Sink Pressure Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.47 J
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
			POET-Influent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.15 J
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
			POET-Influent	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	09/30/2025	ND<0.19	0.21 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
			POET-Effluent	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			Basement Sink	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)				
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5				
~182	180		Kitchen Sink	01/23/2025	12	ND<0.50	ND<0.50	0.29	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0091	ND<0.12				
				01/30/2025	12	ND<0.50	ND<0.50	0.19	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J				
			Post-Treatment	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
				POET-Influent	02/25/2025	14	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.0	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/25/2025		8.8	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	1.2	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/06/2025		3.6	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/25/2025		1.3	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	0.89	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/22/2025		0.42 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	0.42 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/22/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Midfluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				10/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Effluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			Pool Water	08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				10/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
						Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12		
							02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
						Laundry Room Sink	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							POET-Influent	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
						06/03/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						08/26/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						11/03/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
POET-Midfluent	04/21/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	06/03/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/26/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	11/03/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	04/21/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	06/03/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	08/26/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	11/03/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
503	340					Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12		
							POET-Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
						03/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/12/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						07/29/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						09/22/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4
						11/17/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						POET-Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							07/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
							09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.90
							11/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				07/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				11/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
~220	Unknown	Bladder Tank Basement (Influent)	01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.63	
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J		
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		09/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1			
		03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		09/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
		02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
		03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	185-250	Unknown	Kitchen Sink	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink (First Floor)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
04/09/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
05/09/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/30/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
10/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
10/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
345	325	Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.23 J	
		03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2			
		03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J			
		POET-Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		10/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		10/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	10/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J		
			02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
		Kitchen Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
04/11/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
05/08/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
06/10/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Basement Sink (Effluent)	08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2-Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	200-220	~180	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank (Influent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.3
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.5
				07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.7
			POET-Influent	08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				07/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	180	Unknown	Front Spigot	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.28 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J
			POET-Influent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank (Influent)	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.93
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	5.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.6
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.90
				05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.2
				09/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.7
			Laundry Room Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.42 J
			POET-Midfluent	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
			Basement Sink (Effluent)	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5
				05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J
			Basement Kitchen Sink (Effluent)	07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.0
				09/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	1,2-Dichloroethane	1,2-Dibromoethane	Dissolved Lead	
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
450	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Influent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Unknown	Unknown	Pressure Tank	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.41 J
					03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Influent	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/05/2025	ND<0.19	1.7	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				10/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				12/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
POET-Midfluent	03/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	03/27/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/24/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/05/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/04/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
10/07/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
12/08/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	03/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	03/27/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/24/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/05/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/04/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
10/07/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
12/08/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown			Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.46 J
					Pressure Tank	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
		POET-Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
Unknown	180		Bladder Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
			POET-Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.22 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.14 J
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.24 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.16 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Unknown	Unknown	Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095
02/21/2025	ND<0.10	ND<0.10				ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.6	
POET-Influent	03/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	04/02/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.39 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	07/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/27/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/29/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
11/03/2025	ND<0.19	ND<0.19			ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Midfluent	03/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	04/02/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	07/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	08/27/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	08/29/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
11/03/2025	ND<0.19	ND<0.19			ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	03/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	04/02/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/13/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	07/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	08/27/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	08/29/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
11/03/2025	ND<0.19	ND<0.19			ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	1,2-Dichloroethane	1,2 Dibromoethane	Dissolved Lead		
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
DEP MSCs for a Residential, Used Aquifer																		
295	Unknown	Bladder Tank	01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	100	130	130	5	0.05	5		
		Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
		POET-Influent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
			03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			12/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			07/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.6	
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
	~600-700	~400	Bladder Tank	01/23/2025	15	6.7	2.7	49	ND<0.50	1.3	19	48	39	ND<0.50	ND<0.0092	5.2	
			Kitchen Sink	01/31/2025	8.9	3.7	1.7	25	ND<0.50	0.94	7.3	29	22	ND<0.50	ND<0.0093	0.23 J	
			POET-Influent	02/15/2025	25	6.7	4.1	44	0.12 J	1.9	20	49	34	ND<0.50	ND<0.0095	ND<0.12	
				02/24/2025	28	4.6	4.6	42	0.14 J	2.1	22	55	41	ND<0.50	ND<0.0094	0.15 J	
				03/24/2025	15	2.3	3.8	19	ND<0.13	2.0	18	77	48	0.40 J	ND<0.005	ND<0.3	
				05/19/2025	5.6	1.4	2.3	13	ND<0.13	1.5	14	68	40	ND<0.15	ND<0.005	ND<0.3	
				07/17/2025	7.0	1.4	2.1	14	ND<0.13	1.3	13	54	30	ND<0.15	ND<0.005	ND<0.3	
				08/13/2025	15	2.2	2.7	13	ND<0.13	1.3	14	46	23	ND<0.15	ND<0.005	ND<0.3	
				09/16/2025	24	3.4	4.6	15	ND<0.13	1.4	12	47	27	ND<0.15	ND<0.005	ND<0.3	
				10/13/2025	29	5.2	7.0	18	ND<0.13	1.6	17	49	23	ND<0.15	ND<0.005	ND<0.3	
				11/10/2025	23	3.4	8.7	24	ND<0.13	1.6	16	43	14	ND<0.15	ND<0.005	ND<0.3	
				12/08/2025	21	2.0	10	26	ND<0.13	1.8	14	46	2.9	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	0.17 J
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
400	230	Bladder Tank	01/23/2025	20	51	32	640	ND<0.50	7.6	120	310	120	ND<0.50	ND<0.0093	0.23 J		
		Post Treatment	02/07/2025	0.35 J	2.3	1.2	46	ND<0.50	0.26 J	29	19	11	ND<0.50	ND<0.0094	0.75		
This well was taken out of service on February 17, 2025																	
	420-450	300-430	Bladder Tank	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.4	
			Basement	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J	
			POET-Influent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5	
				11/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				11/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4	
			POET-Effluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
05/19/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
07/08/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
09/29/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
11/20/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2-Dibromo- ethane	Dissolved Lead		
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)			
DEP MSCs for a Residential, Used Aquifer																		
Possibly 300	Unknown	Unknown	Kitchen Sink	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12			
			POET-Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	0.24 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	11/18/2025	0.56	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J		
				11/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			550-585	540 or 550	Kitchen Sink	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
						02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.22 J	
						03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
09/16/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
11/10/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
POET-Midfluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
POET-Effluent	09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	11/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
New Pressure Tank	06/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	11/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
550	Unknown	Supply Tank Spigot	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J			
Unknown	Unknown	Pressure Tank	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	1.3		
			01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
		Kitchen Sink	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Influent	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/17/2025	5.5	ND<0.19	ND<0.13	0.78	ND<0.13	ND<0.13	1.6	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.23 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			09/24/2025	0.97	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			12/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			09/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			12/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	07/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	09/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1					
12/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3						

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
	Unknown	145	Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J		
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12		
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				POET-Midfluent	04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/06/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/10/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			12/04/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent		04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			~85-86	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
						02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
	03/15/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Pressure Tank (Influent)	04/07/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.25 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/05/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
		06/11/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
		10/06/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J		
12/01/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J			
POET-Midfluent		05/05/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	06/11/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/06/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J			
Kitchen Sink (Effluent)	12/01/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/07/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/05/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
1st Floor Kitchen Sink (Effluent)	06/11/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4					
	12/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005						
~80	Unknown	Pressure Tank	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10		ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
		POET-Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/14/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
10/28/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2-Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	125	125	Pressure Tank	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	41
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.9
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~200-210	~180	Pressure Tank (Influent)	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.66
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.95
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			POET-Influent													
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
			POET-Effluent	12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	10/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.55
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12		
			POET-Influent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
		03/24/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		04/24/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/21/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		07/07/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		10/20/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		~120-150	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
					POET-Influent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
03/21/2025	ND<0.19			ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
04/22/2025	ND<0.19			ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/03/2025	ND<0.19			ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
08/14/2025	ND<0.19			ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
10/10/2025	ND<0.19			ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent	03/21/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/22/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	06/03/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	10/10/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Effluent			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
03/21/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
04/22/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
06/03/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
08/14/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
10/10/2025				ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
89 or 109	Unknown			Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				Kitchen Sink (Effluent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				Pre-Treatment	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1
		POET-Influent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromomethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	~120	Unknown	Pressure Tank (Influent)	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.68
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.3	
			POET-Influent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Midfluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095
			03/24/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			06/05/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			08/06/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			10/07/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J
			12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink (Effluent)	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	06/05/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	08/06/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	10/07/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	600-705	600	Bathroom Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0							

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.22 J	
		POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		~80	Unknown	POET-Influent	07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
		POET-Midfluent	02/21/2														

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
Unknown	Unknown	Kitchen Sink	01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.12	
			Pressure Tank (Influent)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.6	
				07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7	
			POET-Influent	09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J	
				11/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4	
			POET-Midfluent	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				11/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Effluent	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		11/25/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Kitchen Sink Outside Spigot	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
			03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/20/2025	ND<0.19	58	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/26/2025	ND<0.19	1.7	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
04/21/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
05/22/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Midfluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	09/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Kitchen Sink Outside Spigot	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)			
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5			
Unknown	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.13 J			
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J			
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J			
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0			
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				08/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			600	334	Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.17 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.31 J	
					POET - Influent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
						03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.15 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
						07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						09/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2	
						09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					POET - Midfluent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
03/10/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
03/26/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
04/25/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
05/28/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
07/21/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
09/19/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
09/30/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
11/06/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
12/04/2025	ND<0.19	ND<0.19				ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET - Effluent	02/19/2025	ND<0.10			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
	03/10/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	03/26/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/21/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/19/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/30/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/06/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	12/04/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
~44	Unknown	Pressure Tank			02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.34 J		
		POET-Influent			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	1.2	
					03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.14 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		POET-Midfluent	11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		POET-Effluent	09/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			11/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13</											

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
EP MSCs for a Residential, Used Aquifer	>800	Unknown	Outside Spigot - Kitchen Sink Pressure Tank	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.40 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.32 J		
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.47 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	1.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3		
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.16 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.28 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.24 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.46 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.31 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.54	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.53	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1				
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			~150-200	~150-200	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.16 J	ND<0.50	0.23 J	1.1	0.71	ND<0.50	ND<0.0094	ND<0.12	
						02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.27 J	ND<0.10	ND<0.20	1.2	0.69	ND<0.10	ND<0.0095	ND<0.12	
					POET-Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.18 J	ND<0.13	ND<0.14	0.27 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
						07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	09/24/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.5				
	POET-Midfluent	03/06/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		03/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		05/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/18/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	09/24/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1				
	POET-Effluent	03/06/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		03/31/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		05/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		07/18/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	09/24/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	~350	230			Bathroom Sink	09/26/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
						01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
						02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			Pressure Tank (Influent)	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J	
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	04/14/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/12/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/07/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/03/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	09/12/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
Unknown	<250	Outside Spigot	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	4.0		
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1		
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
		POET-Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/27/2025	0.21 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			09/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		400	<350	Outside Spigot Outside Spigot (Pre-Kitchen Sink (Post-	09/25/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-
					01/31/2025	39	7.9	49	230	0.2	18	160	ND<0.50	180	ND<0.50	ND<0.0094	ND<0.12	
					01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63	
				POET-Influent	02/14/2025	92	80	41	310	0.33 J	13	110	280	120	ND<0.10	ND<0.0095	ND<0.12	
					02/24/2025	58	9.4	ND<0.10	250	0.42 J	ND<0.10	140	450	200	ND<0.10	ND<0.0094	ND<0.12	
					03/21/2025	150	36	17	390	0.30 J	9.8	120	480	210	4.3	ND<0.005	ND<0.3	
04/23/2025	39				5.5	7.5	200	0.64	3.6	82	240	98	ND<0.15	ND<0.005	ND<0.3			
05/19/2025	8.0				1.8	5.8	84	ND<0.13	3.6	110	280	160	ND<0.15	ND<0.005	ND<0.3			
06/19/2025	32				19	5.7	120	0.39 J	1.3	28	95	86	0.76	ND<0.005	ND<0.3			
07/03/2025	13				310	10	280	ND<0.13	3.2	34	190	150	0.16 J	ND<0.005	ND<0.3			
07/24/2025	0.98				11	3.4	80	0.51	1.2	20	72	99	ND<0.15	ND<0.005	ND<0.3			
09/02/2025	ND<0.19				ND<0.19	0.24 J	2.7	ND<0.13	0.21 J	2.7	14	68	ND<0.15	ND<0.005	ND<0.3			
09/18/2025	ND<0.19				ND<0.19	ND<0.13	0.90 J	ND<0.13	ND<0.13	0.92	2.7	66	ND<0.15	ND<0.005	1.0 J			
10/02/2025	0.51			1.4	1.7	17	0.20 J	0.63	8.2	38	76	ND<0.15	ND<0.005	ND<0.3				
10/28/2025	ND<0.19			0.30 J	0.22 J	3.7	ND<0.13	ND<0.13	2.0	8.9	23	ND<0.15	ND<0.005	ND<0.3				
POET-Midfluent	02/14/2025			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
	02/24/2025			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
	03/21/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/23/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/19/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	06/19/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/03/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/24/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	09/02/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.17 J	0.17 J	ND<0.15	ND<0.005	ND<0.3			
	09/18/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4			
10/02/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
10/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	02/14/2025			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
	02/24/2025			ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12			
	03/21/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	06/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	07/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2					
10/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3						
10/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3						
Effluent - Upstairs Bathroom	07/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	13.6					

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
EP MSCs for a Residential, Used Aquifer	300	200	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	20	840	100	130	130	5	0.05	0.17 J			
			Pressure Tank (Influent)	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12		
				03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.6 J		
				06/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	09/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			400	380-390	Pressure Tank (Influent)	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52
						02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
						03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	07/02/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Influent	08/27/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/21/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	NA	ND<0.3		
		03/20/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Kitchen Sink (Effluent)	04/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/09/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		07/02/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Effluent	08/27/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/21/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	NA	ND<0.3		
		124			100	Laundry Room Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094
	Kitchen Sink					03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						05/05/2025	ND<0.19	ND<0.19	0.19 J	0.89 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			06/02/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/31/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	10/03/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	12/01/2025			ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	05/05/2025			ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Midfluent		06/02/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/31/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/03/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.8 J		
	POET-Effluent		12/01/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/05/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			06/02/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	+340		340	Kitchen Sink		01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				POET-Influent		02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
						03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
04/28/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
05/30/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
07/18/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Midfluent		09/02/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		11/06/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		02/28/2025		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
POET-Effluent		03/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		05/30/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Midfluent		07/18/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		09/02/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	NA	ND<0.3			
		11/06/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		02/28/2025		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
		03/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		04/28/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.5 J					
	09/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	11/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12					
	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2-Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.26 J	
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.13 J
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			12/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			10/08/20														

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)		
	DEP MSCs for a Residential, Used Aquifer																	
					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
	150-200	150	Utility Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			Pressure Tank (Influent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.78	
			Utility Sink (Effluent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	0.36 J	
			POET-Influent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13		ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				06/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				12/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			147	~115	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.18 J
						03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	POET-Influent	04/12/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
		05/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.3 J		
		07/16/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
		10/16/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET-Midfluent	04/12/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		05/14/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
07/16/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
10/16/2025		ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	04/12/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/14/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	10/16/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
Unknown	Unknown	Pressure Tank			04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Pre-Carbon Treatment	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52			
		Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J		
			02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
		Irrigation Well	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	6.5		
Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J			
			02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12				
		Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		430	400	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				Kitchen Sink (First Floor)	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
04/01/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Influent	05/13/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Midfluent	05/13/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~600	Unknown	POET-Effluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Pressure Tank	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
		Spigot in Basement	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
	Unknown	Unknown	Kitchen Sink *bypassed Pressure Tank	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
			Influent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0	
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				Effluent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			03/14/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/14/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Backyard Spigot Outside Spigot (next to front door)	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.14 J	
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0 J	
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Influent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.6	
				POET - Midfluent	06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	570-700	700	Pressure Tank	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	5.6	
			Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				Influent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent		04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				Effluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Pressure Tank (Influent)	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12		
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Influent	07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				11/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			05/12/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/10/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
11/10/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	400	Unknown	Utility Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.33 J		
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.54	
			POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
05/12/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
07/22/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
10/29/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
340-400	340	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12		
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Influent	03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Midfluent	10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET - Effluent	06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		137	120	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
					03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Influent	05/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					07/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
POET-Midfluent	10/23/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	03/22/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
POET-Effluent	05/16/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~350	Unknown			Pressure Tank	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	24
					02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7	
				POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	07/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			11/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Unknown	Unknown	Bathroom Sink Next to Kitchen	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.16 J
					02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	0.16 J	
				Kitchen Sink	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					09/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
105	75			Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J
					03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Influent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Midfluent	07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Effluent	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
					05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	190	190	Pressure Tank (Influent)	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66 J
			POET-Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (Effluent)	11/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~65-80	Unknown	Bathroom Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.45 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
			POET-Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
			POET-Midfluent	08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	08/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	655	400	Pressure Tank	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			POET-Influent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300	100-150	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			POET-Influent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Laundry Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				07/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
			POET-Influent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	10/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	10/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
~75-90	70-90	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		~120	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
					03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Influent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				POET-Midfluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					05/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				POET-Effluent	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
05/17/2025	ND<0.19				ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
08/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
140	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	1.0	
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.9		
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.1		
		POET-Influent	05/10/2025	ND<0.19	ND<0.19	0.18 J	0.77	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
			07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7		
			10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J		
		POET-Midfluent	05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	05/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromomethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
~101	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J	
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			11/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
11/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
~212	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12
			02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
		Pressure Tank	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
			POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		06/02/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		08/25/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		200-400	250-350	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50
Bladder Tank	02/26/2025				ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.86
Kitchen Sink	02/26/2025				ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
POET-Influent	03/10/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	03/17/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.957 J	
	04/08/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/28/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
08/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Midfluent	03/10/2025			ND<0.19	0.29 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	03/17/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	04/08/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/01/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	05/28/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
08/25/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	03/10/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
163	162		Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			Pressure Tank (Influent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.73	
			Kitchen Sink (Effluent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20		ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			POET-Influent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Effluent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				10/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			500	170	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
						02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
					POET - Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethyl-benzene	Total Xylenes	MTBE	Isopropyl Benzene	Naph- thalene	1,2,4-Trimethyl- benzene	1,3,5-Trimethyl- benzene	1,2-Dichloro- ethane	1,2-Dibromo- ethane	Dissolved Lead
		(µg/L)			(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
DEP MSCs for a Residential, Used Aquifer																
~ 92	Unknown	Pressure Tank		02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63
			Kitchen Sink	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005
		POET-Influent		05/20/2025	ND<0.19	ND<0.19	0.80	3.9	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent		05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent		05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
150-160	120-130	Kitchen Sink		02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.17 J
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
		POET-Influent		03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent		03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent		03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
Unknown	Unknown	Pressure Tank (Influent)		02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	2.5
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
		POET-Influent		04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent		04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				11/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		Kitchen Sink (Effluent)		03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent		04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				08/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	11/13/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
250	~240	Bar sink- bypassed softener		02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.76	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.91
~65-90	~62-65	Bathroom Sink		02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
		Kitchen Sink		03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		Pressure Tank		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
		Basement Sink (Effluent)		05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromomethane (µg/L)	Dissolved Lead (µg/L)			
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5			
223	223	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.65			
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			POET-Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				11/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
						02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
						03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					Pressure Tank (Influent)	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
						11/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
					POET-Influent	05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
POET-Midfluent	03/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/14/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
11/07/2025	ND<0.19	ND<0.19			ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent	03/28/2025	ND<0.19			ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	05/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
11/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3						
~ 200	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12				
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12				
		POET-Influent	03/19/2025	ND<0.19	0.23 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			09/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Midfluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			09/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
04/22/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
05/21/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
09/23/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
~125-180	Unknown	Outside Spigot	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.3				
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7				
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J				
			04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J				
			07/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J				
		10/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J					
		Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12				
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12				
			03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			05/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			08/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
			11/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)			
DEP MSCs for a Residential, Used Aquifer																			
Unknown	Unknown	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
			Pre -Water Softener	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	0.23 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank (Influent)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Main Well (Well 1)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Influent (Well 1)	11/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank (Influent)	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
				05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Back-up Well (Well 2, Old Well)	11/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Influent (Well 2)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent - Main Well (Well 1, New Well)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent - Back-up Well (Well 2, Old Well)	11/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET-Midfluent (Combined)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
04/22/2025	ND<0.19	ND<0.19		ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Effluent - Main Well (Well 1, New Well)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Effluent - Back-up Well (Well 2, Old Well)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent (Combined)	05/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	11/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
Unknown	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
			02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
			02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.60			
		Outside Spigot Next to Outside Spigot	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		10/16/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
POET-Effluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	07/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	10/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
980	690	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
			02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
		03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		Influent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
220-225	200+	Kitchen Sink	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12			
			02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
			04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			10/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
400	~400	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.37 J			
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			11/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		POET-Midfluent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			08/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent (Sink)	11/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
05/22/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15							

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2 Dibromoethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	232	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.16 J
			Kitchen Sink (First Floor)	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink	04/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			POET - Influent	06/16/2025	ND<0.19	ND<0.19	0.55	2.2	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			POET - Midfluent	06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET - Effluent	06/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	75	65	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~35	Unknown	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~140	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.4
			POET-Influent	04/29/2025	ND<0.19	ND<0.19	0.19 J	0.70	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				10/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	04/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	10/29/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	09/12/2025	ND<0.19		ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
			03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J	
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12	
			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~50-192	Close to the bottom	Pressure Tank	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	220
			Pressure Tank (Influent)	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
				04/04/2025	ND<0.19	4.6	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent	05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink (Effluent)	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/04/2025	ND<0.19	0.31 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
	200-100	Unknown-Unknown	Kennel Main House	02/27/2025 02/27/2025	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.20 ND<0.20	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.10 ND<0.10	ND<0.0094 ND<0.0095	ND<0.12 ND<0.12	
	100-150	Jet Pump	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.23 J	
	500-600	360-400	Kitchen Sink	02/07/2025	0.18 J	120	ND<0.50	ND<0.50	ND<0.50	0.12 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/18/2025	0.14 J	80	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
				03/25/2025	ND<0.19	40	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/02/2025	ND<0.19	13	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				08/25/2025	ND<0.19	4.1	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				12/08/2025	ND<0.19	2.0	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.41 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	240	200	Outside Spigot	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				09/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
	~25	Jet Pump	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
				04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	26'9"	20	Basement Bathroom	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J	
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	90-92	60-92	Pressure Tank (Influent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/24/2025	ND<0.19	ND<0.19	0.17 J	0.50	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Kitchen Sink (Effluent)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~40	32-40	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.22 J	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				06/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Basement Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J	
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	45-50	Unknown	Laundry Room Utility	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Kitchen Sink	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Island Sink	05/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	~240	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J	
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.7	
			Influent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	Unknown	Kitchen Sink	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	115	100	Pre-Treatment Pressure Tank (Influent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0098	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Basement Sink (Effluent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink (First Floor)	05/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	NA	NA	Northwest Side of Pond	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Well (Outfall Pipe)	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Bathroom Sink (First	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	80-100	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~150	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~140	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink (First Floor)	03/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)		
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5		
	280	270	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Midfluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Effluent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Influent (Carbon Filter)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.8		
			POET-Influent	05/08/2025	ND<0.19	ND<0.19	0.21 J	0.87 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Kitchen Sink (Effluent)	04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J		
			POET-Effluent	05/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				07/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	06/24/2025	ND<0.19	ND<0.19	0.22 J	0.65	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	POET-Effluent	06/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			~300	~297	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
					Influent (Pressure Tank)	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
						04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
						05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
	POET-Midfluent	03/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		04/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13											

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2 Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	~80	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/30/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~200	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	85-88	~70	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	310	~240	Basement Spigot	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	-	-	Pressure Tank	09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	8.5
			Kitchen Sink	09/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
	Unknown	Unknown	Influent Kitchen Sink (Effluent)	03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	4.2
				03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
	~ 90	Unknown	Kitchen Sink	02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.41 J
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	123	Unknown	Office Downstairs	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	90	~90	Basement (Pre-	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink (Effluent)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Pressure Tank	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.50 J
			Basement Utility Sink	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	26	26	Kitchen Sink													
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	240	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	200	~75	Untreated hose in closet	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.30 J	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.6
			Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Influent	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Midfluent	05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			POET-Effluent	05/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
265	210	Pressure Tank	02/07/2025	0.44 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.21 J	
			02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
		Utility Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
		POET-Influent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	05/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent	03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
125-165	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Influent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Midfluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent	03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
~30	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12		
			03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Influent	03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Midfluent	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent	04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0									

Table 1
Potable Well Analytical Results Summary

	Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (ug/L)	Toluene (ug/L)	Ethyl-benzene (ug/L)	Total Xylenes (ug/L)	MTBE (ug/L)	Isopropyl Benzene (ug/L)	Naphthalene (ug/L)	1,2,4-Trimethylbenzene (ug/L)	1,3,5-Trimethylbenzene (ug/L)	1,2-Dichloroethane (ug/L)	1,2 Dibromoethane (ug/L)	Dissolved Lead (ug/L)	
EP MSCs for a Residential, Used Aquifer						5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
	Unknown	Unknown	Basement Bathroom Sink Influent (Pressure Tank) Effluent (Basement)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J		
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	300+	~300	Outside Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J		
			POET - Influent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET - Midfluent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET - Effluent	04/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	Unknown	Unknown	Kitchen Sink	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	700-720	340-350	Pressure Tank Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			First Floor Kitchen Sink (Effluent)	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			POET - Influent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	POET - Midfluent	06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
		06/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
	Unknown	400	Outside Spigot (South Side of House)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	0.3 J	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Influent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			POET-Midfluent	05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
				05/13/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
	600 - 700	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9		
			03/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9			
			POET-Influent	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7		
				07/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9		
10/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.3				
POET-Midfluent			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			07/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
10/15/2025			ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
POET-Effluent			05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
	07/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
10/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3						
Unknown	300	Spigot Near Blue	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.6	
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Influent	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			11/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J			
		POET-Midfluent	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			11/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	05/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			11/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
~290	Unknown	Kitchen Sink	02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12		
			03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.014	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Influent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.5			
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.9 J			
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2			
			12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.2			
		POET-Midfluent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
		POET-Effluent	03/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			06/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			08/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			
			12/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3			

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethyl-benzene (µg/L)	1,3,5-Trimethyl-benzene (µg/L)	1,2-Dichloro-ethane (µg/L)	1,2 Dibromo-ethane (µg/L)	Dissolved Lead (µg/L)	
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
~350	Unknown	Pre-Treatment Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.34 J	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Influent	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Midfluent	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		POET-Effluent	05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3
310	280	Kitchen Sink (First Floor)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/22/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Spigot Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7		
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.16 J		
340	120	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.6	
		Pressure Tank (Influent)	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.1	
			03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.2	
Unknown	Unknown	Pressure Tank	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.4 J	
			02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2	
		Kitchen Sink	03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~400-600	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Basement Kitchen Sink	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
400	380	Pressure Tank (Influent) Basement Bathroom Sink Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.8	
			02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			04/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
400	380	Pressure Tank (Influent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.3 J	
		Kitchen Sink (Effluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
600	50-500	Pre-Treatment Spigot Near Supply Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Pressure Tank (Influent)	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
280-400	260	Bathroom Sink (Basement)	04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
400	360	Pre-Treatment	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Unknown	Unknown	Pre-Treatment	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J	
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Kitchen Sink Pressure Tank (Influent)	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	0.9 J	
			04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Midfluent	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Basement Sink (Effluent)	04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink Island	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			03/19/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
400	380	Outside Spigot	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12		
			03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
500	480	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J	
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	1.7	
		Bladder Tank	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	2.2	
			05/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	2.7	
			06/02/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.15	ND<0.005	6.6	
			Refrigerator	04/03/2025	ND<0.19	ND<0.19											

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromothene (µg/L)	Dissolved Lead (µg/L)
					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
EP MSCs for a Residential, Used Aquifer	600	500	Filtered Drinking Water	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.0094	ND<0.12	
				04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
	500	480	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
600	500	Pressure Tank (Influent)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3		
		Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6		
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
650	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Basement Sink	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
265-360	260	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
		Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Influent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J		
		Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
		Effluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
300	260	Pressure Tank	04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~700	240	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
~300+	Unknown	Pressure Tank	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
		Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
		04/11/2025		ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Maybe 200	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Midfluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Effluent	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			05/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
188	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
			03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		POET-Influent	03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
		Influent	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
300	150	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J		
		Influent - Pressure Tank	06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0	
			Effluent - Kitchen Sink	06/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	60	45	Pressure Tank	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	25	~25	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
	33	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	65	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	57	48	Pressure Tank	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.5
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
				03/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	45	40	Port closest to well in the basement.	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2
	35-50	Unknown	Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~150	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	04/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	Unknown	Unknown	Upstairs Kitchen Sink	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				03/27/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	450 or 650	Unknown	Kitchen Sink	05/29/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	60-80	45-60	Kitchen Sink	04/23/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/26/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	04/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/31/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	60-70	60-65	Kitchen Sink	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	>400	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	ND<0.12
			Kitchen Sink	03/17/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank (Influent)	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Main House Well - Unknown	Main House Well - Unknown	Kitchen Sink (Effluent)	04/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Main House Well - Kitchen Sink	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Main House POET-Influent	08/25/2025	ND<0.19	ND<0.19	ND<0.13	0.40 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	0.31 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Main House POET-Midfluent	08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Main House POET-Effluent	08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Guest House	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Guest House Well - Kitchen Sink	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.5 J
	Guest House Well - 810	Guest House Well - 800	Guest House POET-Influent	08/25/2025	ND<0.19	ND<0.19	0.44 J	1.7 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
				09/09/2025	ND<0.19	ND<0.19	0.27 J	1.4 J	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Guest House POET-Midfluent	08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	650	450	Kitchen Sink (Effluent)	08/25/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				09/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naph- thalene (µg/L)	1,2,4-Trimethyl- benzene (µg/L)	1,3,5-Trimethyl- benzene (µg/L)	1,2-Dichloro- ethane (µg/L)	1,2-Dibromo- ethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	~200	70	Pressure Tank Spigot Kitchen Sink	03/08/2025 04/08/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	0.8 J ND<0.3
	Unknown	Unknown	Kitchen Sink (non-RO) Laundry Room Sink	03/20/2025 04/15/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
	Unknown	Unknown	Garage Spigot	02/28/2025 04/14/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 0.24 J	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0095 ND<0.005	ND<0.12 ND<0.3
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/14/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Bladder Tank	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.4
	Unknown	Unknown	Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Effluent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink (First Floor) Kitchen Sink	02/22/2025 03/18/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~60-90	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
	~70-90	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
	Unknown	460	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~300	Unknown	Kitchen Sink	02/22/2025 03/19/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
	60	Unknown	Kitchen Sink	03/18/2025 04/16/2025	ND<0.19 ND<0.19	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.19 ND<0.19	ND<0.13 ND<0.13	ND<0.13 ND<0.13	ND<0.14 ND<0.14	ND<0.13 ND<0.13	ND<0.15 ND<0.15	ND<0.15 ND<0.15	ND<0.005 ND<0.005	ND<0.3 ND<0.3
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~60-70	Unknown	Kitchen Sink	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
	41	Unknown	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.18 J
	~70	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/20/2025 03/05/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~200	Unknown	Kitchen Sink (First Floor) Pre-Treatment Basement	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	300	Unknown	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	144	Unknown	Pressure Tank	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	7.2
	~75	Unknown	Bathroom Sink	02/21/2025 03/07/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0095 ND<0.005	0.39 J ND<0.3
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink - (Cottage)	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink													
	120	100	Kitchen Sink	02/20/2025 03/31/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Couple Hundred Feet	Unknown	Kitchen Sink	04/21/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	270	260	Pressure Tank	04/24/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink													
			Pressure Tank													

Table 1
Potable Well Analytical Results Summary

Sample Address	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (µg/L)	1,2-Dibromoethane (µg/L)	Dissolved Lead (µg/L)
EP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	500	460-480	Kitchen Sink-1 Apartment (Effluent1)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	460-480	400-445	Kitchen Sink-2 House (Effluent2)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.18 J
				03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
				04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	Unknown	Unknown	Basement (Influent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
				03/27/2025	0.72	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Pressure Tank (Influent)	04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.35 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/28/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	450	~440	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	270	270	Utility Sink in Garage Utility Sink in Garage	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.34 J
				04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.017 J
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Kitchen Sink	04/16/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				07/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.9
	~100	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	140	140	Pressure Tank	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/20/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				05/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	128	Unknown	Kitchen Sink (First Floor)	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				04/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
	185	Unknown	Kitchen Sink	03/15/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~30-50	Unknown	Kitchen Sink (Effluent)	03/18/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	300	Unknown	Pressure Tank Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~30	Unknown	Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.52
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Influent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	04/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	350	300	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	15	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	200 Unknown	Unknown 300	Well 15	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Well 9	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	~90	Kitchen Sink	04/09/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Utility Sink (near Kitchen)	04/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Notes:
DEP = Pennsylvania Department of Environmental Protection
MSCs = Medium-Specific Concentrations per 25 Pa. Code Chapter 250
µg/L = Micrograms/Liter
ND<# = Not Detected (# is method detection limit)
NA = Not Available or Not Analyzed
MDL = Method Detection Limit
RL = Reporting Limit
PID = Photoionization Detector
ppm = Parts Per Million
J = Approximate value; result is < RL and ≥ MDL
* = See laboratory report for qualifiers
Bold = Exceeds the DEP MSC for a Used, Residential Aquifer < 2,500 mg/L total dissolved solids
Volatiles analyzed via EPA Method 524.2
EDB analyzed via EPA Method 8011 through 2/28/2025; samples collected beginning 3/1/2025 analyzed via EPA Method 504
Dissolved Lead analyzed via EPA Method 200.8