WATER.
AT YOUR SERVICE

Vanport Township Municipal Authority

285 RIVER AVENUE VANPORT, PENNSYLVANIA 15009 (412) 774-2091 (412) 775-1038

November 13, 1991

Westinghouse Corporation 1 Tuscarawas Road Beaver, PA 15009

ATTN: E.F. FARLAND

Dear Mr. Farland:

Please find attached your correspondence to C.W. Smith Contracting, Inc. dated October 1, 1991 and correspondence from our Authority dated August 12, 1991 regarding installation of the sloped overlay.

Please note in VTMA letter dated August 12, per paragraph 3, the Authority states that all work is to be peformed by Sika licensed applicators and performed in strict accordance with Sika. Vanport Township Municipal Authority is definite in this statement and will not accept the work to be performed by anyone other than a Sika licensed applicator as originally stated. (

If you have any questions, please call the Authority

By Order of the Authority,

Dana J. Lengyel

SECRETARY/TREASURER

DJL/djl

Attachments



Westinghouse Electric Corporation

Distribution and Control

1 Tuscarawas Road Beaver Pennsylvania 15009 (412) 775 2000

October 1, 1991

C.W. Smith Contracting, Inc. 978 Shenango Road Beaver Falls, PA 15010 Attn: Gary Campbell

Dear Gary:

Attached is an approval letter from the Vanport Municipal Authority concerning the installation of the sloped overlay to the pump room floor at the Stripping Towers. This work should be scheduled for late fall, when the heating system is on and condensation on the piping is reduced. This will allow the work to preceed in relatively dry conditions.

As far as the installation being performed by a Sika licensed applicator, I think that is a good idea if you subcontract the work, but if you elect to do the work with your people, I will discuss that with the Authority.


Please advise when this work can be scheduled.

Sincerely,

E.F.Farland

cc: VIMA - Ron Bumiller, Chairman

Attachment .
CWSMITH/s



Vanport Township Municipal Authority

285 RIVER AVENUE VANPORT, PENNSYLVANIA 15009 (412) 774-2091 (412) 775-1038

August 12, 1991

Westinghouse Electric Corporation 1 Tuscarawas Road Beaver, Pa 15009

Attn:

E.F. Farland

Manager, Works Engineering

Dear Mr. Farland:

Please be advised, per your attached correspondence dated June 6, 1991, that Vanport Township Municipal Authority accepts your proposal to provide a bonded overlay to provide a slope to the drains and that it is to be painted by Westinghouse Corporation.

Also, the Authority is in agreement that a polymer improved repair mortar should be used per floor overlay spec as submitted. (Also attached).

Upon acceptance of said proposal, Vanport Township Municipal Authority understand that all work to be performed by Sika licensed applicator and performed in strict accordance with Sika installation instructions.

By Order of the Authority,

Ropáld L. Bumiller

Chairman

Signed:

Date:

Westinghouse Electric Corporation